



AMIDON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	AMIDON ELEMENTARY SCHOOL	WS- 003543	8/21/2016	1	Fountain	In classroom B126	FT-82016-003543-A	< 1	FT-82016-003543-B	< 1
2	AMIDON ELEMENTARY SCHOOL	WS- 003544	8/21/2016	1	Cooler	In hallway adjacent to classroom B128 High Left	FT-82016-003544-A	< 1	FT-82016-003544-B	< 1
3	AMIDON ELEMENTARY SCHOOL	WS- 003545	8/21/2016	1	Cooler	In hallway adjacent to classroom B128 Low Right	FT-82016-003545-A	< 1	FT-82016-003545-B	< 1
4	AMIDON ELEMENTARY SCHOOL	WS- 003547	8/21/2016	1	Fountain	In classroom B128	FT-82016-003547-A	< 1	FT-82016-003547-B	< 1
5	AMIDON ELEMENTARY SCHOOL	WS- 003549	8/21/2016	1	Cooler	In hallway adjacent to gym	FT-82016-003549-A	< 1	FT-82016-003549-B	< 1
6	AMIDON ELEMENTARY SCHOOL	WS- 003550	8/21/2016	1	Cooler	In gym	FT-82016-003550-A	< 1	FT-82016-003550-B	< 1
7	AMIDON ELEMENTARY SCHOOL	WS- 003551	8/21/2016	1	Cooler	In classroom D161A Left	FT-82016-003551-A	< 1	FT-82016-003551-B	< 1
8	AMIDON ELEMENTARY SCHOOL	WS- 003557	8/21/2016	1	Food Prep Sink	In kitchen on south wall Right	FT-82016-003557-A	< 1	FT-82016-003557-B	< 1
9	AMIDON ELEMENTARY SCHOOL	WS- 003558	8/21/2016	1	Cooler	In hallway adjacent to kitchen	FT-82016-003558-A	< 1	FT-82016-003558-B	< 1
10	AMIDON ELEMENTARY SCHOOL	WS- 003560	8/21/2016	1	Fountain	In classroom A106 High Left	FT-82016-003560-A	< 1	FT-82016-003560-B	< 1
11	AMIDON ELEMENTARY SCHOOL	WS- 003562	8/21/2016	1	Fountain	In classroom A106 Low Right	FT-82016-003562-A	< 1	FT-82016-003562-B	< 1
12	AMIDON ELEMENTARY SCHOOL	WS- 003564	8/21/2016	1	Fountain	In classroom A103 Low Left	FT-82016-003564-A	< 1	FT-82016-003564-B	< 1
13	AMIDON ELEMENTARY SCHOOL	WS- 003566	8/21/2016	1	Fountain	In classroom A103 High Right	FT-82016-003566-A	< 1	FT-82016-003566-B	< 1
14	AMIDON ELEMENTARY SCHOOL	WS- 003568	8/21/2016	1	Fountain	In classroom A105 High Left	FT-82016-003568-A	< 1	FT-82016-003568-B	< 1
15	AMIDON ELEMENTARY SCHOOL	WS- 003570	8/21/2016	1	Fountain	In classroom A105 Low Right	FT-82016-003570-A	< 1	FT-82016-003570-B	< 1
16	AMIDON ELEMENTARY SCHOOL	WS- 003571	8/21/2016	1	Cooler	In hallway adjacent to health suite A116	FT-82016-003571-A	< 1	FT-82016-003571-B	< 1
17	AMIDON ELEMENTARY SCHOOL	WS- 003573	8/21/2016	1	Fountain	In classroom A107 Low Left	FT-82016-003573-A	< 1	FT-82016-003573-B	< 1
18	AMIDON ELEMENTARY SCHOOL	WS- 003575	8/21/2016	1	Fountain	In classroom A107 High Right	FT-82016-003575-A	< 1	FT-82016-003575-B	< 1
19	AMIDON ELEMENTARY SCHOOL	WS- 003576	8/21/2016	1	Cooler	In health suite A116	FT-82016-003576-A	< 1	FT-82016-003576-B	< 1
20	AMIDON ELEMENTARY SCHOOL	WS- 003578	8/21/2016	2	Fountain	In classroom A212	FT-82016-003578-A	< 1	FT-82016-003578-B	< 1
21	AMIDON ELEMENTARY SCHOOL	WS- 003580	8/21/2016	2	Fountain	In classroom A213	FT-82016-003580-A	< 1	FT-82016-003580-B	< 1
22	AMIDON ELEMENTARY SCHOOL	WS- 003582	8/21/2016	2	Fountain	In classroom A209	FT-82016-003582-A	< 1	FT-82016-003582-B	< 1
23	AMIDON ELEMENTARY SCHOOL	WS- 003584	8/21/2016	2	Fountain	In classroom A208	FT-82016-003584-A	< 1	FT-82016-003584-B	< 1
24	AMIDON ELEMENTARY SCHOOL	WS- 003585	8/21/2016	2	Cooler	In hallway between girls' and boys' restrooms High Left	FT-82016-003585-A	< 1	FT-82016-003585-B	< 1
25	AMIDON ELEMENTARY SCHOOL	WS- 003586	8/21/2016	2	Cooler	In hallway between girls' and boys' restrooms Low Right	FT-82016-003586-A	< 1	FT-82016-003586-B	< 1
26	AMIDON ELEMENTARY SCHOOL	WS- 003588	8/21/2016	2	Fountain	In classroom A202	FT-82016-003588-A	< 1	FT-82016-003588-B	< 1
27	AMIDON ELEMENTARY SCHOOL	WS- 003590	8/21/2016	2	Fountain	In classroom B223	FT-82016-003590-A	< 1	FT-82016-003590-B	< 1
28	AMIDON ELEMENTARY SCHOOL	WS- 003592	8/21/2016	2	Fountain	In classroom B230	FT-82016-003592-A	< 1	FT-82016-003592-B	< 1
29	AMIDON ELEMENTARY SCHOOL	WS- 003594	8/21/2016	2	Fountain	In classroom B225	FT-82016-003594-A	< 1	FT-82016-003594-B	< 1
30	AMIDON ELEMENTARY SCHOOL	WS- 003596	8/21/2016	2	Fountain	In classroom B232	FT-82016-003596-A	< 1	FT-82016-003596-B	< 1
31	AMIDON ELEMENTARY SCHOOL	WS- 003598	8/21/2016	2	Fountain	In classroom B227	FT-82016-003598-A	< 1	FT-82016-003598-B	< 1
32	AMIDON ELEMENTARY SCHOOL	WS- 003600	8/21/2016	2	Fountain	In classroom B236	FT-82016-003600-A	< 1	FT-82016-003600-B	< 1
33	AMIDON ELEMENTARY SCHOOL	WS- 003602	8/21/2016	2	Fountain	In classroom B231	FT-82016-003602-A	< 1	FT-82016-003602-B	< 1
34	AMIDON ELEMENTARY SCHOOL	WS- 003603	8/21/2016	1	Health Suite	In health suite A116 in bathroom	FT-82016-003603-A	< 1	FT-82016-003603-B	< 1
35	AMIDON ELEMENTARY SCHOOL	WS- 003604	8/21/2016	2	Cooler	In hallway between library and stairwell C	FT-82016-003604-A	< 1	FT-82016-003604-B	< 1
36	AMIDON ELEMENTARY SCHOOL	WS- 003606	8/21/2016	2	Fountain	In ESL teacher room adjacent to classroom 269	FT-82016-003606-A	< 1	FT-82016-003606-B	< 1