



AMIDON LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003606	Fountain	2	In ESL teacher room adjacent to classroom 269	WT-042916-3623- A	< 2	WT-042916-3623- B	< 2				
2	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003605	Classroom	2	In ESL teacher room adjacent to classroom 269	WT-042916-3622- A	< 2	WT-042916-3622- B	< 2				
3	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003604	Cooler	2	In hallway between library and stairwell C	WT-042916-3621- A	< 2	WT-042916-3621- B	< 2				
4	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003603	Health Suite	1	In health suite A116 (utility sink)	WT-042916-3620- A	3.4	WT-042916-3620- B	< 2				
5	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003602	Fountain	2	In classroom B231	WT-042916-3619- A	< 2	WT-042916-3619- B	< 2				
6	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003601	Classroom	2	In classroom B231	WT-042916-3618- A	12.4	WT-042916-3618- B	< 2				
7	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003600	Fountain	2	In classroom B236	WT-042916-3617- A	< 2	WT-042916-3617- B	< 2				
8	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003599	Classroom	2	In classroom B236	WT-042916-3616- A	< 2	WT-042916-3616- B	< 2				
9	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003598	Fountain	2	In classroom B227	WT-042916-3615- A	< 2	WT-042916-3615- B	< 2				
10	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003597	Classroom	2	In classroom B227	WT-042916-3614- A	< 2	WT-042916-3614- B	< 2				
11	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003596	Fountain	2	In classroom B232	WT-042916-3613- A	< 2	WT-042916-3613- B	< 2				
12	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003595	Classroom	2	In classroom B232	WT-042916-3612- A	< 2	WT-042916-3612- B	< 2				
13	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003594	Fountain	2	In classroom B225	WT-042916-3611- A	< 2	WT-042916-3611- B	< 2				
14	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003593	Classroom	2	In classroom B225	WT-042916-3610- A	< 2	WT-042916-3610- B	< 2				
15	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003592	Fountain	2	In classroom B230	WT-042916-3609- A	< 2	WT-042916-3609- B	< 2				
16	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003591	Classroom	2	In classroom B230	WT-042916-3608- A	< 2	WT-042916-3608- B	< 2				
17	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003590	Fountain	2	In classroom B223	WT-042916-3607- A	< 2	WT-042916-3607- B	< 2				
18	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003589	Classroom	2	In classroom B223	WT-042916-3606- A	< 2	WT-042916-3606- B	< 2				
19	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003588	Fountain	2	In classroom A202	WT-042916-3605- A	< 2	WT-042916-3605- B	< 2				
20	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003587	Classroom	2	In classroom A202	WT-042916-3604- A	< 2	WT-042916-3604- B	< 2				
21	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003586	Cooler	2	In A section hallway between girls and boys restrooms Right Low	WT-042916-3603- A	< 2	WT-042916-3603- B	< 2				
22	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003585	Cooler	2	In A section hallway between girls and boys restrooms Left High	WT-042916-3602- A	< 2	WT-042916-3602- B	< 2				
23	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003584	Fountain	2	In classroom A208	WT-042916-3601- A	< 2	WT-042916-3601- B	< 2				
24	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003583	Classroom	2	In classroom A208	WT-042916-3600- A	< 2	WT-042916-3600- B	< 2				
25	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003582	Fountain	2	In classroom A209	WT-042916-3599- A	< 2	WT-042916-3599- B	< 2				
26	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003581	Classroom	2	In classroom A209	WT-042916-3598- A	< 2	WT-042916-3598- B	< 2				
27	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003580	Fountain	2	In classroom A213	WT-042916-3597- A	< 2	WT-042916-3597- B	< 2				
28	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003579	Classroom	2	In classroom A213	WT-042916-3596- A	< 2	WT-042916-3596- B	< 2				
29	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003578	Fountain	2	In classroom A212	WT-042916-3595- A	< 2	WT-042916-3595- B	< 2				
30	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003577	Classroom	2	In classroom A212	WT-042916-3594- A	< 2	WT-042916-3594- B	< 2				
31	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003576	Health Suite	1	In health suite A116	WT-042916-3593- A	< 2	WT-042916-3593- B	< 2				
32	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003575	Fountain	1	In classroom A107 Right High	WT-042916-3592- A	< 2	WT-042916-3592- B	< 2				
33	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003574	Classroom	1	In classroom A107 Right High	WT-042916-3591- A	< 2	WT-042916-3591- B	< 2				
34	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003573	Fountain	1	In classroom A107 adjacent to restroom Left Low	WT-042916-3590- A	< 2	WT-042916-3590- B	< 2				
35	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003572	Classroom	1	In classroom A107 adjoining restroom Left Low	WT-042916-3589- A	< 2	WT-042916-3589- B	< 2				
36	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003571	Cooler	1	In hallway adjacent to health suite A116	WT-042916-3588- A	< 2	WT-042916-3588- B	< 2				
37	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003570	Fountain	1	In classroom A105 Right Low	WT-042916-3587- A	< 2	WT-042916-3587- B	< 2				
38	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003569	Classroom	1	In classroom A105 Right Low	WT-042916-3586- A	< 2	WT-042916-3586- B	< 2				
39	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003568	Fountain	1	In classroom A105 Left High	WT-042916-3585- A	< 2	WT-042916-3585- B	< 2				
40	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003567	Classroom	1	In classroom A105 Left High	WT-042916-3584- A	< 2	WT-042916-3584- B	< 2				
41	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003566	Fountain	1	In classroom A103 Right High	WT-042916-3583- A	< 2	WT-042916-3583- B	< 2				
42	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003565	Classroom	1	In classroom A103 Right High	WT-042916-3582- A	< 2	WT-042916-3582- B	< 2				
43	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003564	Fountain	1	In classroom A103 Left Low	WT-042916-3581- A	< 2	WT-042916-3581- B	< 2				
44	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003563	Classroom	1	In classroom A103 Left Low	WT-042916-3580- A	< 2	WT-042916-3580- B	< 2				
45	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003562	Fountain	1	In classroom A106 Right	WT-042916-3579- A	< 2	WT-042916-3579- B	< 2				
46	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003561	Classroom	1	In classroom A106 Right	WT-042916-3578- A	< 2	WT-042916-3578- B	< 2				
47	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003560	Fountain	1	In classroom A106 Left	WT-042916-3577- A	< 2	WT-042916-3577- B	< 2				
48	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003559	Classroom	1	In classroom A106 Left	WT-042916-3576- A	< 2	WT-042916-3576- B	< 2				
49	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003558	Cooler	1	In hallway between cafeteria and kitchen	WT-042916-3575- A	< 2	WT-042916-3575- B	< 2				
50	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003557	Kitchen	1	In kitchen (south wall sink)	WT-042916-3574- A	< 2	WT-042916-3574- B	< 2				
51	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003556	Kitchen	1	In kitchen (south wall spray nozzle) In first floor lobby adjacent to principal's office B121	WT-042916-3573- A	< 2	WT-042916-3573- B	< 2				
52	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003555	Break Room	1	In first floor lobby adjacent to principal's office B121	WT-042916-3572- A	< 2	WT-042916-3572- B	< 2				
53	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003554	Classroom	1	In classroom D161B (right)	WT-042916-3571- A	< 2	WT-042916-3571- B	< 2				
54	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003553	Other	1	In classroom 161A (left, spray nozzle)	WT-042916-3570- A	< 2	WT-042916-3570- B	< 2				
55	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003552	Classroom	1	In classroom D161A (left)	WT-042916-3569- A	3.1	WT-042916-3569- B	< 2				
56	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003551	Cooler	1	Inside classroom D161 A (left)	WT-042916-3568- A	< 2	WT-042916-3568- B	< 2				
57	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003550	Cooler	1	Inside gymnasium	WT-042916-3567- A	< 2	WT-042916-3567- B	< 2				
58	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003549	Cooler	1	In hallway adjacent to gymnasium	WT-042916-3566- A	< 2	WT-042916-3566- B	< 2				
59	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003548	Break Room	1	In workroom B137	WT-042916-3565- A	< 2	WT-042916-3565- B	< 2				



AMIDON LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
60	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003547	Fountain	1	In classroom B128	WT-042916-3564- A	< 2	WT-042916-3564- B	< 2				
61	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003546	Classroom	1	In classroom B128	WT-042916-3563- A	< 2	WT-042916-3563- B	< 2				
62	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003545	Cooler	1	In hallway adjacent to classroom B128 Right Low	WT-042916-3562- A	< 2	WT-042916-3562- B	< 2				
63	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003544	Cooler	1	In hallway adjacent to classroom B128 Left High	WT-042916-3561- A	< 2	WT-042916-3561- B	< 2				
64	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003543	Fountain	1	In classroom B126	WT-042916-3560- A	< 2	WT-042916-3560- B	< 2				
65	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003542	Classroom	1	In classroom 126	WT-042916-3559- A	< 2	WT-042916-3559- B	< 2				
66	AMIDON ELEMENTARY SCHOOL	5/5/2016	WS- 003541	Utility	1	In mechanical room sink (water source)	WT-042916-3558- A	72.7	WT-042916-3558- B	< 2	Non-drinking water source – Not accessible to children			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.