



# AMIDON ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	AMIDON ELEMENTARY SCHOOL	WS- 003587	12/21/2016	2	Combo Faucet	In classroom A202	FT-122016-003587-A	< 1	FT-122016-003587-B	< 1
2	AMIDON ELEMENTARY SCHOOL	WS- 003565	12/21/2016	1	Combo Faucet	In classroom A103 High Right	FT-122016-003565-A	< 1	FT-122016-003565-B	< 1
3	AMIDON ELEMENTARY SCHOOL	WS- 003599	12/21/2016	2	Combo Faucet	In classroom B236	FT-122016-003599-A	< 1	FT-122016-003599-B	< 1
4	AMIDON ELEMENTARY SCHOOL	WS- 003548	12/21/2016	1	Break Room	In workroom B137	FT-122016-003548-A	< 1	FT-122016-003548-B	< 1
5	AMIDON ELEMENTARY SCHOOL	WS- 003555	12/21/2016	1	Break Room	In first floor lobby adjacent to principal's office B121	FT-122016-003555-A	< 1	FT-122016-003555-B	< 1
6	AMIDON ELEMENTARY SCHOOL	WS- 003579	12/21/2016	2	Combo Faucet	In classroom A213	FT-122016-003579-A	< 1	FT-122016-003579-B	< 1
7	AMIDON ELEMENTARY SCHOOL	WS- 003577	12/21/2016	2	Combo Faucet	In classroom A212	FT-122016-003577-A	< 1	FT-122016-003577-B	< 1
8	AMIDON ELEMENTARY SCHOOL	WS- 003583	12/21/2016	2	Combo Faucet	In classroom A208	FT-122016-003583-A	< 1	FT-122016-003583-B	< 1
9	AMIDON ELEMENTARY SCHOOL	WS- 003581	12/21/2016	2	Combo Faucet	In classroom A209	FT-122016-003581-A	< 1	FT-122016-003581-B	< 1
10	AMIDON ELEMENTARY SCHOOL	WS- 003559	12/21/2016	1	Combo Faucet	In classroom A106 High Left	FT-122016-003559-A	< 1	FT-122016-003559-B	< 1
11	AMIDON ELEMENTARY SCHOOL	WS- 003561	12/21/2016	1	Combo Faucet	In classroom A106 Low Right	FT-122016-003561-A	< 1	FT-122016-003561-B	< 1
12	AMIDON ELEMENTARY SCHOOL	WS- 003563	12/21/2016	1	Combo Faucet	In classroom A103 Low Left	FT-122016-003563-A	< 1	FT-122016-003563-B	< 1
13	AMIDON ELEMENTARY SCHOOL	WS- 003574	12/21/2016	1	Combo Faucet	In classroom A107 High Right	FT-122016-003574-A	< 1	FT-122016-003574-B	< 1
14	AMIDON ELEMENTARY SCHOOL	WS- 003572	12/21/2016	1	Combo Faucet	In classroom A107 Low Left	FT-122016-003572-A	< 1	FT-122016-003572-B	< 1
15	AMIDON ELEMENTARY SCHOOL	WS- 003567	12/21/2016	1	Combo Faucet	In classroom A105 High Left	FT-122016-003567-A	< 1	FT-122016-003567-B	< 1
16	AMIDON ELEMENTARY SCHOOL	WS- 003591	12/21/2016	2	Combo Faucet	In classroom B230	FT-122016-003591-A	< 1	FT-122016-003591-B	< 1
17	AMIDON ELEMENTARY SCHOOL	WS- 003597	12/21/2016	2	Combo Faucet	In classroom B227	FT-122016-003597-A	< 1	FT-122016-003597-B	< 1
18	AMIDON ELEMENTARY SCHOOL	WS- 003593	12/21/2016	2	Combo Faucet	In classroom B225	FT-122016-003593-A	< 1	FT-122016-003593-B	< 1
19	AMIDON ELEMENTARY SCHOOL	WS- 003589	12/21/2016	2	Combo Faucet	In classroom B223	FT-122016-003589-A	< 1	FT-122016-003589-B	< 1
20	AMIDON ELEMENTARY SCHOOL	WS- 003595	12/21/2016	2	Combo Faucet	In classroom B232	FT-122016-003595-A	< 1	FT-122016-003595-B	< 1
21	AMIDON ELEMENTARY SCHOOL	WS- 003605	12/21/2016	2	Combo Faucet	In ESL teacher room adjacent to classroom 269	FT-122016-003605-A	< 1	FT-122016-003605-B	< 1
22	AMIDON ELEMENTARY SCHOOL	WS- 003542	12/21/2016	1	Combo Faucet	In classroom B126	FT-122016-003542-A	< 1	FT-122016-003542-B	< 1
23	AMIDON ELEMENTARY SCHOOL	WS- 003601	12/21/2016	2	Combo Faucet	In classroom B231	FT-122016-003601-A	< 1	FT-122016-003601-B	< 1
24	AMIDON ELEMENTARY SCHOOL	WS- 003546	12/21/2016	1	Combo Faucet	In classroom B128	FT-122016-003546-A	< 1	FT-122016-003546-B	< 1
25	AMIDON ELEMENTARY SCHOOL	WS- 003569	12/21/2016	1	Combo Faucet	In classroom A105 Low Right	FT-122016-003569-A	< 1	FT-122016-003569-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb