



# Amidon ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003366	11/8/2018	11/8/2019	1	Combo Fountain	In classroom 114 High Right	WF-11082018-003366	11/16/2018	FT-FY19-112018-003366-A	< 1	FT-FY19-112018-003366-B	< 1
WS-003367	10/11/2018	10/11/2019	1	Classroom Faucet	In classroom 114 High Right	WF-10112018-003367	11/16/2018	FT-FY19-112018-003367-A	< 1	FT-FY19-112018-003367-B	< 1
WS-003368	11/8/2018	11/8/2019	1	Combo Fountain	In classroom 114 Low Left	WF-11082018-003368	11/16/2018	FT-FY19-112018-003368-A	< 1	FT-FY19-112018-003368-B	< 1
WS-003369	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 114 Low Left	WF-10112018-003369	11/16/2018	FT-FY19-112018-003369-A	< 1	FT-FY19-112018-003369-B	< 1
WS-003370	11/8/2018	11/8/2019	2	Cooler	In hallway adjacent to stairwell C	WF-11082018-003370	11/16/2018	FT-FY19-112018-003370-A	< 1	FT-FY19-112018-003370-B	< 1
WS-003542	10/1/2018	10/1/2019	1	Combo Faucet	In classroom B126	WF-10012018-003542	11/16/2018	FT-FY19-112018-003542-A	< 1	FT-FY19-112018-003542-B	< 1
WS-003543	11/8/2018	11/8/2019	1	Combo Fountain	In classroom B126	WF-11082018-003543	11/16/2018	FT-FY19-112018-003543-A	< 1	FT-FY19-112018-003543-B	< 1
WS-003544	11/8/2018	11/8/2019	1	Cooler	In hallway adjacent to classroom B128 High Left	WF-11082018-003544	11/16/2018	FT-FY19-112018-003544-A	< 1	FT-FY19-112018-003544-B	< 1
WS-003545	11/8/2018	11/8/2019	1	Cooler	In hallway adjacent to classroom B128 Low Right	WF-11082018-003545	11/16/2018	FT-FY19-112018-003545-A	< 1	FT-FY19-112018-003545-B	< 1
WS-003546	10/1/2018	10/1/2019	1	Combo Faucet	In classroom B128	WF-10012018-003546	11/16/2018	FT-FY19-112018-003546-A	< 1	FT-FY19-112018-003546-B	< 1
WS-003547	11/8/2018	11/8/2019	1	Combo Fountain	In classroom B128	WF-11082018-003547	11/16/2018	FT-FY19-112018-003547-A	< 1	FT-FY19-112018-003547-B	< 1
WS-003548	11/8/2018	11/8/2019	1	Break Room	In workroom B137	WF-11082018-003548	11/16/2018	FT-FY19-112018-003548-A	< 1	FT-FY19-112018-003548-B	< 1
WS-003549	11/8/2018	11/8/2019	1	Cooler	In hallway adjacent to gym	WF-11082018-003549	11/16/2018	FT-FY19-112018-003549-A	< 1	FT-FY19-112018-003549-B	< 1
WS-003550	11/8/2018	11/8/2019	1	Cooler	In gym	WF-11082018-003550	11/16/2018	FT-FY19-112018-003550-A	< 1	FT-FY19-112018-003550-B	< 1
WS-003551	11/8/2018	11/8/2019	1	Cooler	In classroom D161A	WF-11082018-003551	11/16/2018	FT-FY19-112018-003551-A	< 1	FT-FY19-112018-003551-B	< 1
WS-003555	11/8/2018	11/8/2019	1	Break Room	In first floor lobby adjacent to principal's office B121	WF-11082018-003555	11/16/2018	FT-FY19-112018-003555-A	1.2	FT-FY19-112018-003555-B	< 1
WS-003558	11/8/2018	11/8/2019	1	Cooler	In hallway adjacent to kitchen	WF-11082018-003558	11/16/2018	FT-FY19-112018-003558-A	< 1	FT-FY19-112018-003558-B	< 1
WS-003559	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A106 High Left	WF-10012018-003559	11/16/2018	FT-FY19-112018-003559-A	< 1	FT-FY19-112018-003559-B	< 1
WS-003560	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A106 High Left	WF-11082018-003560	11/16/2018	FT-FY19-112018-003560-A	< 1	FT-FY19-112018-003560-B	< 1
WS-003561	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A106 Low Right	WF-10012018-003561	11/16/2018	FT-FY19-112018-003561-A	< 1	FT-FY19-112018-003561-B	< 1
WS-003562	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A106 Low Right	WF-11082018-003562	11/16/2018	FT-FY19-112018-003562-A	< 1	FT-FY19-112018-003562-B	< 1
WS-003563	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A103 Low Left	WF-10012018-003563	11/16/2018	FT-FY19-112018-003563-A	< 1	FT-FY19-112018-003563-B	< 1
WS-003564	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A103 Low Left	WF-11082018-003564	11/16/2018	FT-FY19-112018-003564-A	< 1	FT-FY19-112018-003564-B	< 1
WS-003565	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A103 High Right	WF-10012018-003565	11/16/2018	FT-FY19-112018-003565-A	< 1	FT-FY19-112018-003565-B	< 1
WS-003566	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A103 High Right	WF-11082018-003566	11/16/2018	FT-FY19-112018-003566-A	< 1	FT-FY19-112018-003566-B	< 1
WS-003567	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A105 High Left	WF-10012018-003567	11/16/2018	FT-FY19-112018-003567-A	< 1	FT-FY19-112018-003567-B	< 1
WS-003568	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A105 High Left	WF-11082018-003568	11/16/2018	FT-FY19-112018-003568-A	< 1	FT-FY19-112018-003568-B	< 1
WS-003569	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A105 Low Right	WF-10012018-003569	11/16/2018	FT-FY19-112018-003569-A	< 1	FT-FY19-112018-003569-B	< 1
WS-003570	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A105 Low Right	WF-11082018-003570	11/16/2018	FT-FY19-112018-003570-A	< 1	FT-FY19-112018-003570-B	< 1
WS-003571	11/8/2018	11/8/2019	1	Cooler	In hallway adjacent to health suite A116	WF-11082018-003571	11/16/2018	FT-FY19-112018-003571-A	< 1	FT-FY19-112018-003571-B	< 1
WS-003572	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A107 Low Left	WF-10012018-003572	11/16/2018	FT-FY19-112018-003572-A	< 1	FT-FY19-112018-003572-B	< 1
WS-003573	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A107 Low Left	WF-11082018-003573	11/16/2018	FT-FY19-112018-003573-A	< 1	FT-FY19-112018-003573-B	< 1

WS-003574	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A107	High Right	WF-10012018-003574	11/16/2018	FT-FY19-112018-003574-A	< 1	FT-FY19-112018-003574-B	< 1
WS-003575	11/8/2018	11/8/2019	1	Combo Fountain	In classroom A107	High Right	WF-11082018-003575	11/16/2018	FT-FY19-112018-003575-A	< 1	FT-FY19-112018-003575-B	< 1
WS-003576	11/8/2018	11/8/2019	1	Cooler	In health suite A116		WF-11082018-003576	11/16/2018	FT-FY19-112018-003576-A	< 1	FT-FY19-112018-003576-B	< 1
WS-003577	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A212		WF-10012018-003577	11/16/2018	FT-FY19-112018-003577-A	< 1	FT-FY19-112018-003577-B	< 1
WS-003578	11/8/2018	11/8/2019	2	Combo Fountain	In classroom A212		WF-11082018-003578	11/16/2018	FT-FY19-112018-003578-A	< 1	FT-FY19-112018-003578-B	< 1
WS-003579	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A213		WF-10012018-003579	11/16/2018	FT-FY19-112018-003579-A	< 1	FT-FY19-112018-003579-B	< 1
WS-003580	11/8/2018	11/8/2019	2	Combo Fountain	In classroom A213		WF-11082018-003580	11/16/2018	FT-FY19-112018-003580-A	< 1	FT-FY19-112018-003580-B	< 1
WS-003581	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A209		WF-10012018-003581	11/16/2018	FT-FY19-112018-003581-A	< 1	FT-FY19-112018-003581-B	< 1
WS-003582	11/8/2018	11/8/2019	2	Combo Fountain	In classroom A209		WF-11082018-003582	11/16/2018	FT-FY19-112018-003582-A	< 1	FT-FY19-112018-003582-B	< 1
WS-003583	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A208		WF-10012018-003583	11/16/2018	FT-FY19-112018-003583-A	1	FT-FY19-112018-003583-B	< 1
WS-003584	11/8/2018	11/8/2019	2	Combo Fountain	In classroom A208		WF-11082018-003584	11/16/2018	FT-FY19-112018-003584-A	< 1	FT-FY19-112018-003584-B	< 1
WS-003585	11/8/2018	11/8/2019	2	Cooler	In hallway between girls' and boys' restrooms	High Left	WF-11082018-003585	11/16/2018	FT-FY19-112018-003585-A	< 1	FT-FY19-112018-003585-B	< 1
WS-003586	11/8/2018	11/8/2019	2	Cooler	In hallway between girls' and boys' restrooms	Low Right	WF-11082018-003586	11/16/2018	FT-FY19-112018-003586-A	< 1	FT-FY19-112018-003586-B	< 1
WS-003587	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A202		WF-10012018-003587	11/16/2018	FT-FY19-112018-003587-A	< 1	FT-FY19-112018-003587-B	< 1
WS-003588	11/8/2018	11/8/2019	2	Combo Fountain	In classroom A202		WF-11082018-003588	11/16/2018	FT-FY19-112018-003588-A	< 1	FT-FY19-112018-003588-B	< 1
WS-003589	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B223		WF-10012018-003589	11/16/2018	FT-FY19-112018-003589-A	< 1	FT-FY19-112018-003589-B	< 1
WS-003590	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B223		WF-11082018-003590	11/16/2018	FT-FY19-112018-003590-A	< 1	FT-FY19-112018-003590-B	< 1
WS-003591	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B230		WF-10012018-003591	11/16/2018	FT-FY19-112018-003591-A	2.9	FT-FY19-112018-003591-B	< 1
WS-003592	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B230		WF-11082018-003592	11/16/2018	FT-FY19-112018-003592-A	< 1	FT-FY19-112018-003592-B	< 1
WS-003593	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B225		WF-10012018-003593	11/16/2018	FT-FY19-112018-003593-A	1.5	FT-FY19-112018-003593-B	< 1
WS-003594	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B225		WF-11082018-003594	11/16/2018	FT-FY19-112018-003594-A	< 1	FT-FY19-112018-003594-B	< 1
WS-003595	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B232		WF-10012018-003595	11/16/2018	FT-FY19-112018-003595-A	1.6	FT-FY19-112018-003595-B	< 1
WS-003596	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B232		WF-11082018-003596	11/16/2018	FT-FY19-112018-003596-A	< 1	FT-FY19-112018-003596-B	< 1
WS-003597	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B227		WF-10012018-003597	11/16/2018	FT-FY19-112018-003597-A	< 1	FT-FY19-112018-003597-B	< 1
WS-003598	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B227		WF-11082018-003598	11/16/2018	FT-FY19-112018-003598-A	< 1	FT-FY19-112018-003598-B	< 1
WS-003599	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B236		WF-10012018-003599	11/16/2018	FT-FY19-112018-003599-A	< 1	FT-FY19-112018-003599-B	< 1
WS-003600	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B236		WF-11082018-003600	11/16/2018	FT-FY19-112018-003600-A	< 1	FT-FY19-112018-003600-B	< 1
WS-003601	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B231		WF-10012018-003601	11/16/2018	FT-FY19-112018-003601-A	< 1	FT-FY19-112018-003601-B	< 1
WS-003602	11/8/2018	11/8/2019	2	Combo Fountain	In classroom B231		WF-11082018-003602	11/16/2018	FT-FY19-112018-003602-A	< 1	FT-FY19-112018-003602-B	< 1
WS-003603	4/30/2018	4/30/2019	1	Health Suite	In health suite A116 in bathroom		WF-04302018-003603	11/16/2018	FT-FY19-112018-003603-A	< 1	FT-FY19-112018-003603-B	< 1
WS-003605	10/1/2018	10/1/2019	2	Combo Faucet	In ESL teacher room adjacent to classroom 269		WF-10012018-003605	11/16/2018	FT-FY19-112018-003605-A	< 1	FT-FY19-112018-003605-B	< 1
WS-003606	11/8/2018	11/8/2019	2	Combo Fountain	In ESL teacher room adjacent to classroom 269		WF-11082018-003606	11/16/2018	FT-FY19-112018-003606-A	< 1	FT-FY19-112018-003606-B	< 1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003557	1	Food Prep Sink	In kitchen on south wall	11/16/2018	FT-FY19-112018-003557-A	< 1	FT-FY19-112018-003557-B	< 1