



# Amidon-Bowen ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003366	4/23/2019	4/23/2020	1	Combo Fountain	In classroom 114	High Right WF-04232019-003366	11/13/2019	FT-FY20-112019-003366-A	<1	FT-FY20-112019-003366-B	<1
WS-003367	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 114	High Right WF-09232019-003367	11/13/2019	FT-FY20-112019-003367-A	<1	FT-FY20-112019-003367-B	<1
WS-003368	4/23/2019	4/23/2020	1	Combo Fountain	In classroom 114	Low Left WF-04232019-003368	11/13/2019	FT-FY20-112019-003368-A	<1	FT-FY20-112019-003368-B	<1
WS-003369	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 114	Low Left WF-09232019-003369	11/13/2019	FT-FY20-112019-003369-A	<1	FT-FY20-112019-003369-B	<1
WS-003542	9/23/2019	9/23/2020	1	Combo Faucet	In classroom B126	WF-09232019-003542	11/13/2019	FT-FY20-112019-003542-A	<1	FT-FY20-112019-003542-B	<1
WS-003543	4/23/2019	4/23/2020	1	Combo Fountain	In classroom B126	WF-04232019-003543	11/13/2019	FT-FY20-112019-003543-A	<1	FT-FY20-112019-003543-B	<1
WS-003544	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to classroom B128	High Left WF-04232019-003544	11/13/2019	FT-FY20-112019-003544-A	<1	FT-FY20-112019-003544-B	<1
WS-003545	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to classroom B128	Low Right WF-04232019-003545	11/13/2019	FT-FY20-112019-003545-A	<1	FT-FY20-112019-003545-B	<1
WS-003546	9/23/2019	9/23/2020	1	Combo Faucet	In classroom B128	WF-09232019-003546	11/13/2019	FT-FY20-112019-003546-A	1.3	FT-FY20-112019-003546-B	<1
WS-003547	4/23/2019	4/23/2020	1	Combo Fountain	In classroom B128	WF-04232019-003547	11/13/2019	FT-FY20-112019-003547-A	<1	FT-FY20-112019-003547-B	<1
WS-003548	4/23/2019	4/23/2020	1	Break Room	In workroom B137	WF-04232019-003548	11/13/2019	FT-FY20-112019-003548-A	<1	FT-FY20-112019-003548-B	<1
WS-003549	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to gym	WF-04232019-003549	11/13/2019	FT-FY20-112019-003549-A	<1	FT-FY20-112019-003549-B	<1
WS-003550	4/23/2019	4/23/2020	1	Cooler	In gym	WF-04232019-003550	11/13/2019	FT-FY20-112019-003550-A	<1	FT-FY20-112019-003550-B	<1
WS-003551	4/23/2019	4/23/2020	1	Cooler	In classroom D161A	WF-04232019-003551	11/13/2019	FT-FY20-112019-003551-A	<1	FT-FY20-112019-003551-B	<1
WS-003555	4/23/2019	4/23/2020	1	Break Room	In first floor lobby adjacent to principal's office B121	WF-04232019-003555	11/13/2019	FT-FY20-112019-003555-A	<1	FT-FY20-112019-003555-B	<1
WS-003556	6/26/2019	6/26/2020	1	Dishwashing Hose	In kitchen on south wall (dishwashing hose)	Left WF-06262019-003556	11/13/2019	FT-FY20-112019-003556-A	<1	FT-FY20-112019-003556-B	<1
WS-003558	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to kitchen	WF-04232019-003558	11/13/2019	FT-FY20-112019-003558-A	<1	FT-FY20-112019-003558-B	<1
WS-003559	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A106	High Left WF-09232019-003559	11/13/2019	FT-FY20-112019-003559-A	<1	FT-FY20-112019-003559-B	<1
WS-003560	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A106	High Left WF-04232019-003560	11/13/2019	FT-FY20-112019-003560-A	<1	FT-FY20-112019-003560-B	<1
WS-003561	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A106	Low Right WF-09232019-003561	11/13/2019	FT-FY20-112019-003561-A	<1	FT-FY20-112019-003561-B	<1
WS-003562	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A106	Low Right WF-04232019-003562	11/13/2019	FT-FY20-112019-003562-A	<1	FT-FY20-112019-003562-B	<1
WS-003563	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A103	Low Left WF-09232019-003563	11/13/2019	FT-FY20-112019-003563-A	<1	FT-FY20-112019-003563-B	<1
WS-003564	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A103	Low Left WF-04232019-003564	11/13/2019	FT-FY20-112019-003564-A	<1	FT-FY20-112019-003564-B	<1
WS-003565	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A103	High Right WF-09232019-003565	11/13/2019	FT-FY20-112019-003565-A	<1	FT-FY20-112019-003565-B	<1
WS-003566	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A103	High Right WF-04232019-003566	11/13/2019	FT-FY20-112019-003566-A	<1	FT-FY20-112019-003566-B	<1
WS-003567	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A105	High Left WF-09232019-003567	11/13/2019	FT-FY20-112019-003567-A	<1	FT-FY20-112019-003567-B	<1
WS-003568	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A105	High Left WF-04232019-003568	11/13/2019	FT-FY20-112019-003568-A	<1	FT-FY20-112019-003568-B	<1
WS-003569	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A105	Low Right WF-09232019-003569	11/13/2019	FT-FY20-112019-003569-A	<1	FT-FY20-112019-003569-B	<1
WS-003570	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A105	Low Right WF-04232019-003570	11/13/2019	FT-FY20-112019-003570-A	<1	FT-FY20-112019-003570-B	<1
WS-003571	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to health suite A116	WF-04232019-003571	11/13/2019	FT-FY20-112019-003571-A	<1	FT-FY20-112019-003571-B	<1
WS-003572	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A107	Low Left WF-09232019-003572	11/13/2019	FT-FY20-112019-003572-A	<1	FT-FY20-112019-003572-B	<1
WS-003573	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A107	Low Left WF-04232019-003573	11/13/2019	FT-FY20-112019-003573-A	<1	FT-FY20-112019-003573-B	<1
WS-003574	9/23/2019	9/23/2020	1	Combo Faucet	In classroom A107	High Right WF-09232019-003574	11/13/2019	FT-FY20-112019-003574-A	<1	FT-FY20-112019-003574-B	<1
WS-003575	4/23/2019	4/23/2020	1	Combo Fountain	In classroom A107	High Right WF-04232019-003575	11/13/2019	FT-FY20-112019-003575-A	<1	FT-FY20-112019-003575-B	<1
WS-003576	4/23/2019	4/23/2020	1	Cooler	In health suite A116	WF-04232019-003576	11/13/2019	FT-FY20-112019-003576-A	<1	FT-FY20-112019-003576-B	<1

WS-003577	9/23/2019	9/23/2020	2	Combo Faucet	in classroom A212		WF-09232019-003577	11/13/2019	FT-FY20-112019-003577-A	<1	FT-FY20-112019-003577-B	<1
WS-003578	4/23/2019	4/23/2020	2	Combo Fountain	in classroom A212		WF-04232019-003578	11/13/2019	FT-FY20-112019-003578-A	<1	FT-FY20-112019-003578-B	<1
WS-003579	9/23/2019	9/23/2020	2	Combo Faucet	in classroom A213		WF-09232019-003579	11/13/2019	FT-FY20-112019-003579-A	<1	FT-FY20-112019-003579-B	<1
WS-003580	4/23/2019	4/23/2020	2	Combo Fountain	in classroom A213		WF-04232019-003580	11/13/2019	FT-FY20-112019-003580-A	<1	FT-FY20-112019-003580-B	<1
WS-003581	9/23/2019	9/23/2020	2	Combo Faucet	in classroom A209		WF-09232019-003581	11/13/2019	FT-FY20-112019-003581-A	<1	FT-FY20-112019-003581-B	<1
WS-003582	4/23/2019	4/23/2020	2	Combo Fountain	in classroom A209		WF-04232019-003582	11/13/2019	FT-FY20-112019-003582-A	<1	FT-FY20-112019-003582-B	<1
WS-003583	9/23/2019	9/23/2020	2	Combo Faucet	in classroom A208		WF-09232019-003583	11/13/2019	FT-FY20-112019-003583-A	<1	FT-FY20-112019-003583-B	<1
WS-003584	4/23/2019	4/23/2020	2	Combo Fountain	in classroom A208		WF-04232019-003584	11/13/2019	FT-FY20-112019-003584-A	<1	FT-FY20-112019-003584-B	<1
WS-003585	4/23/2019	4/23/2020	2	Cooler	in hallway between girls' and boys' restrooms	High Left	WF-04232019-003585	11/13/2019	FT-FY20-112019-003585-A	<1	FT-FY20-112019-003585-B	<1
WS-003586	4/23/2019	4/23/2020	2	Cooler	in hallway between girls' and boys' restrooms	Low Right	WF-04232019-003586	11/13/2019	FT-FY20-112019-003586-A	<1	FT-FY20-112019-003586-B	<1
WS-003587	9/23/2019	9/23/2020	2	Combo Faucet	in classroom A202		WF-09232019-003587	11/13/2019	FT-FY20-112019-003587-A	2.9	FT-FY20-112019-003587-B	<1
WS-003588	4/23/2019	4/23/2020	2	Combo Fountain	in classroom A202		WF-04232019-003588	11/13/2019	FT-FY20-112019-003588-A	<1	FT-FY20-112019-003588-B	<1
WS-003589	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B223		WF-09232019-003589	11/13/2019	FT-FY20-112019-003589-A	<1	FT-FY20-112019-003589-B	<1
WS-003590	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B223		WF-04232019-003590	11/13/2019	FT-FY20-112019-003590-A	<1	FT-FY20-112019-003590-B	<1
WS-003591	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B230		WF-09232019-003591	11/13/2019	FT-FY20-112019-003591-A	<1	FT-FY20-112019-003591-B	<1
WS-003592	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B230		WF-04232019-003592	11/13/2019	FT-FY20-112019-003592-A	<1	FT-FY20-112019-003592-B	<1
WS-003593	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B225		WF-09232019-003593	11/13/2019	FT-FY20-112019-003593-A	<1	FT-FY20-112019-003593-B	<1
WS-003594	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B225		WF-04232019-003594	11/13/2019	FT-FY20-112019-003594-A	<1	FT-FY20-112019-003594-B	<1
WS-003595	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B232		WF-09232019-003595	11/13/2019	FT-FY20-112019-003595-A	1.1	FT-FY20-112019-003595-B	<1
WS-003596	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B232		WF-04232019-003596	11/13/2019	FT-FY20-112019-003596-A	<1	FT-FY20-112019-003596-B	<1
WS-003597	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B227		WF-09232019-003597	11/13/2019	FT-FY20-112019-003597-A	2.4	FT-FY20-112019-003597-B	<1
WS-003598	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B227		WF-04232019-003598	11/13/2019	FT-FY20-112019-003598-A	<1	FT-FY20-112019-003598-B	<1
WS-003599	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B236		WF-09232019-003599	11/13/2019	FT-FY20-112019-003599-A	<1	FT-FY20-112019-003599-B	<1
WS-003600	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B236		WF-04232019-003600	11/13/2019	FT-FY20-112019-003600-A	<1	FT-FY20-112019-003600-B	<1
WS-003601	9/23/2019	9/23/2020	2	Combo Faucet	in classroom B231		WF-09232019-003601	11/13/2019	FT-FY20-112019-003601-A	<1	FT-FY20-112019-003601-B	<1
WS-003602	4/23/2019	4/23/2020	2	Combo Fountain	in classroom B231		WF-04232019-003602	11/13/2019	FT-FY20-112019-003602-A	<1	FT-FY20-112019-003602-B	<1
WS-003603	4/23/2019	4/23/2020	1	Health Suite	in health suite A116 in bathroom		WF-04232019-003603	11/13/2019	FT-FY20-112019-003603-A	2.3	FT-FY20-112019-003603-B	<1
WS-003605	9/23/2019	9/23/2020	2	Combo Faucet	in ESL teacher room adjacent to classroom 269		WF-09232019-003605	11/13/2019	FT-FY20-112019-003605-A	<1	FT-FY20-112019-003605-B	<1
WS-003606	4/23/2019	4/23/2020	2	Combo Fountain	in ESL teacher room adjacent to classroom 269		WF-04232019-003606	11/13/2019	FT-FY20-112019-003606-A	<1	FT-FY20-112019-003606-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003557	6/26/2019	6/26/2020	1	Food Prep Sink	in kitchen on south wall	Right	WF-06262019-003557	11/13/2019	FT-FY20-112019-003557-A	<1	FT-FY20-112019-003557-B	<1