



ANACOSTIA ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	ANACOSTIA HIGH SCHOOL	WS- 011609	12/21/2016	Basement	Classroom Faucet	In classroom N004 Right	FT-122016-011609-A	< 1	FT-122016-011609-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011606	12/21/2016	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	FT-122016-011606-A	< 1	FT-122016-011606-B	< 1
3	ANACOSTIA HIGH SCHOOL	WS- 011613	12/21/2016	Basement	Classroom Faucet	In classroom N009 Right	FT-122016-011613-A	< 1	FT-122016-011613-B	< 1
4	ANACOSTIA HIGH SCHOOL	WS- 011614	12/21/2016	Basement	Classroom Faucet	In classroom N012 Right	FT-122016-011614-A	< 1	FT-122016-011614-B	< 1
5	ANACOSTIA HIGH SCHOOL	WS- 011608	12/21/2016	Basement	Classroom Faucet	In classroom N004 Left	FT-122016-011608-A	< 1	FT-122016-011608-B	< 1
6	ANACOSTIA HIGH SCHOOL	WS- 011605	12/21/2016	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	FT-122016-011605-A	< 1	FT-122016-011605-B	< 1
7	ANACOSTIA HIGH SCHOOL	WS- 011611	12/21/2016	Basement	Classroom Faucet	In classroom N009A	FT-122016-011611-A	< 1	FT-122016-011611-B	< 1
8	ANACOSTIA HIGH SCHOOL	WS- 011612	12/21/2016	Basement	Classroom Faucet	In classroom N009 Left	FT-122016-011612-A	< 1	FT-122016-011612-B	< 1
9	ANACOSTIA HIGH SCHOOL	WS- 011610	12/21/2016	Basement	Classroom Faucet	In classroom N005	FT-122016-011610-A	< 1	FT-122016-011610-B	< 1
10	ANACOSTIA HIGH SCHOOL	WS- 011616	12/21/2016	Basement	Break Room	In break room N008 in room N001	FT-122016-011616-A	< 1	FT-122016-011616-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	ANACOSTIA HIGH SCHOOL	WS- 011607	12/21/2016	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	FT-122016-011607-A	1.6	FT-122016-011607-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011615	12/21/2016	Basement	Classroom Faucet	In classroom N012 Left	FT-122016-011615-A	1.1	FT-122016-011615-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	ANACOSTIA HIGH SCHOOL	WS- 011607	1/25/2017	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	FT-122016-011607-A	1.6	FT-122016-011607-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011615	1/25/2017	Basement	Classroom Faucet	In classroom N012 Left	FT-122016-011615-A	1.4	FT-122016-011615-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	ANACOSTIA HIGH SCHOOL	WS- 011607	3/14/2017	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	FT-122016-011607-A	1.8	FT-122016-011607-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011615	3/14/2017	Basement	Classroom Faucet	In classroom N012 Left	FT-122016-011615-A	1.7	FT-122016-011615-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 1 ppb - Devices Returned to Service										
1	ANACOSTIA HIGH SCHOOL	WS- 011607	8/11/2017	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	FT-122016-011607-A	< 1	FT-122016-011607-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011615	8/11/2017	Basement	Classroom Faucet	In classroom N012 Left	FT-122016-011615-A	< 1	FT-122016-011615-B	< 1