



ANACOSTIA LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	ANACOSTIA HIGH SCHOOL	WS- 011599	8/16/2016	Basement	Ice Maker	In kitchen first clockwise from entry door (ice maker)	FT-82016-011599-A	< 1	FT-82016-011599-B	< 1
2	ANACOSTIA HIGH SCHOOL	WS- 011600	8/16/2016	Basement	Food Prep Sink	In kitchen second clockwise from entry door	FT-72016-011600-A	< 1	FT-72016-011600-B	< 1
3	ANACOSTIA HIGH SCHOOL	WS- 011618	8/16/2016	Basement	Cooler	In hallway across from stairwell 9	FT-82016-011618-A	< 1	FT-82016-011618-B	< 1
4	ANACOSTIA HIGH SCHOOL	WS- 011638	8/16/2016	Basement	Cooler	In hallway adjacent to room S007	FT-82016-011638-A	< 1	FT-82016-011638-B	< 1
5	ANACOSTIA HIGH SCHOOL	WS- 011639	8/16/2016	1	Cooler	In hallway adjacent to room S102	FT-82016-011639-A	< 1	FT-82016-011639-B	< 1
6	ANACOSTIA HIGH SCHOOL	WS- 011640	8/16/2016	1	Cooler	In hallway adjacent to room G101	FT-82016-011640-A	< 1	FT-82016-011640-B	< 1
7	ANACOSTIA HIGH SCHOOL	WS- 011641	8/16/2016	1	Cooler	In hallway adjacent to room M103	FT-82016-011641-A	< 1	FT-82016-011641-B	< 1
8	ANACOSTIA HIGH SCHOOL	WS- 011642	8/16/2016	1	Health Suite	In health suite across from M105F	FT-82016-011642-A	< 1	FT-82016-011642-B	< 1
9	ANACOSTIA HIGH SCHOOL	WS- 011643	8/16/2016	1	Health Suite	In health suite M105F	FT-82016-011643-A	< 1	FT-82016-011643-B	< 1
10	ANACOSTIA HIGH SCHOOL	WS- 011644	8/16/2016	1	Health Suite	In health suite M105H	FT-82016-011644-A	< 1	FT-82016-011644-B	< 1
11	ANACOSTIA HIGH SCHOOL	WS- 011645	8/16/2016	1	Health Suite	In health suite M105E	FT-82016-011645-A	< 1	FT-82016-011645-B	< 1
12	ANACOSTIA HIGH SCHOOL	WS- 011646	8/16/2016	1	Health Suite	In health suite across from room M105D	FT-82016-011646-A	< 1	FT-82016-011646-B	< 1
13	ANACOSTIA HIGH SCHOOL	WS- 011647	8/16/2016	1	Health Suite	In health suite across from room M105A	FT-82016-011647-A	< 1	FT-82016-011647-B	< 1
14	ANACOSTIA HIGH SCHOOL	WS- 011648	8/16/2016	1	Health Suite	In health suite M105N Right	FT-82016-011648-A	< 1	FT-82016-011648-B	< 1
15	ANACOSTIA HIGH SCHOOL	WS- 011649	8/16/2016	1	Health Suite	In health suite M105N Left	FT-82016-011649-A	< 1	FT-82016-011649-B	< 1
16	ANACOSTIA HIGH SCHOOL	WS- 011650	8/16/2016	1	Cooler	In hallway adjacent to room M115	FT-82016-011650-A	< 1	FT-82016-011650-B	< 1
17	ANACOSTIA HIGH SCHOOL	WS- 011651	8/16/2016	1	Cooler	In hallway adjacent to room N110	FT-82016-011651-A	< 1	FT-82016-011651-B	< 1
18	ANACOSTIA HIGH SCHOOL	WS- 011653	8/16/2016	2	Cooler	In hallway adjacent to room M202	FT-82016-011653-A	< 1	FT-82016-011653-B	< 1
19	ANACOSTIA HIGH SCHOOL	WS- 011655	8/16/2016	2	Cooler	In hallway adjacent to room M212A	FT-82016-011655-A	< 1	FT-82016-011655-B	< 1
20	ANACOSTIA HIGH SCHOOL	WS- 011667	8/16/2016	2	Cooler	In hallway adjacent to room M220	FT-82016-011667-A	< 1	FT-82016-011667-B	< 1
21	ANACOSTIA HIGH SCHOOL	WS- 011688	8/16/2016	2	Cooler	In hallway adjacent to room S204	FT-82016-011688-A	< 1	FT-82016-011688-B	< 1
22	ANACOSTIA HIGH SCHOOL	WS- 011690	8/16/2016	2	Cooler	In hallway adjacent to room G204	FT-82016-011690-A	< 1	FT-82016-011690-B	< 1
23	ANACOSTIA HIGH SCHOOL	WS- 011691	8/16/2016	2	Cooler	In hallway across from room N201	FT-82016-011691-A	< 1	FT-82016-011691-B	< 1
24	ANACOSTIA HIGH SCHOOL	WS- 011702	8/16/2016	3	Cooler	In hallway adjacent to room M319	FT-82016-011702-A	< 1	FT-82016-011702-B	< 1
25	ANACOSTIA HIGH SCHOOL	WS- 011703	8/16/2016	3	Cooler	In hallway adjacent to room M303	FT-82016-011703-A	< 1	FT-82016-011703-B	< 1
26	ANACOSTIA HIGH SCHOOL	WS- 011714	8/16/2016	3	Cooler	In hallway adjacent to room g302	FT-82016-011714-A	< 1	FT-82016-011714-B	< 1