



Anacostia High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011605	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	WF-10062020-011605	4/28/2021	FT-FY21-042021-011605-A	<1	FT-FY21-042021-011605-B	<1
WS-011606	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	WF-10062020-011606	4/28/2021	FT-FY21-042021-011606-A	<1	FT-FY21-042021-011606-B	<1
WS-011607	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	WF-10062020-011607	4/28/2021	FT-FY21-042021-011607-A	<1	FT-FY21-042021-011607-B	<1
WS-011608	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N004	WF-10062020-011608	4/28/2021	FT-FY21-042021-011608-A	<1	FT-FY21-042021-011608-B	<1
WS-011609	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N004	WF-10062020-011609	4/28/2021	FT-FY21-042021-011609-A	<1	FT-FY21-042021-011609-B	<1
WS-011610	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N005	WF-10062020-011610	4/28/2021	FT-FY21-042021-011610-A	<1	FT-FY21-042021-011610-B	<1
WS-011611	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N009A	WF-10062020-011611	4/28/2021	FT-FY21-042021-011611-A	<1	FT-FY21-042021-011611-B	<1
WS-011612	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N009	WF-10062020-011612	4/28/2021	FT-FY21-042021-011612-A	<1	FT-FY21-042021-011612-B	<1
WS-011613	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N009	WF-10062020-011613	4/28/2021	FT-FY21-042021-011613-A	<1	FT-FY21-042021-011613-B	<1
WS-011614	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N012	WF-10062020-011614	4/28/2021	FT-FY21-042021-011614-A	<1	FT-FY21-042021-011614-B	<1
WS-011615	10/6/2020	10/6/2021	Basement	Classroom Faucet	In classroom N012	WF-10062020-011615	4/28/2021	FT-FY21-042021-011615-A	<1	FT-FY21-042021-011615-B	<1
WS-011616	4/19/2021	4/19/2022	Basement	Break Room	In break room N008 in room N001	WF-04192021-011616	4/28/2021	FT-FY21-042021-011616-A	<1	FT-FY21-042021-011616-B	<1
WS-011638	4/19/2021	4/19/2022	Basement	Cooler	In hallway adjacent to room S007	WF-04192021-011638	4/28/2021	FT-FY21-042021-011638-A	<1	FT-FY21-042021-011638-B	<1
WS-011639	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room S102	WF-04192021-011639	4/28/2021	FT-FY21-042021-011639-A	<1	FT-FY21-042021-011639-B	<1
WS-011640	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room G101	WF-04192021-011640	4/28/2021	FT-FY21-042021-011640-A	<1	FT-FY21-042021-011640-B	<1
WS-011641	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room M103	WF-04192021-011641	4/28/2021	FT-FY21-042021-011641-A	<1	FT-FY21-042021-011641-B	<1
WS-011642	4/19/2021	4/19/2022	1	Health Suite	In health suite across from M105F	WF-04192021-011642	4/28/2021	FT-FY21-042021-011642-A	<1	FT-FY21-042021-011642-B	<1
WS-011643	4/19/2021	4/19/2022	1	Health Suite	In health suite M105F	WF-04192021-011643	4/28/2021	FT-FY21-042021-011643-A	<1	FT-FY21-042021-011643-B	<1
WS-011644	4/19/2021	4/19/2022	1	Health Suite	In health suite M105H	WF-04192021-011644	4/28/2021	FT-FY21-042021-011644-A	<1	FT-FY21-042021-011644-B	<1
WS-011645	4/19/2021	4/19/2022	1	Health Suite	In health suite M105E	WF-04192021-011645	4/28/2021	FT-FY21-042021-011645-A	<1	FT-FY21-042021-011645-B	<1
WS-011646	4/19/2021	4/19/2022	1	Health Suite	In health suite across from room M105D	WF-04192021-011646	4/28/2021	FT-FY21-042021-011646-A	<1	FT-FY21-042021-011646-B	<1
WS-011647	4/19/2021	4/19/2022	1	Health Suite	In health suite across from room M105A	WF-04192021-011647	4/28/2021	FT-FY21-042021-011647-A	<1	FT-FY21-042021-011647-B	<1
WS-011648	4/19/2021	4/19/2022	1	Health Suite	In health suite M105N	WF-04192021-011648	4/28/2021	FT-FY21-042021-011648-A	<1	FT-FY21-042021-011648-B	<1
WS-011649	4/19/2021	4/19/2022	1	Health Suite	In health suite M105N	WF-04192021-011649	4/28/2021	FT-FY21-042021-011649-A	<1	FT-FY21-042021-011649-B	<1
WS-011650	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room M115	WF-04192021-011650	4/28/2021	FT-FY21-042021-011650-A	<1	FT-FY21-042021-011650-B	<1
WS-011651	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room N110	WF-04192021-011651	4/28/2021	FT-FY21-042021-011651-A	<1	FT-FY21-042021-011651-B	<1
WS-011653	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M202	WF-04192021-011653	4/28/2021	FT-FY21-042021-011653-A	<1	FT-FY21-042021-011653-B	<1
WS-011655	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M212A	WF-04192021-011655	4/28/2021	FT-FY21-042021-011655-A	<1	FT-FY21-042021-011655-B	<1
WS-011667	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M220	WF-04192021-011667	4/28/2021	FT-FY21-042021-011667-A	<1	FT-FY21-042021-011667-B	<1
WS-011690	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room G204	WF-04192021-011690	4/28/2021	FT-FY21-042021-011690-A	<1	FT-FY21-042021-011690-B	<1
WS-011702	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room M319	WF-04192021-011702	4/28/2021	FT-FY21-042021-011702-A	<1	FT-FY21-042021-011702-B	<1
WS-011703	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room M303	WF-04192021-011703	4/28/2021	FT-FY21-042021-011703-A	<1	FT-FY21-042021-011703-B	<1
WS-011714	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room G302	WF-04192021-011714	4/28/2021	FT-FY21-042021-011714-A	<1	FT-FY21-042021-011714-B	<1