



Anacostia High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011605	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	WF-09202022-011605	2/13/2023	FT-FY23-01262023-011605-A	<1	FT-FY23-01262023-011605-B	<1
WS-011606	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	WF-09202022-011606	2/13/2023	FT-FY23-01262023-011606-A	<1	FT-FY23-01262023-011606-B	<1
WS-011607	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	WF-09202022-011607	2/13/2023	FT-FY23-01262023-011607-A	<1	FT-FY23-01262023-011607-B	<1
WS-011610	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N005	WF-09202022-011610	2/13/2023	FT-FY23-01262023-011610-A	<1	FT-FY23-01262023-011610-B	<1
WS-011611	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N009A	WF-09202022-011611	2/13/2023	FT-FY23-01262023-011611-A	<1	FT-FY23-01262023-011611-B	<1
WS-011612	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N009 Left	WF-09202022-011612	2/13/2023	FT-FY23-01262023-011612-A	<1	FT-FY23-01262023-011612-B	<1
WS-011613	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N009 Right	WF-09202022-011613	2/13/2023	FT-FY23-01262023-011613-A	<1	FT-FY23-01262023-011613-B	<1
WS-011614	9/20/2022	9/20/2023	Basement	Classroom Faucet	In classroom N012 Right	WF-09202022-011614	2/13/2023	FT-FY23-01262023-011614-A	<1	FT-FY23-01262023-011614-B	<1
WS-011616	4/12/2022	4/12/2023	Basement	Break Room	In break room N008 in room N001	WF-04122022-011616	2/13/2023	FT-FY23-01262023-011616-A	<1	FT-FY23-01262023-011616-B	<1
WS-011639	4/12/2022	4/12/2023	1	Cooler	In hallway adjacent to room S102	WF-04122022-011639	2/13/2023	FT-FY23-01262023-011639-A	<1	FT-FY23-01262023-011639-B	<1
WS-011640	4/12/2022	4/12/2023	1	Cooler	In hallway adjacent to room G101	WF-04122022-011640	2/13/2023	FT-FY23-01262023-011640-A	<1	FT-FY23-01262023-011640-B	<1
WS-011641	1/26/2023	1/26/2024	1	Cooler	In hallway adjacent to room M103	WF-01262023-011641	2/13/2023	FT-FY23-01262023-011641-A	<1	FT-FY23-01262023-011641-B	<1
WS-011642	4/12/2022	4/12/2023	1	Health Suite	In health suite across from M105F	WF-04122022-011642	2/13/2023	FT-FY23-01262023-011642-A	<1	FT-FY23-01262023-011642-B	<1
WS-011643	4/12/2022	4/12/2023	1	Health Suite	In health suite M105F	WF-04122022-011643	2/13/2023	FT-FY23-01262023-011643-A	<1	FT-FY23-01262023-011643-B	<1
WS-011644	4/12/2022	4/12/2023	1	Health Suite	In health suite M105H	WF-04122022-011644	2/13/2023	FT-FY23-01262023-011644-A	<1	FT-FY23-01262023-011644-B	<1
WS-011645	4/12/2022	4/12/2023	1	Health Suite	In health suite M105E	WF-04122022-011645	2/13/2023	FT-FY23-01262023-011645-A	<1	FT-FY23-01262023-011645-B	<1
WS-011646	4/12/2022	4/12/2023	1	Health Suite	In health suite across from room M105D	WF-04122022-011646	2/13/2023	FT-FY23-01262023-011646-A	<1	FT-FY23-01262023-011646-B	<1
WS-011647	4/12/2022	4/12/2023	1	Health Suite	In health suite across from room M105A	WF-04122022-011647	2/13/2023	FT-FY23-01262023-011647-A	<1	FT-FY23-01262023-011647-B	<1
WS-011649	4/12/2022	4/12/2023	1	Health Suite	In health suite M105N Left	WF-04122022-011649	2/13/2023	FT-FY23-01262023-011649-A	<1	FT-FY23-01262023-011649-B	<1
WS-011650	4/12/2022	4/12/2023	1	Cooler	In hallway adjacent to room M115	WF-04122022-011650	2/13/2023	FT-FY23-01262023-011650-A	<1	FT-FY23-01262023-011650-B	<1
WS-011651	4/12/2022	4/12/2023	1	Cooler	In hallway adjacent to room N110	WF-04122022-011651	2/13/2023	FT-FY23-01262023-011651-A	<1	FT-FY23-01262023-011651-B	<1
WS-011653	4/12/2022	4/12/2023	2	Cooler	In hallway adjacent to room M202	WF-04122022-011653	2/13/2023	FT-FY23-01262023-011653-A	<1	FT-FY23-01262023-011653-B	<1
WS-011655	4/12/2022	4/12/2023	2	Cooler	In hallway adjacent to room M212A	WF-04122022-011655	2/13/2023	FT-FY23-01262023-011655-A	<1	FT-FY23-01262023-011655-B	<1
WS-011688	4/12/2022	4/12/2023	2	Cooler	In hallway adjacent to room S204	WF-04122022-011688	2/13/2023	FT-FY23-01262023-011688-A	<1	FT-FY23-01262023-011688-B	<1
WS-011690	4/12/2022	4/12/2023	2	Cooler	In hallway adjacent to room G204	WF-04122022-011690	2/13/2023	FT-FY23-01262023-011690-A	<1	FT-FY23-01262023-011690-B	<1
WS-011691	4/12/2022	4/12/2023	2	Cooler	In hallway across from room N201	WF-04122022-011691	2/13/2023	FT-FY23-01262023-011691-A	<1	FT-FY23-01262023-011691-B	<1
WS-011702	4/12/2022	4/12/2023	3	Cooler	In hallway adjacent to room M319	WF-04122022-011702	2/13/2023	FT-FY23-01262023-011702-A	<1	FT-FY23-01262023-011702-B	<1
WS-011714	4/12/2022	4/12/2023	3	Cooler	In hallway adjacent to room G302	WF-04122022-011714	2/13/2023	FT-FY23-01262023-011714-A	<1	FT-FY23-01262023-011714-B	<1
WS-011738	1/26/2023	1/26/2024	1	Bottle Filler	In hallway adjacent to room M103	WF-01262023-011738	2/13/2023	FT-FY23-01262023-011738-A	<1	FT-FY23-01262023-011738-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011600	1/10/2023	1/10/2024	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-01102023-011600	2/13/2023	FT-FY23-01262023-011600-A	<1	FT-FY23-01262023-011600-B	<1