



Anacostia HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011599	5/30/2019	5/30/2020	Basement	Ice Maker	In kitchen first clockwise from entry door (ice maker)	WF-05302019-011599	1/8/2020	FT-FY20-122019-011599-A	<1	FT-FY20-122019-011599-B	<1
WS- 011605	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	WF-10172019-011605	1/8/2020	FT-FY20-122019-011605-A	<1	FT-FY20-122019-011605-B	<1
WS- 011606	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	WF-10172019-011606	1/8/2020	FT-FY20-122019-011606-A	<1	FT-FY20-122019-011606-B	<1
WS- 011607	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	WF-10172019-011607	1/8/2020	FT-FY20-122019-011607-A	<1	FT-FY20-122019-011607-B	<1
WS- 011608	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N004 Left	WF-10172019-011608	1/8/2020	FT-FY20-122019-011608-A	<1	FT-FY20-122019-011608-B	<1
WS- 011609	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N004 Right	WF-10172019-011609	1/8/2020	FT-FY20-122019-011609-A	<1	FT-FY20-122019-011609-B	<1
WS- 011610	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N005	WF-10172019-011610	1/8/2020	FT-FY20-122019-011610-A	<1	FT-FY20-122019-011610-B	<1
WS- 011611	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N009A	WF-10172019-011611	1/8/2020	FT-FY20-122019-011611-A	<1	FT-FY20-122019-011611-B	<1
WS- 011612	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N009 Left	WF-10172019-011612	1/8/2020	FT-FY20-122019-011612-A	2.9	FT-FY20-122019-011612-B	2.6
WS- 011613	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N009 Right	WF-10172019-011613	1/8/2020	FT-FY20-122019-011613-A	<1	FT-FY20-122019-011613-B	<1
WS- 011614	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N012 Right	WF-10172019-011614	1/8/2020	FT-FY20-122019-011614-A	<1	FT-FY20-122019-011614-B	<1
WS- 011615	10/17/2019	10/17/2020	Basement	Classroom Faucet	In classroom N012 Left	WF-10172019-011615	1/8/2020	FT-FY20-122019-011615-A	<1	FT-FY20-122019-011615-B	<1
WS- 011616	5/30/2019	5/30/2020	Basement	Break Room	In break room N008 in room N001	WF-05302019-011616	1/8/2020	FT-FY20-122019-011616-A	<1	FT-FY20-122019-011616-B	<1
WS- 011618	5/30/2019	5/30/2020	Basement	Cooler	In hallway across from stairwell 9	WF-05302019-011618	1/8/2020	FT-FY20-122019-011618-A	<1	FT-FY20-122019-011618-B	<1
WS- 011638	5/30/2019	5/30/2020	Basement	Cooler	In hallway adjacent to room S007	WF-05302019-011638	1/8/2020	FT-FY20-122019-011638-A	<1	FT-FY20-122019-011638-B	<1
WS- 011639	5/30/2019	5/30/2020	1	Cooler	In hallway adjacent to room S102	WF-05302019-011639	1/8/2020	FT-FY20-122019-011639-A	<1	FT-FY20-122019-011639-B	<1
WS- 011640	5/30/2019	5/30/2020	1	Cooler	In hallway adjacent to room G101	WF-05302019-011640	1/8/2020	FT-FY20-122019-011640-A	<1	FT-FY20-122019-011640-B	<1
WS- 011641	5/30/2019	5/30/2020	1	Cooler	In hallway adjacent to room M103	WF-05302019-011641	1/8/2020	FT-FY20-122019-011641-A	<1	FT-FY20-122019-011641-B	<1
WS- 011642	5/30/2019	5/30/2020	1	Health Suite	In health suite across from M105F	WF-05302019-011642	1/8/2020	FT-FY20-122019-011642-A	<1	FT-FY20-122019-011642-B	<1
WS- 011643	5/30/2019	5/30/2020	1	Health Suite	In health suite M105F	WF-05302019-011643	1/8/2020	FT-FY20-122019-011643-A	<1	FT-FY20-122019-011643-B	<1
WS- 011644	5/30/2019	5/30/2020	1	Health Suite	In health suite M105H	WF-05302019-011644	1/8/2020	FT-FY20-122019-011644-A	<1	FT-FY20-122019-011644-B	<1
WS- 011645	5/30/2019	5/30/2020	1	Health Suite	In health suite M105E	WF-05302019-011645	1/8/2020	FT-FY20-122019-011645-A	<1	FT-FY20-122019-011645-B	<1
WS- 011646	5/30/2019	5/30/2020	1	Health Suite	In health suite across from room M105D	WF-05302019-011646	1/8/2020	FT-FY20-122019-011646-A	<1	FT-FY20-122019-011646-B	<1
WS- 011647	5/30/2019	5/30/2020	1	Health Suite	In health suite across from room M105A	WF-05302019-011647	1/8/2020	FT-FY20-122019-011647-A	<1	FT-FY20-122019-011647-B	<1
WS- 011648	5/30/2019	5/30/2020	1	Health Suite	In health suite M105N Right	WF-05302019-011648	1/8/2020	FT-FY20-122019-011648-A	<1	FT-FY20-122019-011648-B	<1
WS- 011649	5/30/2019	5/30/2020	1	Health Suite	In health suite M105N Left	WF-05302019-011649	1/8/2020	FT-FY20-122019-011649-A	<1	FT-FY20-122019-011649-B	<1
WS- 011650	5/30/2019	5/30/2020	1	Cooler	In hallway adjacent to room M115	WF-05302019-011650	1/8/2020	FT-FY20-122019-011650-A	<1	FT-FY20-122019-011650-B	<1
WS- 011651	5/30/2019	5/30/2020	1	Cooler	In hallway adjacent to room N110	WF-05302019-011651	1/8/2020	FT-FY20-122019-011651-A	<1	FT-FY20-122019-011651-B	<1
WS- 011653	5/30/2019	5/30/2020	2	Cooler	In hallway adjacent to room M202	WF-05302019-011653	1/8/2020	FT-FY20-122019-011653-A	<1	FT-FY20-122019-011653-B	<1
WS- 011655	5/30/2019	5/30/2020	2	Cooler	In hallway adjacent to room M212A	WF-05302019-011655	1/8/2020	FT-FY20-122019-011655-A	<1	FT-FY20-122019-011655-B	<1
WS- 011667	5/30/2019	5/30/2020	2	Cooler	In hallway adjacent to room M220	WF-05302019-011667	1/8/2020	FT-FY20-122019-011667-A	<1	FT-FY20-122019-011667-B	<1
WS- 011688	5/30/2019	5/30/2020	2	Cooler	In hallway adjacent to room S204	WF-05302019-011688	1/8/2020	FT-FY20-122019-011688-A	<1	FT-FY20-122019-011688-B	<1
WS- 011690	5/30/2019	5/30/2020	2	Cooler	In hallway adjacent to room G204	WF-05302019-011690	1/8/2020	FT-FY20-122019-011690-A	<1	FT-FY20-122019-011690-B	<1
WS- 011691	5/30/2019	5/30/2020	2	Cooler	In hallway across from room N201	WF-05302019-011691	1/8/2020	FT-FY20-122019-011691-A	<1	FT-FY20-122019-011691-B	<1
WS- 011702	5/30/2019	5/30/2020	3	Cooler	In hallway adjacent to room M319	WF-05302019-011702	1/8/2020	FT-FY20-122019-011702-A	<1	FT-FY20-122019-011702-B	<1

WS- 011703	5/30/2019	5/30/2020	3	Cooler	In hallway adjacent to room M303	WF-05302019-011703	1/8/2020	FT-FY20-122019-011703-A	<1	FT-FY20-122019-011703-B	<1
WS- 011714	5/30/2019	5/30/2020	3	Cooler	In hallway adjacent to room G302	WF-05302019-011714	1/8/2020	FT-FY20-122019-011714-A	<1	FT-FY20-122019-011714-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011600	7/11/2019	7/11/2020	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-07112019-011600	1/8/2020	FT-FY20-122019-011600-A	<1	FT-FY20-122019-011600-B	<1