



# Anacostia High School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-011599	4/19/2021	4/19/2022	Basement	Ice Maker	In kitchen first clockwise from entry door (ice maker)	WF-04192021-011599	3/22/2022	FT-FY22-02212022-011599-A	<1	FT-FY22-02212022-011599-B	1.4	
WS-011605	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	WF-09282021-011605	3/22/2022	FT-FY22-02212022-011605-A	<1	FT-FY22-02212022-011605-B	<1	
WS-011606	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	WF-09282021-011606	3/22/2022	FT-FY22-02212022-011606-A	<1	FT-FY22-02212022-011606-B	<1	
WS-011607	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	WF-09282021-011607	3/22/2022	FT-FY22-02212022-011607-A	<1	FT-FY22-02212022-011607-B	<1	
WS-011608	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N004	Left	WF-09282021-011608	3/22/2022	FT-FY22-02212022-011608-A	1.0	FT-FY22-02212022-011608-B	<1
WS-011609	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N004	Right	WF-09282021-011609	3/22/2022	FT-FY22-02212022-011609-A	<1	FT-FY22-02212022-011609-B	<1
WS-011610	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N005		WF-09282021-011610	3/22/2022	FT-FY22-02212022-011610-A	1.7	FT-FY22-02212022-011610-B	<1
WS-011611	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N009A		WF-09282021-011611	3/22/2022	FT-FY22-02212022-011611-A	<1	FT-FY22-02212022-011611-B	<1
WS-011612	9/28/2021	9/28/2022	Basement	Classroom Faucet	In classroom N009	Left	WF-09282021-011612	3/22/2022	FT-FY22-02212022-011612-A	<1	FT-FY22-02212022-011612-B	<1
WS-011616	4/19/2021	4/19/2022	Basement	Break Room	In break room N008 in room N001		WF-04192021-011616	3/22/2022	FT-FY22-02212022-011616-A	<1	FT-FY22-02212022-011616-B	<1
WS-011618	4/19/2021	4/19/2022	Basement	Cooler	In hallway across from stairwell 9		WF-04192021-011618	3/22/2022	FT-FY22-02212022-011618-A	<1	FT-FY22-02212022-011618-B	2.4
WS-011638	4/19/2021	4/19/2022	Basement	Cooler	In hallway adjacent to room S007		WF-04192021-011638	3/22/2022	FT-FY22-02212022-011638-A	<1	FT-FY22-02212022-011638-B	<1
WS-011639	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room S102		WF-04192021-011639	3/22/2022	FT-FY22-02212022-011639-A	<1	FT-FY22-02212022-011639-B	<1
WS-011640	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room G101		WF-04192021-011640	3/22/2022	FT-FY22-02212022-011640-A	<1	FT-FY22-02212022-011640-B	1.4
WS-011642	4/19/2021	4/19/2022	1	Health Suite	In health suite across from M105F		WF-04192021-011642	3/22/2022	FT-FY22-02212022-011642-A	<1	FT-FY22-02212022-011642-B	<1
WS-011643	4/19/2021	4/19/2022	1	Health Suite	In health suite M105F		WF-04192021-011643	3/22/2022	FT-FY22-02212022-011643-A	1.4	FT-FY22-02212022-011643-B	2.0
WS-011644	4/19/2021	4/19/2022	1	Health Suite	In health suite M105H		WF-04192021-011644	3/22/2022	FT-FY22-02212022-011644-A	<1	FT-FY22-02212022-011644-B	<1
WS-011645	4/19/2021	4/19/2022	1	Health Suite	In health suite M105E		WF-04192021-011645	3/22/2022	FT-FY22-02212022-011645-A	<1	FT-FY22-02212022-011645-B	<1
WS-011646	4/19/2021	4/19/2022	1	Health Suite	In health suite across from room M105D		WF-04192021-011646	3/22/2022	FT-FY22-02212022-011646-A	4.3	FT-FY22-02212022-011646-B	1.4
WS-011647	4/19/2021	4/19/2022	1	Health Suite	In health suite across from room M105A		WF-04192021-011647	3/22/2022	FT-FY22-02212022-011647-A	<1	FT-FY22-02212022-011647-B	<1
WS-011648	4/19/2021	4/19/2022	1	Health Suite	In health suite M105N	Right	WF-04192021-011648	3/22/2022	FT-FY22-02212022-011648-A	<1	FT-FY22-02212022-011648-B	3.0
WS-011649	4/19/2021	4/19/2022	1	Health Suite	In health suite M105N	Left	WF-04192021-011649	3/22/2022	FT-FY22-02212022-011649-A	<1	FT-FY22-02212022-011649-B	<1
WS-011650	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room M115		WF-04192021-011650	3/22/2022	FT-FY22-02212022-011650-A	2.6	FT-FY22-02212022-011650-B	<1
WS-011651	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room N110		WF-04192021-011651	3/22/2022	FT-FY22-02212022-011651-A	<1	FT-FY22-02212022-011651-B	<1
WS-011653	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M202		WF-04192021-011653	3/22/2022	FT-FY22-02212022-011653-A	<1	FT-FY22-02212022-011653-B	1.7
WS-011655	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M212A		WF-04192021-011655	3/22/2022	FT-FY22-02212022-011655-A	<1	FT-FY22-02212022-011655-B	<1
WS-011667	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room M220		WF-04192021-011667	3/22/2022	FT-FY22-02212022-011667-A	<1	FT-FY22-02212022-011667-B	1.2
WS-011688	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room S204		WF-04192021-011688	3/22/2022	FT-FY22-02212022-011688-A	<1	FT-FY22-02212022-011688-B	<1
WS-011690	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room G204		WF-04192021-011690	3/22/2022	FT-FY22-02212022-011690-A	<1	FT-FY22-02212022-011690-B	<1
WS-011691	4/19/2021	4/19/2022	2	Cooler	In hallway across from room N201		WF-04192021-011691	3/22/2022	FT-FY22-02212022-011691-A	<1	FT-FY22-02212022-011691-B	<1
WS-011702	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room M319		WF-04192021-011702	3/22/2022	FT-FY22-02212022-011702-A	<1	FT-FY22-02212022-011702-B	<1
WS-011703	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room M303		WF-04192021-011703	3/22/2022	FT-FY22-02212022-011703-A	<1	FT-FY22-02212022-011703-B	<1
WS-011714	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room G302		WF-04192021-011714	3/22/2022	FT-FY22-02212022-011714-A	<1	FT-FY22-02212022-011714-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011600	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-02092022-011600	3/22/2022	FT-FY22-02212022-011600-A	<1	FT-FY22-02212022-011600-B	<1