



# ANACOSTIA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011723	Classroom	Basement	In science lab room G001 clockwise 4	Left	WT-042916-11740- A	5				
2	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011722	Classroom	Basement	In science lab room s001 clockwise 4	Right	WT-042916-11739- A	< 1				
3	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011721	Classroom	Basement	In science lab room G001 clockwise 3	Right	WT-042916-11738- A	2.8				
4	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011720	Classroom	Basement	In science lab room s001 clockwise 3	Mid	WT-042916-11737- A	5				
5	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011719	Classroom	Basement	In science lab room s001 clockwise 3	Left	WT-042916-11736- A	6.3				
6	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011718	Classroom	Basement	In science lab room S001 clockwise 2	Right	WT-042916-11735- A	4.8				
7	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011717	Classroom	Basement	In science lab room S001 clockwise 2	Mid	WT-042916-11734- A	5.3				
8	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011716	Classroom	Basement	In science lab room s001 clockwise 2	Left	WT-042916-11733- A	2.4				
9	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011715	Classroom	Basement	In science lab room s001 clockwise 1		WT-042916-11732- A	2.4				
10	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011714	Cooler	3	In hallway adjacent to room g302		WT-042916-11731- A	< 1				
11	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011713	Classroom	3	In science lab room m305 prep room		WT-042916-11730- A	3				
12	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011712	Classroom	3	In science lab room m305 clockwise 4	Right	WT-042916-11729- A	3.1				
13	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011711	Classroom	3	In science lab room m305 clockwise 4	Left	WT-042916-11728- A	< 1				
14	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011710	Classroom	3	In science lab room m305 clockwise 3	Right	WT-042916-11727- A	11.4				
15	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011709	Classroom	3	In science lab room M305 clockwise 3	Mid	WT-042916-11726- A	4.5				
16	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011708	Classroom	3	In science lab room m305 clockwise 3	Left	WT-042916-11725- A	4				
17	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011707	Classroom	3	In science lab room M305 clockwise 2	Right	WT-042916-11724- A	2.8				
18	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011706	Classroom	3	In science lab room M305 clockwise 2	Mid	WT-042916-11723- A	1.9				
19	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011705	Classroom	3	In science lab room M305 clockwise 2	Left	WT-042916-11722- A	1.9				
20	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011704	Classroom	3	In science lab room M305 clockwise 1		WT-042916-11721- A	2.5				
21	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011703	Cooler	3	In hallway adjacent to room M303		WT-042916-11720- A	< 1				
22	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011702	Cooler	3	In hallway adjacent to room M319		WT-042916-11719- A	< 1				
23	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011701	Classroom	3	In science lab prep room m317		WT-042916-11718- A	< 1				
24	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011700	Classroom	3	In science lab room M317 clockwise 4		WT-042916-11717- A	1.7				
25	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011699	Classroom	3	In science lab room m317 clockwise 3	Left	WT-042916-11716- A	1.3				
26	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011698	Classroom	3	In science lab room m317 clockwise 3	Mid	WT-042916-11715- A	1.7				
27	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011697	Classroom	3	In science lab room m317	Right	WT-042916-11714- A	1.7				
28	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011696	Classroom	3	In science lab room M317 clockwise 2	Left	WT-042916-11713- A	2.1				
29	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011695	Classroom	3	In science lab room M317 clockwise 2	Mid	WT-042916-11712- A	2.4				
30	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011694	Classroom	3	In room M317 clockwise 2	Right	WT-042916-11711- A	< 1				
31	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011693	Classroom	3	In science lab M317 clockwise 1	Right	WT-042916-11710- A	1.3				
32	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011692	Classroom	3	In science lab room M317 clockwise 1	Left	WT-042916-11709- A	1				
33	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011691	Cooler	2	In hallway across from room N201		WT-042916-11708- A	< 1				
34	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011690	Cooler	2	In hallway adjacent to room G204		WT-042916-11707- A	< 1				
35	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011689	Other	2	In room G204 ( work room)		WT-042916-11706- A	< 1				
36	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011688	Cooler	2	In hallway adjacent to room S204		WT-042916-11705- A	< 1				
37	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011687	Classroom	2	In science lab room S202 prep room		WT-042916-11704- A	2.1				
38	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011686	Classroom	2	In science lab room s202 clockwise 4	Right	WT-042916-11703- A	< 1				
39	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011685	Classroom	2	In science lab room s202 clockwise 4	Left	WT-042916-11702- A	2.1				
40	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011684	Classroom	2	In science lab room s202 clockwise 3	Right	WT-042916-11701- A	< 1				
41	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011683	Classroom	2	In science lab room S202 clockwise 3	Mid	WT-042916-11700- A	< 1				
42	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011682	Classroom	2	In science lab room S202 clockwise 3	Left	WT-042916-11699- A	1.4				
43	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011681	Classroom	2	In science lab room S202 clockwise 2	Right	WT-042916-11698- A	< 1				
44	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011680	Classroom	2	In Science lab room S202 clockwise 2	Mid	WT-042916-11697- A	< 1				
45	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011679	Classroom	2	In science lab room S202 clockwise 2	Left	WT-042916-11696- A	< 1				
46	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011678	Classroom	2	In science lab room S202 clockwise 1		WT-042916-11695- A	1.6				
47	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011677	Classroom	2	In room M221		WT-042916-11694- A	< 1				
48	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011676	Classroom	2	In room M220 clockwise 4	Right	WT-042916-11693- A	2.5				
49	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011675	Classroom	2	In room M220 clockwise clockwise 4		WT-042916-11692- A	5.2				
50	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011674	Classroom	2	In science lab room 220 clockwise 4	Right	WT-042916-11691- A	4.4				
51	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011673	Classroom	2	In science lab room m220 clockwise 3	Left	WT-042916-11690- A	3.8				
52	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011672	Classroom	2	In science lab room M220	Left	WT-042916-11689- A	2.5				
53	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011671	Classroom	2	In room M220 clockwise clockwise 2	Right	WT-042916-11688- A	2.1				
54	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011670	Classroom	2	In room M220 clockwise clockwise 2	Mid	WT-042916-11687- A	2.9				
55	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011669	Classroom	2	In room M220 clockwise 2	Left	WT-042916-11686- A	< 1				2.7
56	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011668	Classroom	2	In room M220 clockwise 1		WT-042916-11685- A	1				< 1
57	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011667	Cooler	2	In hallway adjacent to room M220		WT-042916-11684- A	< 1				< 1
58	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011666	Classroom	2	In room M218 clockwise 4		WT-042916-11683- A	4.8				< 1
59	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011665	Classroom	2	In science lab room 218 clockwise 3	Right	WT-042916-11682- A	< 1				< 1
60	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011664	Classroom	2	In science lab room M218 clockwise 3	Mid	WT-042916-11681- A	3.2				< 1
61	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011663	Classroom	2	In science lab room M218 clockwise 3	Left	WT-042916-11680- A	1.8				< 1
62	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011662	Classroom	2	In room M218 clockwise 2	Right	WT-042916-11679- A	1.4				< 1
63	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011661	Classroom	2	In room M218 clockwise 2	Mid	WT-042916-11678- A	1.8				< 1
64	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011660	Classroom	2	In room M218 clockwise 2	Left	WT-042916-11677- A	< 1				< 1
65	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011659	Classroom	2	In science lab room M218	Right	WT-042916-11676- A	2.4				< 1



# ANACOSTIA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
66	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011658	Classroom	2	In science lab room M218 clockwise 1	Left	WT-042916-11675- A	1.4	WT-042916-11675- B	< 1		
67	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011657	Classroom	2	In room M217		WT-042916-11674- A	1.2	WT-042916-11674- B	< 1		
68	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011656	Classroom	2	In room M215		WT-042916-11673- A	< 1	WT-042916-11673- B	1.1		
69	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011655	Cooler	2	In hallway adjacent to M212A		WT-042916-11672- A	< 1	WT-042916-11672- B	< 1		
70	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011654	Classroom	2	In room M210		WT-042916-11671- A	< 1	WT-042916-11671- B	< 1		
71	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011653	Cooler	2	In hallway adjacent to room M202		WT-042916-11670- A	< 1	WT-042916-11670- B	< 1		
72	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011652	Classroom	2	In room M201		WT-042916-11669- A	< 1	WT-042916-11669- B	< 1		
73	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011651	Cooler	1	In hallway adjacent to N110		WT-042916-11668- A	< 1	WT-042916-11668- B	< 1		
74	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011650	Cooler	1	In hallway adjacent to room M115		WT-042916-11667- A	< 1	WT-042916-11667- B	< 1		
75	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011649	Health Suite	1	In health suite M105N	Left	WT-042916-11666- A	1.7	WT-042916-11666- B	< 1		
76	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011648	Health Suite	1	In health suite room M105N	Right	WT-042916-11665- A	1.6	WT-042916-11665- B	< 1		
77	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011647	Health Suite	1	In healthsuit room Across from M105A		WT-042916-11664- A	< 1	WT-042916-11664- B	< 1		
78	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011646	Health Suite	1	In health suite across from room M105D		WT-042916-11663- A	< 1	WT-042916-11663- B	< 1		
79	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011645	Health Suite	1	In room M105E		WT-042916-11662- A	1.2	WT-042916-11662- B	< 1		
80	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011644	Health Suite	1	In health suite room M105H		WT-042916-11661- A	1.1	WT-042916-11661- B	< 1		
81	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011643	Health Suite	1	In healthsuit room M105F		WT-042916-11660- A	5.9	WT-042916-11660- B	< 1		
82	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011642	Health Suite	1	In health suite across from the room M105F		WT-042916-11659- A	< 1	WT-042916-11659- B	< 1		
83	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011641	Cooler	1	In hallway adjacent to room M103		WT-042916-11658- A	< 1	WT-042916-11658- B	< 1		
84	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011640	Cooler	1	In hallway adjacent to room G101		WT-042916-11657- A	< 1	WT-042916-11657- B	< 1		
85	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011639	Cooler	1	In hallway adjacent to room S102		WT-042916-11656- A	< 1	WT-042916-11656- B	< 1		
86	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011638	Cooler	Basement	In hallway adjacent to room S007		WT-042916-11655- A	< 1	WT-042916-11655- B	< 1		
87	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011637	Classroom	Basement	In science prep room S006		WT-042916-11654- A	< 1	WT-042916-11654- B	< 1		
88	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011636	Classroom	Basement	In science lab room S007 clockwise 4		WT-042916-11653- A	5.2	WT-042916-11653- B	< 1		
89	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011635	Classroom	Basement	In science lab room S007 clockwise 2	Right	WT-042916-11652- A	< 1	WT-042916-11652- B	< 1		
90	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011634	Classroom	Basement	In science lab room s007	Mid	WT-042916-11651- A	< 1	WT-042916-11651- B	< 1		
91	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011633	Classroom	Basement	In science lab room s007	Left	WT-042916-11650- A	< 1	WT-042916-11650- B	< 1		
92	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011632	Classroom	Basement	In science lab room 006	Right	WT-042916-11649- A	2.6	WT-042916-11649- B	< 1		
93	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011631	Classroom	Basement	In science lab room S007 clockwise 2	Mid	WT-042916-11648- A	2	WT-042916-11648- B	< 1		
94	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011630	Classroom	Basement	In science lab S007 clockwise 2	Right	WT-042916-11647- A	2.6	WT-042916-11647- B	< 1		
95	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011629	Classroom	Basement	In science lab room S007 clockwise 1	Right	WT-042916-11646- A	2	WT-042916-11646- B	< 1		
96	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011628	Classroom	Basement	In science lab room S003 clockwise 1	Left	WT-042916-11645- A	< 1	WT-042916-11645- B	< 1		
97	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011627	Classroom	Basement	In science prep room S003		WT-042916-11644- A	< 1	WT-042916-11644- B	< 1		
98	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011626	Classroom	Basement	In science lab room S003 clockwise 3	Left	WT-042916-11643- A	4.5	WT-042916-11643- B	< 1		
99	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011625	Classroom	Basement	In science lab room S003 clockwise 3	Right	WT-042916-11642- A	3.7	WT-042916-11642- B	< 1		
100	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011624	Classroom	Basement	In science lab room S003 clockwise 3	Right	WT-042916-11641- A	5.1	WT-042916-11641- B	< 1		
101	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011623	Classroom	Basement	In science lab room s003 clockwise 2	Mid	WT-042916-11640- A	5	WT-042916-11640- B	< 1		
102	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011622	Classroom	Basement	In room s013 clockwise 1	Left	WT-042916-11639- A	5.9	WT-042916-11639- B	< 1		
103	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011621	Classroom	Basement	In science lab room S003	Right	WT-042916-11638- A	< 1	WT-042916-11638- B	< 1		
104	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011620	Classroom	Basement	In science lab room S003 clockwise 1	Mid	WT-042916-11637- A	< 1	WT-042916-11637- B	< 1		
105	ANACOSTIA HIGH SCHOOL	5/18/2016	WS- 011619	Classroom	Basement	In science lab room S003 clockwise 1	Left	WT-042916-11636- A	< 1	WT-042916-11636- B	< 1		
106	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011618	Cooler	Basement	In hallway across from the stair 9		WT-042916-11635- A	< 1	WT-042916-11635- B	< 1		
107	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011617	Classroom	Basement	In room S003 clockwise 1		WT-042916-11634- A	67	WT-042916-11634- B	< 1	Filter will be installed and then retested	
108	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011616	Break Room	Basement	In room N008		WT-042916-11633- A	< 1	WT-042916-11633- B	< 1		
109	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011615	Classroom	Basement	In room N012		WT-042916-11632- A	7.2	WT-042916-11632- B	< 1		
110	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011614	Classroom	Basement	In room N012		WT-042916-11631- A	1.7	WT-042916-11631- B	< 1		
111	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011613	Classroom	Basement	In room N009 clockwise 2		WT-042916-11630- A	< 1	WT-042916-11630- B	< 1		
112	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011612	Classroom	Basement	In room N009 clockwise 1		WT-042916-11629- A	< 1	WT-042916-11629- B	< 1		
113	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011611	Classroom	Basement	In room N009A		WT-042916-11628- A	< 1	WT-042916-11628- B	< 1		
114	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011610	Classroom	Basement	In room N005		WT-042916-11627- A	< 1	WT-042916-11627- B	< 1		
115	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011609	Classroom	Basement	In room N004 clockwise 2		WT-042916-11626- A	< 1	WT-042916-11626- B	< 1		
116	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011608	Classroom	Basement	In room N004 clockwise 1		WT-042916-11625- A	1	WT-042916-11625- B	< 1		
117	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011607	Classroom	Basement	In room N003		WT-042916-11624- A	< 1	WT-042916-11624- B	< 1		
118	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011606	Classroom	Basement	In room N003 clockwise 2		WT-042916-11623- A	2.8	WT-042916-11623- B	< 1		
119	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011605	Classroom	Basement	In room N003 clockwise 1		WT-042916-11622- A	< 1	WT-042916-11622- B	< 1		
120	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011604	Kitchen	Basement	In kitchen spray nozzle clockwise 6		WT-042916-11621- A	1	WT-042916-11621- B	< 1		
121	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011603	Kitchen	Basement	In kitchen clockwise 5		WT-042916-11620- A	< 1	WT-042916-11620- B	< 1		
122	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011602	Kitchen	Basement	In kitchen clockwise 4		WT-042916-11619- A	< 1	WT-042916-11619- B	< 1		
123	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011601	Kitchen	Basement	In kitchen spray nozzle clockwise 3		WT-042916-11618- A	< 1	WT-042916-11618- B	< 1		
124	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011600	Kitchen	Basement	In kitchen clockwise 2		WT-042916-11617- A	< 1	WT-042916-11617- B	< 1		
125	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011599	Kitchen	Basement	In kitchen ice maker clockwise 1		WT-042916-11616- A	< 1	WT-042916-11616- B	< 1		



# ANACOSTIA LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
126	ANACOSTIA HIGH SCHOOL	5/17/2016	WS- 011598	Utility	Basement	In boiler room	WT-042916-11615- A	< 1	WT-042916-11615- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.