



## ANACOSTIA REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	ANACOSTIA RECREATION CENTER	WS- 005330	9/20/2016	1	Cooler	In hallway	FT-82016-005330-A	< 1	FT-82016-005330-B	< 1
2	ANACOSTIA RECREATION CENTER	WS- 005331	9/20/2016	1	Food Prep Sink	In left gym	FT-82016-005331-A	< 1	FT-82016-005331-B	< 1