



# Anacostia Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011599	6/23/17	6/23/18	Basement	Ice Maker	In kitchen first clockwise from entry door	WF-62017-011599	12/20/17	FT-FY18--62017-011599-A	<1	FT-FY18--62017-011599-B	<1
WS- 011611	11/20/17	11/20/18	Basement	Classroom Faucet	In classroom N009A	WF-112017-011611	12/20/17	FT-FY18-112017-011611-A	<1	FT-FY18-112017-011611-B	<1
WS- 011614	11/20/17	11/20/18	Basement	Classroom Faucet	In classroom N012 Right	WF-112017-011614	12/20/17	FT-FY18-112017-011614-A	<1	FT-FY18-112017-011614-B	<1
WS- 011616	6/23/17	6/23/18	Basement	Break Room	In break room N008 in room N001	WF-62017-011616	12/20/17	FT-FY18--62017-011616-A	<1	FT-FY18--62017-011616-B	<1
WS- 011618	6/23/17	6/23/18	Basement	Cooler	In hallway across from stairwell 9	WF-62017-011618	12/20/17	FT-FY18--62017-011618-A	<1	FT-FY18--62017-011618-B	<1
WS- 011641	6/23/17	6/23/18	1	Cooler	In hallway adjacent to room M103	WF-62017-011641	12/20/17	FT-FY18--62017-011641-A	<1	FT-FY18--62017-011641-B	<1
WS- 011642	6/23/17	6/23/18	1	Health Suite	In health suite across from M105F	WF-62017-011642	12/20/17	FT-FY18--62017-011642-A	<1	FT-FY18--62017-011642-B	<1
WS- 011648	6/23/17	6/23/18	1	Health Suite	In health suite M105N Right	WF-62017-011648	12/20/17	FT-FY18--62017-011648-A	<1	FT-FY18--62017-011648-B	<1
WS- 011649	6/23/17	6/23/18	1	Health Suite	In health suite M105N Left	WF-62017-011649	12/20/17	FT-FY18--62017-011649-A	<1	FT-FY18--62017-011649-B	<1
WS- 011688	6/23/17	6/23/18	2	Cooler	In hallway adjacent to room S204	WF-62017-011688	12/20/17	FT-FY18--62017-011688-A	<1	FT-FY18--62017-011688-B	<1
WS- 011690	6/23/17	6/23/18	2	Cooler	In hallway adjacent to room G204	WF-62017-011690	12/20/17	FT-FY18--62017-011690-A	<1	FT-FY18--62017-011690-B	<1
WS- 011702	6/23/17	6/23/18	3	Cooler	In hallway adjacent to room M319	WF-62017-011702	12/20/17	FT-FY18--62017-011702-A	<1	FT-FY18--62017-011702-B	<1
WS- 011703	6/23/17	6/23/18	3	Cooler	In hallway adjacent to room M303	WF-62017-011703	12/20/17	FT-FY18--62017-011703-A	<1	FT-FY18--62017-011703-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011600	Basement	Food Prep Sink	In kitchen second clockwise from entry door	12/20/17	FT-FY18-102017-011600-A	<1	FT-FY18-102017-011600-B	<1	