



# Anacostia HS Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-011605	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N003 first clockwise from entry door	WF-10242018-011605	11/9/2018	FT-FY19-102018-011605-A	< 1	FT-FY19-102018-011605-B	< 1	
WS-011606	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N003 second clockwise from entry door	WF-10242018-011606	11/9/2018	FT-FY19-102018-011606-A	< 1	FT-FY19-102018-011606-B	< 1	
WS-011607	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N003 third clockwise from entry door	WF-10242018-011607	11/9/2018	FT-FY19-102018-011607-A	< 1	FT-FY19-102018-011607-B	< 1	
WS-011608	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N004	Left	WF-10242018-011608	11/9/2018	FT-FY19-102018-011608-A	< 1	FT-FY19-102018-011608-B	< 1
WS-011609	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N004	Right	WF-10242018-011609	11/9/2018	FT-FY19-102018-011609-A	< 1	FT-FY19-102018-011609-B	< 1
WS-011610	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N005		WF-10242018-011610	11/9/2018	FT-FY19-102018-011610-A	< 1	FT-FY19-102018-011610-B	< 1
WS-011611	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N009A		WF-10242018-011611	11/9/2018	FT-FY19-102018-011611-A	< 1	FT-FY19-102018-011611-B	< 1
WS-011612	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N009	Left	WF-10242018-011612	11/9/2018	FT-FY19-102018-011612-A	< 1	FT-FY19-102018-011612-B	< 1
WS-011613	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N009	Right	WF-10242018-011613	11/9/2018	FT-FY19-102018-011613-A	< 1	FT-FY19-102018-011613-B	< 1
WS-011614	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N012	Right	WF-10242018-011614	11/9/2018	FT-FY19-102018-011614-A	< 1	FT-FY19-102018-011614-B	< 1
WS-011615	10/24/2018	10/24/2019	Basement	Classroom Faucet	In classroom N012	Left	WF-10242018-011615	11/9/2018	FT-FY19-102018-011615-A	< 1	FT-FY19-102018-011615-B	< 1
WS-011616	6/4/2018	6/4/2019	Basement	Break Room	In break room N008 in room N001		WF-06042018-011616	11/9/2018	FT-FY19-102018-011616-A	< 1	FT-FY19-102018-011616-B	< 1
WS-011618	6/4/2018	6/4/2019	Basement	Cooler	In hallway across from stairwell 9		WF-06042018-011618	11/9/2018	FT-FY19-102018-011618-A	< 1	FT-FY19-102018-011618-B	< 1
WS-011638	6/4/2018	6/4/2019	Basement	Cooler	In hallway adjacent to room S007		WF-06042018-011638	11/9/2018	FT-FY19-102018-011638-A	< 1	FT-FY19-102018-011638-B	< 1
WS-011639	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room S102		WF-06042018-011639	11/9/2018	FT-FY19-102018-011639-A	< 1	FT-FY19-102018-011639-B	< 1
WS-011640	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room G101		WF-06042018-011640	11/9/2018	FT-FY19-102018-011640-A	< 1	FT-FY19-102018-011640-B	< 1
WS-011641	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room M103		WF-06042018-011641	11/9/2018	FT-FY19-102018-011641-A	< 1	FT-FY19-102018-011641-B	< 1
WS-011642	6/4/2018	6/4/2019	1	Health Suite	In health suite across from M105F		WF-06042018-011642	11/9/2018	FT-FY19-102018-011642-A	< 1	FT-FY19-102018-011642-B	< 1
WS-011643	6/4/2018	6/4/2019	1	Health Suite	In health suite M105F		WF-06042018-011643	11/9/2018	FT-FY19-102018-011643-A	< 1	FT-FY19-102018-011643-B	< 1
WS-011644	6/4/2018	6/4/2019	1	Health Suite	In health suite M105H		WF-06042018-011644	11/9/2018	FT-FY19-102018-011644-A	< 1	FT-FY19-102018-011644-B	< 1
WS-011645	6/4/2018	6/4/2019	1	Health Suite	In health suite M105E		WF-06042018-011645	11/9/2018	FT-FY19-102018-011645-A	< 1	FT-FY19-102018-011645-B	< 1
WS-011646	6/4/2018	6/4/2019	1	Health Suite	In health suite across from room M105D		WF-06042018-011646	11/9/2018	FT-FY19-102018-011646-A	< 1	FT-FY19-102018-011646-B	< 1
WS-011647	6/4/2018	6/4/2019	1	Health Suite	In health suite across from room M105A		WF-06042018-011647	11/9/2018	FT-FY19-102018-011647-A	< 1	FT-FY19-102018-011647-B	< 1
WS-011648	6/4/2018	6/4/2019	1	Health Suite	In health suite M105N	Right	WF-06042018-011648	11/9/2018	FT-FY19-102018-011648-A	< 1	FT-FY19-102018-011648-B	< 1
WS-011649	6/4/2018	6/4/2019	1	Health Suite	In health suite M105N	Left	WF-06042018-011649	11/9/2018	FT-FY19-102018-011649-A	< 1	FT-FY19-102018-011649-B	< 1
WS-011650	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room M115		WF-06042018-011650	11/9/2018	FT-FY19-102018-011650-A	< 1	FT-FY19-102018-011650-B	< 1
WS-011651	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room N110		WF-06042018-011651	11/9/2018	FT-FY19-102018-011651-A	< 1	FT-FY19-102018-011651-B	< 1
WS-011653	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room M202		WF-06042018-011653	11/9/2018	FT-FY19-102018-011653-A	< 1	FT-FY19-102018-011653-B	< 1
WS-011655	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room M212A		WF-06042018-011655	11/9/2018	FT-FY19-102018-011655-A	< 1	FT-FY19-102018-011655-B	< 1
WS-011667	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room M220		WF-06042018-011667	11/9/2018	FT-FY19-102018-011667-A	< 1	FT-FY19-102018-011667-B	< 1
WS-011688	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room S204		WF-06042018-011688	11/9/2018	FT-FY19-102018-011688-A	< 1	FT-FY19-102018-011688-B	< 1
WS-011690	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room G204		WF-06042018-011690	11/9/2018	FT-FY19-102018-011690-A	< 1	FT-FY19-102018-011690-B	< 1

WS- 011691	6/4/2018	6/4/2019	2	Cooler	In hallway across from room N201	WF-06042018-011691	11/9/2018	FT-FY19-102018-011691-A	< 1	FT-FY19-102018-011691-B	< 1
WS- 011702	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room M319	WF-06042018-011702	11/9/2018	FT-FY19-102018-011702-A	< 1	FT-FY19-102018-011702-B	< 1
WS- 011703	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room M303	WF-06042018-011703	11/9/2018	FT-FY19-102018-011703-A	< 1	FT-FY19-102018-011703-B	< 1
WS- 011714	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room G302	WF-06042018-011714	11/9/2018	FT-FY19-102018-011714-A	< 1	FT-FY19-102018-011714-B	< 1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 011600	Basement	Food Prep Sink	In kitchen second clockwise from entry door	11/9/2018	FT-FY19-102018-011600-A	< 1	FT-FY19-102018-011600-B	< 1		