



Arboretum RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005019	3/31/2021	3/31/2022	1	Fountain	In lobby adjacent to restrooms	High	Left	WF-03312021-005019	4/27/2021	FT-FY21-042021-005019-A	<1	FT-FY21-042021-005019-B	<1
WS- 005116	3/31/2021	3/31/2022	1	Cooler	In lobby adjacent to restrooms	Low	Right	WF-03312021-005116	4/27/2021	FT-FY21-042021-005116-A	<1	FT-FY21-042021-005116-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005017	2/23/2021	2/23/2022	1	Food Prep Sink	In lobby adjacent to restrooms (water source)	WF-02232021-005017	4/27/2021	FT-FY21-042021-005017-A	<1	FT-FY21-042021-005017-B	<1