



Arborteam RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005019	6/21/17	6/21/18	1	Fountain	In lobby adjacent to restrooms Left High	WF-62017-005019	2/6/18	FT-FY18--62017-005019-A	<1	FT-FY18--62017-005019-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005017	6/21/17	6/21/18	1	Food Prep Sink	In lobby adjacent to restrooms (water source)	WF-62017-005017	2/6/18	FT-FY18--62017-005017-A	<1	FT-FY18--62017-005017-B	<1