



ARBORETUM REC LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	ARBORETUM RECREATION CENTER	5/24/2016	WS- 005017	Kitchen	1	In lobby adjacent to restrooms (water source)	WT-042916-5034- A	1.8	WT-042916-5034- B	< 1				
2	ARBORETUM RECREATION CENTER	5/24/2016	WS- 005019	Fountain	1	In lobby adjacent to restrooms	WT-042916-5036- A	< 1	WT-042916-5036- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.