



# Bald Eagle RC Lead Water Test Results



## FY18 Filter Test

| Less than 5 ppb - Devices Requiring No Remediation |                       |                        |              |             |   |                    |               |                         |                                  |                         |                                  |
|--|-----------------------|------------------------|--------------|-------------|---|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID  | Filter Installed Date | Filter Expiration Date | Floor        | Device Type | Device Location                               | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS-012588  | 6/13/17               | 6/13/18                | Ground Floor | Cooler      | In hallway across from men's and women's room | WF-62017-012588    | 3/7/18        | FT-FY18--62017-012588-A | <1                               | FT-FY18--62017-012588-B | <1                               |
| WS-012596  | 6/12/17               | 6/12/18                | Ground Floor | Cooler      | In boxing annex on east wall                  | WF-62017-012596    | 3/7/18        | FT-FY18--62017-012596-A | <1                               | FT-FY18--62017-012596-B | <1                               |

## Food Prep Sink

| Less than 5 ppb - Devices Requiring No Remediation |                       |                        |              |                |                               |                    |               |                         |                                  |                         |                                  |
|--|-----------------------|------------------------|--------------|----------------|-------------------------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID  | Filter Installed Date | Filter Expiration Date | Floor        | Device Type    | Device Location               | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS-012591  | 6/12/17               | 6/12/18                | Ground Floor | Food Prep Sink | In kitchen 101 north wall     | WF-62017-012591    | 3/7/18        | FT-FY18--62017-012591-A | <1                               | FT-FY18--62017-012591-B | <1                               |
| WS-012593  | 8/7/17                | 8/7/18                 | Ground Floor | Food Prep Sink | In pantry room 216 north wall | WF-82017-012593    | 3/7/18        | FT-FY18--82017-012593-A | <1                               | FT-FY18--82017-012593-B | <1                               |