



Bald Eagle Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012587	4/23/2018	4/23/2019	Ground Floor	Cooler	In hallway across from men's and women's room High Left	WF-04232018-012587	3/18/2019	FT-FY19-032019-012587-A	<1	FT-FY19-032019-012587-B	<1
WS- 012588	4/23/2018	4/23/2019	Ground Floor	Cooler	In hallway across from men's and women's room Low Right	WF-04232018-012588	3/18/2019	FT-FY19-032019-012588-A	<1	FT-FY19-032019-012588-B	<1
WS- 012589	4/23/2018	4/23/2019	Ground Floor	Cooler	In hallway across from fitness room 212 Low Left	WF-04232018-012589	3/18/2019	FT-FY19-032019-012589-A	<1	FT-FY19-032019-012589-B	<1
WS- 012590	4/23/2018	4/23/2019	Ground Floor	Cooler	In hallway across from fitness room 212 High Right	WF-04232018-012590	3/18/2019	FT-FY19-032019-012590-A	<1	FT-FY19-032019-012590-B	<1
WS- 012595	4/23/2018	4/23/2019	Ground Floor	Cooler	In boxing annex on east wall Low Right	WF-04232018-012595	3/18/2019	FT-FY19-032019-012595-A	<1	FT-FY19-032019-012595-B	<1
WS- 012596	4/23/2018	4/23/2019	Ground Floor	Cooler	In boxing annex on east wall High Left	WF-04232018-012596	3/18/2019	FT-FY19-032019-012596-A	<1	FT-FY19-032019-012596-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012591	4/23/2018	4/23/2019	Ground Floor	Food Prep Sink	In kitchen 101 north wall	WF-04232018-012591	3/18/2019	FT-FY19-032019-012591-A	<1	FT-FY19-032019-012591-B	<1
WS- 012593	4/23/2018	4/23/2019	Ground Floor	Food Prep Sink	In pantry room 216 north wall	WF-04232018-012593	3/18/2019	FT-FY19-032019-012593-A	<1	FT-FY19-032019-012593-B	<1