



Ballou High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010370	4/11/2022	4/11/2023	3	Break Room	In staff break room 3304	WF-04112022-010370	2/14/2023	FT-FY23-01262023-010370-A	<1	FT-FY23-01262023-010370-B	<1
WS- 010374	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to auditorium High Left	WF-04112022-010374	2/14/2023	FT-FY23-01262023-010374-A	<1	FT-FY23-01262023-010374-B	<1
WS- 010375	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to auditorium Low Right	WF-04112022-010375	2/14/2023	FT-FY23-01262023-010375-A	<1	FT-FY23-01262023-010375-B	<1
WS- 010399	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3012 Low Right	WF-04112022-010399	2/14/2023	FT-FY23-01262023-010399-A	<1	FT-FY23-01262023-010399-B	<1
WS- 010400	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3012 High Left	WF-04112022-010400	2/14/2023	FT-FY23-01262023-010400-A	<1	FT-FY23-01262023-010400-B	<1
WS- 010910	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3026 High Left	WF-04112022-010910	2/14/2023	FT-FY23-01262023-010910-A	<1	FT-FY23-01262023-010910-B	<1
WS- 010911	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3026 Low Right	WF-04112022-010911	2/14/2023	FT-FY23-01262023-010911-A	<1	FT-FY23-01262023-010911-B	<1
WS- 010959	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3200 High Left	WF-04112022-010959	2/14/2023	FT-FY23-01262023-010959-A	<1	FT-FY23-01262023-010959-B	<1
WS- 010960	4/11/2022	4/11/2023	3	Cooler	In hallway adjacent to room 3200 Low Right	WF-04112022-010960	2/14/2023	FT-FY23-01262023-010960-A	<1	FT-FY23-01262023-010960-B	<1
WS- 011299	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1012 High Left	WF-04112022-011299	2/14/2023	FT-FY23-01262023-011299-A	<1	FT-FY23-01262023-011299-B	<1
WS- 011300	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1012 Low Right	WF-04112022-011300	2/14/2023	FT-FY23-01262023-011300-A	<1	FT-FY23-01262023-011300-B	<1
WS- 011309	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1026 High Left	WF-04112022-011309	2/14/2023	FT-FY23-01262023-011309-A	<1	FT-FY23-01262023-011309-B	<1
WS- 011310	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1026 Low Right	WF-04112022-011310	2/14/2023	FT-FY23-01262023-011310-A	<1	FT-FY23-01262023-011310-B	<1
WS- 011327	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1204 High Left	WF-04112022-011327	2/14/2023	FT-FY23-01262023-011327-A	<1	FT-FY23-01262023-011327-B	<1
WS- 011328	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1204 Low Right	WF-04112022-011328	2/14/2023	FT-FY23-01262023-011328-A	<1	FT-FY23-01262023-011328-B	<1
WS- 011329	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1402 High Left	WF-04112022-011329	2/14/2023	FT-FY23-01262023-011329-A	<1	FT-FY23-01262023-011329-B	<1
WS- 011338	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1306 High Left	WF-04112022-011338	2/14/2023	FT-FY23-01262023-011338-A	<1	FT-FY23-01262023-011338-B	<1
WS- 011339	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to room 1306 Low Right	WF-04112022-011339	2/14/2023	FT-FY23-01262023-011339-A	<1	FT-FY23-01262023-011339-B	<1
WS- 011342	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to dressing room 1612 High Left	WF-04112022-011342	2/14/2023	FT-FY23-01262023-011342-A	<1	FT-FY23-01262023-011342-B	<1
WS- 011343	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to dressing room 1612 Low Right	WF-04112022-011343	2/14/2023	FT-FY23-01262023-011343-A	<1	FT-FY23-01262023-011343-B	<1
WS- 011344	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to day care room 1630 High Left	WF-04112022-011344	2/14/2023	FT-FY23-01262023-011344-A	<1	FT-FY23-01262023-011344-B	<1
WS- 011345	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to day care room 1630 Low Right	WF-04112022-011345	2/14/2023	FT-FY23-01262023-011345-A	<1	FT-FY23-01262023-011345-B	<1
WS- 011346	9/13/2022	9/13/2023	1	Classroom Faucet	In day care room 1630 Right	WF-09132022-011346	2/14/2023	FT-FY23-01262023-011346-A	<1	FT-FY23-01262023-011346-B	<1
WS- 011347	9/13/2022	9/13/2023	1	Classroom Faucet	In day care room 1630	WF-09132022-011347	2/14/2023	FT-FY23-01262023-011347-A	<1	FT-FY23-01262023-011347-B	<1
WS- 011349	9/13/2022	9/13/2023	1	Classroom Faucet	In day care room 1630	WF-09132022-011349	2/14/2023	FT-FY23-01262023-011349-A	<1	FT-FY23-01262023-011349-B	<1
WS- 011359	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2411 High Left	WF-04112022-011359	2/14/2023	FT-FY23-01262023-011359-A	<1	FT-FY23-01262023-011359-B	<1
WS- 011360	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2411 Low Right	WF-04112022-011360	2/14/2023	FT-FY23-01262023-011360-A	<1	FT-FY23-01262023-011360-B	<1
WS- 011377	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2503 Low Right	WF-04112022-011377	2/14/2023	FT-FY23-01262023-011377-A	<1	FT-FY23-01262023-011377-B	<1
WS- 011386	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2503 High Left	WF-04112022-011386	2/14/2023	FT-FY23-01262023-011386-A	<1	FT-FY23-01262023-011386-B	<1
WS- 011399	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2026 High Left	WF-04112022-011399	2/14/2023	FT-FY23-01262023-011399-A	<1	FT-FY23-01262023-011399-B	<1
WS- 011400	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2026 Low Right	WF-04112022-011400	2/14/2023	FT-FY23-01262023-011400-A	<1	FT-FY23-01262023-011400-B	<1
WS- 011416	4/11/2022	4/11/2023	2	Cooler	In pool area left of pool High Left	WF-04112022-011416	2/14/2023	FT-FY23-01262023-011416-A	<1	FT-FY23-01262023-011416-B	<1
WS- 011417	4/11/2022	4/11/2023	2	Cooler	In pool area left of pool Low Right	WF-04112022-011417	2/14/2023	FT-FY23-01262023-011417-A	<1	FT-FY23-01262023-011417-B	<1
WS- 011418	4/11/2022	4/11/2023	2	Cooler	In pool area right of pool High Left	WF-04112022-011418	2/14/2023	FT-FY23-01262023-011418-A	<1	FT-FY23-01262023-011418-B	<1
WS- 011419	4/11/2022	4/11/2023	2	Cooler	In pool area right of pool Low Right	WF-04112022-011419	2/14/2023	FT-FY23-01262023-011419-A	<1	FT-FY23-01262023-011419-B	<1

WS- 011421	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2205	High	Left	WF-04112022-011421	2/14/2023	FT-FY23-01262023-011421-A	<1	FT-FY23-01262023-011421-B	<1
WS- 011422	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2205	Low	Right	WF-04112022-011422	2/14/2023	FT-FY23-01262023-011422-A	<1	FT-FY23-01262023-011422-B	<1
WS- 011426	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to stairwell 6	High	Left	WF-04112022-011426	2/14/2023	FT-FY23-01262023-011426-A	<1	FT-FY23-01262023-011426-B	<1
WS- 011427	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to stairwell 6	Low	Right	WF-04112022-011427	2/14/2023	FT-FY23-01262023-011427-A	<1	FT-FY23-01262023-011427-B	<1
WS- 011432	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2320	High	Left	WF-04112022-011432	2/14/2023	FT-FY23-01262023-011432-A	<1	FT-FY23-01262023-011432-B	<1
WS- 011434	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2320	Low	Right	WF-04112022-011434	2/14/2023	FT-FY23-01262023-011434-A	<1	FT-FY23-01262023-011434-B	<1
WS- 011435	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2200	High	Right	WF-04112022-011435	2/14/2023	FT-FY23-01262023-011435-A	<1	FT-FY23-01262023-011435-B	<1
WS- 011436	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to room 2200	Low	Right	WF-04112022-011436	2/14/2023	FT-FY23-01262023-011436-A	<1	FT-FY23-01262023-011436-B	<1
WS- 011437	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to football locker room	High	Left	WF-04112022-011437	2/14/2023	FT-FY23-01262023-011437-A	<1	FT-FY23-01262023-011437-B	<1
WS- 011438	4/11/2022	4/11/2023	2	Cooler	In hallway adjacent to football locker room	Low	Right	WF-04112022-011438	2/14/2023	FT-FY23-01262023-011438-A	<1	FT-FY23-01262023-011438-B	<1
WS- 011439	4/11/2022	4/11/2023	2	Health Suite	In health suite in break room 2322			WF-04112022-011439	2/14/2023	FT-FY23-01262023-011439-A	<1	FT-FY23-01262023-011439-B	<1
WS- 011440	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2317			WF-04112022-011440	2/14/2023	FT-FY23-01262023-011440-A	<1	FT-FY23-01262023-011440-B	<1
WS- 011441	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2316			WF-04112022-011441	2/14/2023	FT-FY23-01262023-011441-A	<1	FT-FY23-01262023-011441-B	<1
WS- 011442	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2315			WF-04112022-011442	2/14/2023	FT-FY23-01262023-011442-A	<1	FT-FY23-01262023-011442-B	<1
WS- 011443	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2313			WF-04112022-011443	2/14/2023	FT-FY23-01262023-011443-A	<1	FT-FY23-01262023-011443-B	<1
WS- 011444	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2321			WF-04112022-011444	2/14/2023	FT-FY23-01262023-011444-A	<1	FT-FY23-01262023-011444-B	<1
WS- 011445	4/11/2022	4/11/2023	2	Health Suite	In health suite in exam room 2309			WF-04112022-011445	2/14/2023	FT-FY23-01262023-011445-A	<1	FT-FY23-01262023-011445-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011363	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on north wall	Left	WF-12292022-011363	2/14/2023	FT-FY23-01262023-011363-A	<1	FT-FY23-01262023-011363-B	<1
WS- 011364	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on north wall		WF-12292022-011364	2/14/2023	FT-FY23-01262023-011364-A	<1	FT-FY23-01262023-011364-B	<1
WS- 011366	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on east wall		WF-12292022-011366	2/14/2023	FT-FY23-01262023-011366-A	<1	FT-FY23-01262023-011366-B	<1