



Ballou HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010370	5/29/2019	5/29/2020	3	Break Room	In staff break room 3304	WF-05292019-010370	1/16/2020	FT-FY20-122019-010370-A	<1	FT-FY20-122019-010370-B	<1
WS- 010374	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to auditorium High Left	WF-05292019-010374	1/16/2020	FT-FY20-122019-010374-A	<1	FT-FY20-122019-010374-B	<1
WS- 010375	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to auditorium Low Right	WF-05292019-010375	1/16/2020	FT-FY20-122019-010375-A	<1	FT-FY20-122019-010375-B	<1
WS- 010376	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3622 High Left	WF-05292019-010376	1/16/2020	FT-FY20-122019-010376-A	<1	FT-FY20-122019-010376-B	<1
WS- 010377	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3622 Low Right	WF-05292019-010377	1/16/2020	FT-FY20-122019-010377-A	<1	FT-FY20-122019-010377-B	<1
WS- 010399	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3012 Low Right	WF-05292019-010399	1/16/2020	FT-FY20-122019-010399-A	<1	FT-FY20-122019-010399-B	<1
WS- 010400	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3012 High Left	WF-05292019-010400	1/16/2020	FT-FY20-122019-010400-A	<1	FT-FY20-122019-010400-B	<1
WS- 010910	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3026 High Left	WF-05292019-010910	1/16/2020	FT-FY20-122019-010910-A	<1	FT-FY20-122019-010910-B	<1
WS- 010911	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3026 Low Right	WF-05292019-010911	1/16/2020	FT-FY20-122019-010911-A	<1	FT-FY20-122019-010911-B	<1
WS- 010912	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to gym 3210 High Left	WF-05292019-010912	1/16/2020	FT-FY20-122019-010912-A	<1	FT-FY20-122019-010912-B	<1
WS- 010913	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to gym 3210 Low Right	WF-05292019-010913	1/16/2020	FT-FY20-122019-010913-A	<1	FT-FY20-122019-010913-B	<1
WS- 010914	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to gym 3210 High Left	WF-05292019-010914	1/16/2020	FT-FY20-122019-010914-A	<1	FT-FY20-122019-010914-B	<1
WS- 010915	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to gym 3210 Low Right	WF-05292019-010915	1/16/2020	FT-FY20-122019-010915-A	<1	FT-FY20-122019-010915-B	<1
WS- 010916	5/29/2019	5/29/2020	3	Fountain	In gym 3210 Low Right	WF-05292019-010916	1/16/2020	FT-FY20-122019-010916-A	<1	FT-FY20-122019-010916-B	<1
WS- 010917	5/29/2019	5/29/2020	3	Fountain	In gym 3210 High Left	WF-05292019-010917	1/16/2020	FT-FY20-122019-010917-A	<1	FT-FY20-122019-010917-B	<1
WS- 010959	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3200 High Left	WF-05292019-010959	1/16/2020	FT-FY20-122019-010959-A	<1	FT-FY20-122019-010959-B	<1
WS- 010960	5/29/2019	5/29/2020	3	Fountain	In hallway adjacent to room 3200 Low Right	WF-05292019-010960	1/16/2020	FT-FY20-122019-010960-A	<1	FT-FY20-122019-010960-B	<1
WS- 010961	5/29/2019	5/29/2020	3	Fountain	In fitness room 3215 High Left	WF-05292019-010961	1/16/2020	FT-FY20-122019-010961-A	<1	FT-FY20-122019-010961-B	<1
WS- 010962	5/29/2019	5/29/2020	3	Fountain	In fitness room 3215 Low Right	WF-05292019-010962	1/16/2020	FT-FY20-122019-010962-A	<1	FT-FY20-122019-010962-B	<1
WS- 010963	5/29/2019	5/29/2020	3	Fountain	In fitness room 3215 High Left	WF-05292019-010963	1/16/2020	FT-FY20-122019-010963-A	<1	FT-FY20-122019-010963-B	<1
WS- 010964	5/29/2019	5/29/2020	3	Fountain	In fitness room 3215 Low Right	WF-05292019-010964	1/16/2020	FT-FY20-122019-010964-A	<1	FT-FY20-122019-010964-B	<1
WS- 011299	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1012 High Left	WF-05292019-011299	1/16/2020	FT-FY20-122019-011299-A	<1	FT-FY20-122019-011299-B	<1
WS- 011300	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1012 Low Right	WF-05292019-011300	1/16/2020	FT-FY20-122019-011300-A	<1	FT-FY20-122019-011300-B	<1
WS- 011309	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1026 High Left	WF-05292019-011309	1/16/2020	FT-FY20-122019-011309-A	<1	FT-FY20-122019-011309-B	<1
WS- 011310	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1026 Low Right	WF-05292019-011310	1/16/2020	FT-FY20-122019-011310-A	<1	FT-FY20-122019-011310-B	<1
WS- 011327	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1204 High Left	WF-05292019-011327	1/16/2020	FT-FY20-122019-011327-A	<1	FT-FY20-122019-011327-B	<1
WS- 011328	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1204 Low Right	WF-05292019-011328	1/16/2020	FT-FY20-122019-011328-A	<1	FT-FY20-122019-011328-B	<1
WS- 011329	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1402 High Left	WF-05292019-011329	1/16/2020	FT-FY20-122019-011329-A	<1	FT-FY20-122019-011329-B	<1
WS- 011330	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1402 Low Right	WF-05292019-011330	1/16/2020	FT-FY20-122019-011330-A	<1	FT-FY20-122019-011330-B	<1
WS- 011338	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1306 High Left	WF-05292019-011338	1/16/2020	FT-FY20-122019-011338-A	<1	FT-FY20-122019-011338-B	<1
WS- 011339	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to room 1306 Low Right	WF-05292019-011339	1/16/2020	FT-FY20-122019-011339-A	<1	FT-FY20-122019-011339-B	<1
WS- 011340	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to auditorium 1600 Low Right	WF-05292019-011340	1/16/2020	FT-FY20-122019-011340-A	<1	FT-FY20-122019-011340-B	<1
WS- 011341	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to auditorium 1600 High Left	WF-05292019-011341	1/16/2020	FT-FY20-122019-011341-A	<1	FT-FY20-122019-011341-B	<1
WS- 011342	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to dressing room 1612 High Left	WF-05292019-011342	1/16/2020	FT-FY20-122019-011342-A	<1	FT-FY20-122019-011342-B	<1
WS- 011343	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to dressing room 1612 Low Right	WF-05292019-011343	1/16/2020	FT-FY20-122019-011343-A	<1	FT-FY20-122019-011343-B	<1

WS-011344	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to day care room 1630	High	Left	WF-05292019-011344	1/16/2020	FT-FY20-122019-011344-A	<1	FT-FY20-122019-011344-B	<1
WS-011345	5/29/2019	5/29/2020	1	Fountain	In hallway adjacent to day care room 1630	Low	Right	WF-05292019-011345	1/16/2020	FT-FY20-122019-011345-A	<1	FT-FY20-122019-011345-B	<1
WS-011346	10/17/2019	10/17/2020	1	Classroom Faucet	In day care room 1630		Right	WF-10172019-011346	1/16/2020	FT-FY20-122019-011346-A	<1	FT-FY20-122019-011346-B	<1
WS-011347	10/17/2019	10/17/2020	1	Classroom Faucet	In day care room 1630			WF-10172019-011347	1/16/2020	FT-FY20-122019-011347-A	<1	FT-FY20-122019-011347-B	<1
WS-011349	10/17/2019	10/17/2020	1	Classroom Faucet	In day care room 1630			WF-10172019-011349	1/16/2020	FT-FY20-122019-011349-A	<1	FT-FY20-122019-011349-B	<1
WS-011357	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to school store room 2350	High	Left	WF-05292019-011357	1/16/2020	FT-FY20-122019-011357-A	<1	FT-FY20-122019-011357-B	<1
WS-011358	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to school store room 2350	Low	Right	WF-05292019-011358	1/16/2020	FT-FY20-122019-011358-A	<1	FT-FY20-122019-011358-B	<1
WS-011359	10/30/2019	10/30/2020	2	Fountain	In hallway adjacent to room 2411	High	Left	WF-10302019-011359	1/16/2020	FT-FY20-122019-011359-A	<1	FT-FY20-122019-011359-B	<1
WS-011360	10/30/2019	10/30/2020	2	Fountain	In hallway adjacent to room 2411	Low	Right	WF-10302019-011360	1/16/2020	FT-FY20-122019-011360-A	<1	FT-FY20-122019-011360-B	<1
WS-011368	5/29/2019	5/29/2020	2	Ice Maker	In kitchen room 2503 (ice maker)		Left	WF-05292019-011368	1/16/2020	FT-FY20-122019-011368-A	<1	FT-FY20-122019-011368-B	<1
WS-011377	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2503	Low	Right	WF-05292019-011377	1/16/2020	FT-FY20-122019-011377-A	<1	FT-FY20-122019-011377-B	<1
WS-011378	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2623	Low	Right	WF-05292019-011378	1/16/2020	FT-FY20-122019-011378-A	<1	FT-FY20-122019-011378-B	<1
WS-011379	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2623	High	Left	WF-05292019-011379	1/16/2020	FT-FY20-122019-011379-A	<1	FT-FY20-122019-011379-B	<1
WS-011384	5/29/2019	5/29/2020	2	Fountain	In hallway across from room 2012	High	Left	WF-05292019-011384	1/16/2020	FT-FY20-122019-011384-A	<1	FT-FY20-122019-011384-B	<1
WS-011385	5/29/2019	5/29/2020	2	Fountain	In hallway across from room 2012	Low	Right	WF-05292019-011385	1/16/2020	FT-FY20-122019-011385-A	<1	FT-FY20-122019-011385-B	<1
WS-011386	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2503	High	Left	WF-05292019-011386	1/16/2020	FT-FY20-122019-011386-A	<1	FT-FY20-122019-011386-B	<1
WS-011399	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2026	High	Left	WF-05292019-011399	1/16/2020	FT-FY20-122019-011399-A	<1	FT-FY20-122019-011399-B	<1
WS-011400	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2026	Low	Right	WF-05292019-011400	1/16/2020	FT-FY20-122019-011400-A	<1	FT-FY20-122019-011400-B	<1
WS-011414	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2201	High	Left	WF-05292019-011414	1/16/2020	FT-FY20-122019-011414-A	<1	FT-FY20-122019-011414-B	<1
WS-011415	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2201	Low	Right	WF-05292019-011415	1/16/2020	FT-FY20-122019-011415-A	<1	FT-FY20-122019-011415-B	<1
WS-011416	5/29/2019	5/29/2020	2	Fountain	In pool area left of pool	High	Left	WF-05292019-011416	1/16/2020	FT-FY20-122019-011416-A	<1	FT-FY20-122019-011416-B	<1
WS-011417	5/29/2019	5/29/2020	2	Fountain	In pool area left of pool	Low	Right	WF-05292019-011417	1/16/2020	FT-FY20-122019-011417-A	<1	FT-FY20-122019-011417-B	<1
WS-011418	5/29/2019	5/29/2020	2	Fountain	In pool area right of pool	High	Left	WF-05292019-011418	1/16/2020	FT-FY20-122019-011418-A	<1	FT-FY20-122019-011418-B	<1
WS-011419	5/29/2019	5/29/2020	2	Fountain	In pool area right of pool	Low	Right	WF-05292019-011419	1/16/2020	FT-FY20-122019-011419-A	<1	FT-FY20-122019-011419-B	<1
WS-011421	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2205	High	Left	WF-05292019-011421	1/16/2020	FT-FY20-122019-011421-A	<1	FT-FY20-122019-011421-B	<1
WS-011422	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2205	Low	Right	WF-05292019-011422	1/16/2020	FT-FY20-122019-011422-A	<1	FT-FY20-122019-011422-B	<1
WS-011426	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to stairwell 6	High	Left	WF-05292019-011426	1/16/2020	FT-FY20-122019-011426-A	<1	FT-FY20-122019-011426-B	<1
WS-011427	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to stairwell 6	Low	Right	WF-05292019-011427	1/16/2020	FT-FY20-122019-011427-A	<1	FT-FY20-122019-011427-B	<1
WS-011432	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2320	High	Left	WF-05292019-011432	1/16/2020	FT-FY20-122019-011432-A	<1	FT-FY20-122019-011432-B	<1
WS-011434	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2320	Low	Right	WF-05292019-011434	1/16/2020	FT-FY20-122019-011434-A	<1	FT-FY20-122019-011434-B	<1
WS-011435	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2200	High	Right	WF-05292019-011435	1/16/2020	FT-FY20-122019-011435-A	<1	FT-FY20-122019-011435-B	<1
WS-011436	5/29/2019	5/29/2020	2	Fountain	In hallway adjacent to room 2200	Low	Right	WF-05292019-011436	1/16/2020	FT-FY20-122019-011436-A	<1	FT-FY20-122019-011436-B	<1
WS-011439	5/29/2019	5/29/2020	2	Health Suite	In health suite in break room 2322			WF-05292019-011439	1/16/2020	FT-FY20-122019-011439-A	<1	FT-FY20-122019-011439-B	<1
WS-011440	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2317			WF-05292019-011440	1/16/2020	FT-FY20-122019-011440-A	<1	FT-FY20-122019-011440-B	<1
WS-011441	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2316			WF-05292019-011441	1/16/2020	FT-FY20-122019-011441-A	<1	FT-FY20-122019-011441-B	<1
WS-011442	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2315			WF-05292019-011442	1/16/2020	FT-FY20-122019-011442-A	<1	FT-FY20-122019-011442-B	<1
WS-011443	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2313			WF-05292019-011443	1/16/2020	FT-FY20-122019-011443-A	<1	FT-FY20-122019-011443-B	<1
WS-011444	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2321			WF-05292019-011444	1/16/2020	FT-FY20-122019-011444-A	<1	FT-FY20-122019-011444-B	<1
WS-011445	5/29/2019	5/29/2020	2	Health Suite	In health suite in exam room 2309			WF-05292019-011445	1/16/2020	FT-FY20-122019-011445-A	<1	FT-FY20-122019-011445-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011363	7/17/2019	7/17/2020	2	Food Prep Sink	In kitchen room 2503 on north wall Left	WF-07172019-011363	1/16/2020	FT-FY20-122019-011363-A	<1	FT-FY20-122019-011363-B	<1
WS- 011364	7/17/2019	7/17/2020	2	Food Prep Sink	In kitchen room 2503 on north wall	WF-07172019-011364	1/16/2020	FT-FY20-122019-011364-A	<1	FT-FY20-122019-011364-B	<1
WS- 011366	7/17/2019	7/17/2020	2	Food Prep Sink	In kitchen room 2503 on east wall	WF-07172019-011366	1/16/2020	FT-FY20-122019-011366-A	<1	FT-FY20-122019-011366-B	<1
WS- 011369	7/17/2019	7/17/2020	2	Food Prep Sink	In kitchen room 2503 on island Mid	WF-07172019-011369	1/16/2020	FT-FY20-122019-011369-A	<1	FT-FY20-122019-011369-B	<1