



# Ballou High School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010370	5/18/2020	5/18/2021	3	Break Room	In staff break room 3304	WF-05182020-010370	4/3/2021	FT-FY21-032021-010370-A	<1	FT-FY21-032021-010370-B	<1
WS- 010374	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to auditorium High Left	WF-05182020-010374	4/3/2021	FT-FY21-032021-010374-A	<1	FT-FY21-032021-010374-B	<1
WS- 010375	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to auditorium Low Right	WF-05182020-010375	4/3/2021	FT-FY21-032021-010375-A	<1	FT-FY21-032021-010375-B	<1
WS- 010376	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3622 High Left	WF-05182020-010376	4/3/2021	FT-FY21-032021-010376-A	<1	FT-FY21-032021-010376-B	<1
WS- 010377	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3622 Low Right	WF-05182020-010377	4/3/2021	FT-FY21-032021-010377-A	<1	FT-FY21-032021-010377-B	<1
WS- 010399	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3012 Low Right	WF-05182020-010399	4/3/2021	FT-FY21-032021-010399-A	<1	FT-FY21-032021-010399-B	<1
WS- 010400	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3012 High Left	WF-05182020-010400	4/3/2021	FT-FY21-032021-010400-A	<1	FT-FY21-032021-010400-B	<1
WS- 010910	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3026 High Left	WF-05182020-010910	4/3/2021	FT-FY21-032021-010910-A	<1	FT-FY21-032021-010910-B	<1
WS- 010911	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3026 Low Right	WF-05182020-010911	4/3/2021	FT-FY21-032021-010911-A	<1	FT-FY21-032021-010911-B	<1
WS- 010912	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to gym 3210 High Left	WF-05182020-010912	4/3/2021	FT-FY21-032021-010912-A	<1	FT-FY21-032021-010912-B	<1
WS- 010913	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to gym 3210 Low Right	WF-05182020-010913	4/3/2021	FT-FY21-032021-010913-A	<1	FT-FY21-032021-010913-B	<1
WS- 010914	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to gym 3210 High Left	WF-05182020-010914	4/3/2021	FT-FY21-032021-010914-A	<1	FT-FY21-032021-010914-B	<1
WS- 010915	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to gym 3210 Low Right	WF-05182020-010915	4/3/2021	FT-FY21-032021-010915-A	<1	FT-FY21-032021-010915-B	<1
WS- 010916	5/18/2020	5/18/2021	3	Cooler	In gym 3210 Low Right	WF-05182020-010916	4/3/2021	FT-FY21-032021-010916-A	<1	FT-FY21-032021-010916-B	<1
WS- 010917	5/18/2020	5/18/2021	3	Cooler	In gym 3210 High Left	WF-05182020-010917	4/3/2021	FT-FY21-032021-010917-A	<1	FT-FY21-032021-010917-B	<1
WS- 010959	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3200 High Left	WF-05182020-010959	4/3/2021	FT-FY21-032021-010959-A	<1	FT-FY21-032021-010959-B	<1
WS- 010960	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3200 Low Right	WF-05182020-010960	4/3/2021	FT-FY21-032021-010960-A	<1	FT-FY21-032021-010960-B	<1
WS- 010961	5/18/2020	5/18/2021	3	Cooler	In fitness room 3215 High Left	WF-05182020-010961	4/3/2021	FT-FY21-032021-010961-A	<1	FT-FY21-032021-010961-B	<1
WS- 010962	5/18/2020	5/18/2021	3	Cooler	In fitness room 3215 Low Right	WF-05182020-010962	4/3/2021	FT-FY21-032021-010962-A	<1	FT-FY21-032021-010962-B	<1
WS- 010963	5/18/2020	5/18/2021	3	Cooler	In fitness room 3215 High Left	WF-05182020-010963	4/3/2021	FT-FY21-032021-010963-A	<1	FT-FY21-032021-010963-B	<1
WS- 010964	5/18/2020	5/18/2021	3	Cooler	In fitness room 3215 Low Right	WF-05182020-010964	4/3/2021	FT-FY21-032021-010964-A	<1	FT-FY21-032021-010964-B	<1
WS- 011299	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1012 High Left	WF-05182020-011299	4/3/2021	FT-FY21-032021-011299-A	<1	FT-FY21-032021-011299-B	<1
WS- 011300	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1012 Low Right	WF-05182020-011300	4/3/2021	FT-FY21-032021-011300-A	<1	FT-FY21-032021-011300-B	<1
WS- 011309	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1026 High Left	WF-05182020-011309	4/3/2021	FT-FY21-032021-011309-A	<1	FT-FY21-032021-011309-B	<1
WS- 011310	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1026 Low Right	WF-05182020-011310	4/3/2021	FT-FY21-032021-011310-A	<1	FT-FY21-032021-011310-B	<1
WS- 011327	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1204 High Left	WF-05182020-011327	4/3/2021	FT-FY21-032021-011327-A	<1	FT-FY21-032021-011327-B	<1
WS- 011328	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1204 Low Right	WF-05182020-011328	4/3/2021	FT-FY21-032021-011328-A	<1	FT-FY21-032021-011328-B	<1
WS- 011329	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1402 High Left	WF-05182020-011329	4/3/2021	FT-FY21-032021-011329-A	<1	FT-FY21-032021-011329-B	<1
WS- 011330	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1402 Low Right	WF-05182020-011330	4/3/2021	FT-FY21-032021-011330-A	<1	FT-FY21-032021-011330-B	<1
WS- 011338	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1306 High Left	WF-05182020-011338	4/3/2021	FT-FY21-032021-011338-A	<1	FT-FY21-032021-011338-B	<1
WS- 011339	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to room 1306 Low Right	WF-05182020-011339	4/3/2021	FT-FY21-032021-011339-A	<1	FT-FY21-032021-011339-B	<1
WS- 011340	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to auditorium 1600 Low Right	WF-05182020-011340	4/3/2021	FT-FY21-032021-011340-A	<1	FT-FY21-032021-011340-B	<1
WS- 011341	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to auditorium 1600 High Left	WF-05182020-011341	4/3/2021	FT-FY21-032021-011341-A	<1	FT-FY21-032021-011341-B	<1
WS- 011342	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to dressing room 1612 High Left	WF-05182020-011342	4/3/2021	FT-FY21-032021-011342-A	<1	FT-FY21-032021-011342-B	<1

WS-011343	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to dressing room 1612	Low	Right	WF-05182020-011343	4/3/2021	FT-FY21-032021-011343-A	<1	FT-FY21-032021-011343-B	<1
WS-011344	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to day care room 1630	High	Left	WF-05182020-011344	4/3/2021	FT-FY21-032021-011344-A	<1	FT-FY21-032021-011344-B	<1
WS-011345	5/18/2020	5/18/2021	1	Cooler	In hallway adjacent to day care room 1630	Low	Right	WF-05182020-011345	4/3/2021	FT-FY21-032021-011345-A	<1	FT-FY21-032021-011345-B	<1
WS-011346	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 1630		Right	WF-10062020-011346	4/3/2021	FT-FY21-032021-011346-A	<1	FT-FY21-032021-011346-B	<1
WS-011347	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 1630			WF-10062020-011347	4/3/2021	FT-FY21-032021-011347-A	<1	FT-FY21-032021-011347-B	<1
WS-011349	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 1630			WF-10062020-011349	4/3/2021	FT-FY21-032021-011349-A	<1	FT-FY21-032021-011349-B	<1
WS-011357	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to school store room 2350	High	Left	WF-05182020-011357	4/3/2021	FT-FY21-032021-011357-A	<1	FT-FY21-032021-011357-B	<1
WS-011358	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to school store room 2350	Low	Right	WF-05182020-011358	4/3/2021	FT-FY21-032021-011358-A	<1	FT-FY21-032021-011358-B	<1
WS-011368	5/18/2020	5/18/2021	2	Ice Maker	In kitchen room 2503 (ice maker)		Left	WF-05182020-011368	4/3/2021	FT-FY21-032021-011368-A	<1	FT-FY21-032021-011368-B	<1
WS-011377	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2503	Low	Right	WF-05182020-011377	4/3/2021	FT-FY21-032021-011377-A	<1	FT-FY21-032021-011377-B	<1
WS-011378	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2623	Low	Right	WF-05182020-011378	4/3/2021	FT-FY21-032021-011378-A	<1	FT-FY21-032021-011378-B	<1
WS-011379	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2623	High	Left	WF-05182020-011379	4/3/2021	FT-FY21-032021-011379-A	<1	FT-FY21-032021-011379-B	<1
WS-011384	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2012	High	Left	WF-05182020-011384	4/3/2021	FT-FY21-032021-011384-A	<1	FT-FY21-032021-011384-B	<1
WS-011385	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2012	Low	Right	WF-05182020-011385	4/3/2021	FT-FY21-032021-011385-A	<1	FT-FY21-032021-011385-B	<1
WS-011386	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2503	High	Left	WF-05182020-011386	4/3/2021	FT-FY21-032021-011386-A	<1	FT-FY21-032021-011386-B	<1
WS-011399	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2026	High	Left	WF-05182020-011399	4/3/2021	FT-FY21-032021-011399-A	<1	FT-FY21-032021-011399-B	<1
WS-011400	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2026	Low	Right	WF-05182020-011400	4/3/2021	FT-FY21-032021-011400-A	<1	FT-FY21-032021-011400-B	<1
WS-011414	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2201	High	Left	WF-05182020-011414	4/3/2021	FT-FY21-032021-011414-A	<1	FT-FY21-032021-011414-B	<1
WS-011415	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2201	Low	Right	WF-05182020-011415	4/3/2021	FT-FY21-032021-011415-A	<1	FT-FY21-032021-011415-B	<1
WS-011416	5/18/2020	5/18/2021	2	Cooler	In pool area left of pool	High	Left	WF-05182020-011416	4/3/2021	FT-FY21-032021-011416-A	<1	FT-FY21-032021-011416-B	<1
WS-011417	5/18/2020	5/18/2021	2	Cooler	In pool area left of pool	Low	Right	WF-05182020-011417	4/3/2021	FT-FY21-032021-011417-A	<1	FT-FY21-032021-011417-B	<1
WS-011418	5/18/2020	5/18/2021	2	Cooler	In pool area right of pool	High	Left	WF-05182020-011418	4/3/2021	FT-FY21-032021-011418-A	<1	FT-FY21-032021-011418-B	<1
WS-011419	5/18/2020	5/18/2021	2	Cooler	In pool area right of pool	Low	Right	WF-05182020-011419	4/3/2021	FT-FY21-032021-011419-A	<1	FT-FY21-032021-011419-B	<1
WS-011421	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2205	High	Left	WF-05182020-011421	4/3/2021	FT-FY21-032021-011421-A	<1	FT-FY21-032021-011421-B	<1
WS-011422	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2205	Low	Right	WF-05182020-011422	4/3/2021	FT-FY21-032021-011422-A	<1	FT-FY21-032021-011422-B	<1
WS-011426	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to stairwell 6	High	Left	WF-05182020-011426	4/3/2021	FT-FY21-032021-011426-A	<1	FT-FY21-032021-011426-B	<1
WS-011427	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to stairwell 6	Low	Right	WF-05182020-011427	4/3/2021	FT-FY21-032021-011427-A	<1	FT-FY21-032021-011427-B	<1
WS-011432	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2320	High	Left	WF-05182020-011432	4/3/2021	FT-FY21-032021-011432-A	<1	FT-FY21-032021-011432-B	<1
WS-011434	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2320	Low	Right	WF-05182020-011434	4/3/2021	FT-FY21-032021-011434-A	<1	FT-FY21-032021-011434-B	<1
WS-011435	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2200	High	Right	WF-05182020-011435	4/3/2021	FT-FY21-032021-011435-A	<1	FT-FY21-032021-011435-B	<1
WS-011436	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to room 2200	Low	Right	WF-05182020-011436	4/3/2021	FT-FY21-032021-011436-A	<1	FT-FY21-032021-011436-B	<1
WS-011437	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to football locker room	High	Left	WF-05182020-011437	4/3/2021	FT-FY21-032021-011437-A	<1	FT-FY21-032021-011437-B	<1
WS-011438	5/18/2020	5/18/2021	2	Cooler	In hallway adjacent to football locker room	Low	Right	WF-05182020-011438	4/3/2021	FT-FY21-032021-011438-A	<1	FT-FY21-032021-011438-B	<1
WS-011439	5/18/2020	5/18/2021	2	Health Suite	In health suite in break room 2322			WF-05182020-011439	4/3/2021	FT-FY21-032021-011439-A	<1	FT-FY21-032021-011439-B	<1
WS-011440	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2317			WF-05182020-011440	4/3/2021	FT-FY21-032021-011440-A	<1	FT-FY21-032021-011440-B	<1
WS-011441	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2316			WF-05182020-011441	4/3/2021	FT-FY21-032021-011441-A	<1	FT-FY21-032021-011441-B	<1
WS-011442	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2315			WF-05182020-011442	4/3/2021	FT-FY21-032021-011442-A	<1	FT-FY21-032021-011442-B	<1
WS-011443	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2313			WF-05182020-011443	4/3/2021	FT-FY21-032021-011443-A	<1	FT-FY21-032021-011443-B	<1
WS-011444	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2321			WF-05182020-011444	4/3/2021	FT-FY21-032021-011444-A	<1	FT-FY21-032021-011444-B	<1
WS-011445	5/18/2020	5/18/2021	2	Health Suite	In health suite in exam room 2309			WF-05182020-011445	4/3/2021	FT-FY21-032021-011445-A	<1	FT-FY21-032021-011445-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011363	1/29/2021	1/29/2022	2	Food Prep Sink	In kitchen room 2503 on north wall	Left	WF-01292021-011363	4/3/2021	FT-FY21-032021-011363-A	<1	FT-FY21-032021-011363-B	<1
WS- 011364	1/29/2021	1/29/2022	2	Food Prep Sink	In kitchen room 2503 on north wall		WF-01292021-011364	4/3/2021	FT-FY21-032021-011364-A	<1	FT-FY21-032021-011364-B	<1
WS- 011366	1/29/2021	1/29/2022	2	Food Prep Sink	In kitchen room 2503 on east wall		WF-01292021-011366	4/3/2021	FT-FY21-032021-011366-A	<1	FT-FY21-032021-011366-B	<1
WS- 011369	1/29/2021	1/29/2022	2	Food Prep Sink	In kitchen room 2503 on island	Mid	WF-01292021-011369	4/3/2021	FT-FY21-032021-011369-A	<1	FT-FY21-032021-011369-B	<1