



Ballou High School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010370	4/19/2021	4/19/2022	3	Break Room	In staff break room 3304	WF-04192021-010370	3/17/2022	FT-FY22-02212022-010370-A	<1	FT-FY22-02212022-010370-B	<1
WS- 010374	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to auditorium High Left	WF-04192021-010374	3/17/2022	FT-FY22-02212022-010374-A	<1	FT-FY22-02212022-010374-B	<1
WS- 010375	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to auditorium Low Right	WF-04192021-010375	3/17/2022	FT-FY22-02212022-010375-A	<1	FT-FY22-02212022-010375-B	<1
WS- 010399	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3012 Low Right	WF-04192021-010399	3/17/2022	FT-FY22-02212022-010399-A	<1	FT-FY22-02212022-010399-B	<1
WS- 010400	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3012 High Left	WF-04192021-010400	3/17/2022	FT-FY22-02212022-010400-A	<1	FT-FY22-02212022-010400-B	<1
WS- 010910	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3026 High Left	WF-04192021-010910	3/17/2022	FT-FY22-02212022-010910-A	<1	FT-FY22-02212022-010910-B	<1
WS- 010911	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3026 Low Right	WF-04192021-010911	3/17/2022	FT-FY22-02212022-010911-A	<1	FT-FY22-02212022-010911-B	<1
WS- 010959	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3200 High Left	WF-04192021-010959	3/17/2022	FT-FY22-02212022-010959-A	<1	FT-FY22-02212022-010959-B	<1
WS- 010960	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 3200 Low Right	WF-04192021-010960	3/17/2022	FT-FY22-02212022-010960-A	<1	FT-FY22-02212022-010960-B	<1
WS- 011299	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1012 High Left	WF-04192021-011299	3/17/2022	FT-FY22-02212022-011299-A	<1	FT-FY22-02212022-011299-B	<1
WS- 011300	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1012 Low Right	WF-04192021-011300	3/17/2022	FT-FY22-02212022-011300-A	<1	FT-FY22-02212022-011300-B	<1
WS- 011309	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1026 High Left	WF-04192021-011309	3/17/2022	FT-FY22-02212022-011309-A	<1	FT-FY22-02212022-011309-B	<1
WS- 011310	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1026 Low Right	WF-04192021-011310	3/17/2022	FT-FY22-02212022-011310-A	<1	FT-FY22-02212022-011310-B	<1
WS- 011327	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1204 High Left	WF-04192021-011327	3/17/2022	FT-FY22-02212022-011327-A	<1	FT-FY22-02212022-011327-B	<1
WS- 011328	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1204 Low Right	WF-04192021-011328	3/17/2022	FT-FY22-02212022-011328-A	<1	FT-FY22-02212022-011328-B	<1
WS- 011329	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1402 High Left	WF-04192021-011329	3/17/2022	FT-FY22-02212022-011329-A	<1	FT-FY22-02212022-011329-B	<1
WS- 011330	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1402 Low Right	WF-04192021-011330	3/17/2022	FT-FY22-02212022-011330-A	<1	FT-FY22-02212022-011330-B	<1
WS- 011338	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1306 High Left	WF-04192021-011338	3/17/2022	FT-FY22-02212022-011338-A	<1	FT-FY22-02212022-011338-B	<1
WS- 011339	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 1306 Low Right	WF-04192021-011339	3/17/2022	FT-FY22-02212022-011339-A	<1	FT-FY22-02212022-011339-B	<1
WS- 011340	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to auditorium 1600 Low Right	WF-04192021-011340	3/17/2022	FT-FY22-02212022-011340-A	<1	FT-FY22-02212022-011340-B	<1
WS- 011341	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to auditorium 1600 High Left	WF-04192021-011341	3/17/2022	FT-FY22-02212022-011341-A	<1	FT-FY22-02212022-011341-B	<1
WS- 011344	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to day care room 1630 High Left	WF-04192021-011344	3/17/2022	FT-FY22-02212022-011344-A	<1	FT-FY22-02212022-011344-B	<1
WS- 011345	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to day care room 1630 Low Right	WF-04192021-011345	3/17/2022	FT-FY22-02212022-011345-A	<1	FT-FY22-02212022-011345-B	<1
WS- 011346	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 1630 Right	WF-09272021-011346	3/17/2022	FT-FY22-02212022-011346-A	<1	FT-FY22-02212022-011346-B	<1
WS- 011347	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 1630	WF-09272021-011347	3/17/2022	FT-FY22-02212022-011347-A	<1	FT-FY22-02212022-011347-B	<1
WS- 011349	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 1630	WF-09272021-011349	3/17/2022	FT-FY22-02212022-011349-A	<1	FT-FY22-02212022-011349-B	<1
WS- 011368	4/19/2021	4/19/2022	2	Ice Maker	In kitchen room 2503 (ice maker) Left	WF-04192021-011368	3/17/2022	FT-FY22-02212022-011368-A	<1	FT-FY22-02212022-011368-B	<1
WS- 011377	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2503 Low Right	WF-04192021-011377	3/17/2022	FT-FY22-02212022-011377-A	<1	FT-FY22-02212022-011377-B	<1
WS- 011378	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2623 Low Right	WF-04192021-011378	3/17/2022	FT-FY22-02212022-011378-A	<1	FT-FY22-02212022-011378-B	<1
WS- 011379	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2623 High Left	WF-04192021-011379	3/17/2022	FT-FY22-02212022-011379-A	<1	FT-FY22-02212022-011379-B	<1
WS- 011384	4/19/2021	4/19/2022	2	Cooler	In hallway across from room 2012 High Left	WF-04192021-011384	3/17/2022	FT-FY22-02212022-011384-A	<1	FT-FY22-02212022-011384-B	<1
WS- 011385	4/19/2021	4/19/2022	2	Cooler	In hallway across from room 2012 Low Right	WF-04192021-011385	3/17/2022	FT-FY22-02212022-011385-A	<1	FT-FY22-02212022-011385-B	<1
WS- 011386	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2503 High Left	WF-04192021-011386	3/17/2022	FT-FY22-02212022-011386-A	<1	FT-FY22-02212022-011386-B	<1
WS- 011399	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2026 High Left	WF-04192021-011399	3/17/2022	FT-FY22-02212022-011399-A	<1	FT-FY22-02212022-011399-B	<1
WS- 011400	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2026 Low Right	WF-04192021-011400	3/17/2022	FT-FY22-02212022-011400-A	<1	FT-FY22-02212022-011400-B	<1

WS- 011414	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2201	High	Left	WF-04192021-011414	3/17/2022	FT-FY22-02212022-011414-A	<1	FT-FY22-02212022-011414-B	<1
WS- 011415	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2201	Low	Right	WF-04192021-011415	3/17/2022	FT-FY22-02212022-011415-A	<1	FT-FY22-02212022-011415-B	<1
WS- 011421	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2205	High	Left	WF-04192021-011421	3/17/2022	FT-FY22-02212022-011421-A	<1	FT-FY22-02212022-011421-B	<1
WS- 011422	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2205	Low	Right	WF-04192021-011422	3/17/2022	FT-FY22-02212022-011422-A	<1	FT-FY22-02212022-011422-B	<1
WS- 011426	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to stairwell 6	High	Left	WF-04192021-011426	3/17/2022	FT-FY22-02212022-011426-A	<1	FT-FY22-02212022-011426-B	<1
WS- 011427	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to stairwell 6	Low	Right	WF-04192021-011427	3/17/2022	FT-FY22-02212022-011427-A	<1	FT-FY22-02212022-011427-B	<1
WS- 011435	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2200	High	Right	WF-04192021-011435	3/17/2022	FT-FY22-02212022-011435-A	<1	FT-FY22-02212022-011435-B	<1
WS- 011436	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to room 2200	Low	Right	WF-04192021-011436	3/17/2022	FT-FY22-02212022-011436-A	<1	FT-FY22-02212022-011436-B	<1
WS- 011439	4/19/2021	4/19/2022	2	Health Suite	In health suite in break room 2322			WF-04192021-011439	3/17/2022	FT-FY22-02212022-011439-A	<1	FT-FY22-02212022-011439-B	<1
WS- 011440	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2317			WF-04192021-011440	3/17/2022	FT-FY22-02212022-011440-A	<1	FT-FY22-02212022-011440-B	<1
WS- 011441	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2316			WF-04192021-011441	3/17/2022	FT-FY22-02212022-011441-A	<1	FT-FY22-02212022-011441-B	<1
WS- 011442	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2315			WF-04192021-011442	3/17/2022	FT-FY22-02212022-011442-A	<1	FT-FY22-02212022-011442-B	<1
WS- 011443	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2313			WF-04192021-011443	3/17/2022	FT-FY22-02212022-011443-A	<1	FT-FY22-02212022-011443-B	<1
WS- 011444	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2321			WF-04192021-011444	3/17/2022	FT-FY22-02212022-011444-A	<1	FT-FY22-02212022-011444-B	<1
WS- 011445	4/19/2021	4/19/2022	2	Health Suite	In health suite in exam room 2309			WF-04192021-011445	3/17/2022	FT-FY22-02212022-011445-A	<1	FT-FY22-02212022-011445-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011363	1/18/2022	1/18/2023	2	Food Prep Sink	In kitchen room 2503 on north wall	Left	WF-01182022-011363	3/17/2022	FT-FY22-02212022-011363-A	<1	FT-FY22-02212022-011363-B	<1
WS- 011364	1/18/2022	1/18/2023	2	Food Prep Sink	In kitchen room 2503 on north wall		WF-01182022-011364	3/17/2022	FT-FY22-02212022-011364-A	<1	FT-FY22-02212022-011364-B	<1
WS- 011366	1/18/2022	1/18/2023	2	Food Prep Sink	In kitchen room 2503 on east wall		WF-01182022-011366	3/17/2022	FT-FY22-02212022-011366-A	1.8	FT-FY22-02212022-011366-B	<1
WS- 011369	1/18/2022	1/18/2023	2	Food Prep Sink	In kitchen room 2503 on island	Mid	WF-01182022-011369	3/17/2022	FT-FY22-02212022-011369-A	<1	FT-FY22-02212022-011369-B	<1