



Ballou HS Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010370	3/19/2025	3/19/2026	3	Break Room	In staff break room 3304	WF-03192025-010370	10/28/2025	FT-FY26-09302025-010370-A	<2	FT-FY26-09302025-010370-B	<2
WS- 010374	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to auditorium High Left	WF-03192025-010374	10/28/2025	FT-FY26-09302025-010374-A	<2	FT-FY26-09302025-010374-B	<2
WS- 010375	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to auditorium Low Right	WF-03192025-010375	10/28/2025	FT-FY26-09302025-010375-A	<2	FT-FY26-09302025-010375-B	<2
WS- 010399	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to room 3012 Low Right	WF-03192025-010399	10/28/2025	FT-FY26-09302025-010399-A	<2	FT-FY26-09302025-010399-B	<2
WS- 010400	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to room 3012 High Left	WF-03192025-010400	10/28/2025	FT-FY26-09302025-010400-A	<2	FT-FY26-09302025-010400-B	<2
WS- 010910	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to room 3026 High Left	WF-03192025-010910	10/28/2025	FT-FY26-09302025-010910-A	<2	FT-FY26-09302025-010910-B	<2
WS- 010911	3/19/2025	3/19/2026	3	Cooler	In hallway adjacent to room 3026 Low Right	WF-03192025-010911	10/28/2025	FT-FY26-09302025-010911-A	<2	FT-FY26-09302025-010911-B	<2
WS- 011299	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1012 High Left	WF-03192025-011299	10/28/2025	FT-FY26-09302025-011299-A	<2	FT-FY26-09302025-011299-B	<2
WS- 011300	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1012 Low Right	WF-03192025-011300	10/28/2025	FT-FY26-09302025-011300-A	<2	FT-FY26-09302025-011300-B	<2
WS- 011309	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1026 High Left	WF-03192025-011309	10/28/2025	FT-FY26-09302025-011309-A	<2	FT-FY26-09302025-011309-B	<2
WS- 011310	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1026 Low Right	WF-03192025-011310	10/28/2025	FT-FY26-09302025-011310-A	<2	FT-FY26-09302025-011310-B	<2
WS- 011327	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1204 High Left	WF-03192025-011327	10/28/2025	FT-FY26-09302025-011327-A	<2	FT-FY26-09302025-011327-B	<2
WS- 011328	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1204 Low Right	WF-03192025-011328	10/28/2025	FT-FY26-09302025-011328-A	<2	FT-FY26-09302025-011328-B	<2
WS- 011329	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1402 High Left	WF-03192025-011329	10/28/2025	FT-FY26-09302025-011329-A	<2	FT-FY26-09302025-011329-B	<2
WS- 011330	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1402 Low Right	WF-03192025-011330	10/28/2025	FT-FY26-09302025-011330-A	<2	FT-FY26-09302025-011330-B	<2
WS- 011338	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1306 High Left	WF-03192025-011338	10/28/2025	FT-FY26-09302025-011338-A	<2	FT-FY26-09302025-011338-B	<2
WS- 011339	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to room 1306 Low Right	WF-03192025-011339	10/28/2025	FT-FY26-09302025-011339-A	<2	FT-FY26-09302025-011339-B	<2
WS- 011340	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to auditorium 1600 Low Right	WF-03192025-011340	10/28/2025	FT-FY26-09302025-011340-A	<2	FT-FY26-09302025-011340-B	<2
WS- 011341	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to auditorium 1600 High Left	WF-03192025-011341	10/28/2025	FT-FY26-09302025-011341-A	<2	FT-FY26-09302025-011341-B	<2
WS- 011344	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to day care room 1630 High Left	WF-03192025-011344	10/28/2025	FT-FY26-09302025-011344-A	<2	FT-FY26-09302025-011344-B	<2
WS- 011345	3/19/2025	3/19/2026	1	Cooler	In hallway adjacent to day care room 1630 Low Right	WF-03192025-011345	10/28/2025	FT-FY26-09302025-011345-A	<2	FT-FY26-09302025-011345-B	<2
WS- 011346	8/25/2025	8/25/2026	1	Classroom Faucet	In day care room 1630 Right	WF-08252025-011346	10/28/2025	FT-FY26-09302025-011346-A	<2	FT-FY26-09302025-011346-B	<2
WS- 011347	8/25/2025	8/25/2026	1	Classroom Faucet	In day care room 1630	WF-08252025-011347	10/28/2025	FT-FY26-09302025-011347-A	<2	FT-FY26-09302025-011347-B	<2
WS- 011349	8/25/2025	8/25/2026	1	Classroom Faucet	In day care room 1630	WF-08252025-011349	10/28/2025	FT-FY26-09302025-011349-A	<2	FT-FY26-09302025-011349-B	<2
WS- 011368	3/19/2025	3/19/2026	2	Ice Maker	In kitchen room 2503 (ice maker) Left	WF-03192025-011368	10/28/2025	FT-FY26-09302025-011368-A	<2	FT-FY26-09302025-011368-B	<2
WS- 011377	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2503 Low Right	WF-03192025-011377	10/28/2025	FT-FY26-09302025-011377-A	<2	FT-FY26-09302025-011377-B	<2
WS- 011378	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2623 Low Right	WF-03192025-011378	10/28/2025	FT-FY26-09302025-011378-A	<2	FT-FY26-09302025-011378-B	<2
WS- 011379	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2623 High Left	WF-03192025-011379	10/28/2025	FT-FY26-09302025-011379-A	<2	FT-FY26-09302025-011379-B	<2
WS- 011384	3/19/2025	3/19/2026	2	Cooler	In hallway across from room 2012 High Left	WF-03192025-011384	10/28/2025	FT-FY26-09302025-011384-A	<2	FT-FY26-09302025-011384-B	<2
WS- 011386	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2503 High Left	WF-03192025-011386	10/28/2025	FT-FY26-09302025-011386-A	<2	FT-FY26-09302025-011386-B	<2
WS- 011399	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2026 High Left	WF-03192025-011399	10/28/2025	FT-FY26-09302025-011399-A	<2	FT-FY26-09302025-011399-B	<2
WS- 011400	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2026 Low Right	WF-03192025-011400	10/28/2025	FT-FY26-09302025-011400-A	<2	FT-FY26-09302025-011400-B	<2
WS- 011414	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2201 High Left	WF-03192025-011414	10/28/2025	FT-FY26-09302025-011414-A	<2	FT-FY26-09302025-011414-B	<2
WS- 011415	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2201 Low Right	WF-03192025-011415	10/28/2025	FT-FY26-09302025-011415-A	<2	FT-FY26-09302025-011415-B	<2

WS- 011416	3/19/2025	3/19/2026	2	Cooler	In pool area left of pool	High Left	WF-03192025-011416	10/28/2025	FT-FY26-09302025-011416-A	<2	FT-FY26-09302025-011416-B	<2
WS- 011417	3/19/2025	3/19/2026	2	Cooler	In pool area left of pool	Low Right	WF-03192025-011417	10/28/2025	FT-FY26-09302025-011417-A	<2	FT-FY26-09302025-011417-B	<2
WS- 011418	3/19/2025	3/19/2026	2	Cooler	In pool area right of pool	High Left	WF-03192025-011418	10/28/2025	FT-FY26-09302025-011418-A	<2	FT-FY26-09302025-011418-B	<2
WS- 011419	3/19/2025	3/19/2026	2	Cooler	In pool area right of pool	Low Right	WF-03192025-011419	10/28/2025	FT-FY26-09302025-011419-A	<2	FT-FY26-09302025-011419-B	<2
WS- 011421	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2205	High Left	WF-03192025-011421	10/28/2025	FT-FY26-09302025-011421-A	<2	FT-FY26-09302025-011421-B	<2
WS- 011422	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to room 2205	Low Right	WF-03192025-011422	10/28/2025	FT-FY26-09302025-011422-A	<2	FT-FY26-09302025-011422-B	<2
WS- 011426	3/19/2025	3/19/2026	2	Cooler	In hallway adjacent to stairwell 6	High Left	WF-03192025-011426	10/28/2025	FT-FY26-09302025-011426-A	<2	FT-FY26-09302025-011426-B	<2
WS- 011439	3/19/2025	3/19/2026	2	Health Suite	In health suite in break room 2322		WF-03192025-011439	10/28/2025	FT-FY26-09302025-011439-A	<2	FT-FY26-09302025-011439-B	<2
WS- 011440	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2317		WF-03192025-011440	10/28/2025	FT-FY26-09302025-011440-A	2.2	FT-FY26-09302025-011440-B	<2
WS- 011441	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2316		WF-03192025-011441	10/28/2025	FT-FY26-09302025-011441-A	<2	FT-FY26-09302025-011441-B	<2
WS- 011442	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2315		WF-03192025-011442	10/28/2025	FT-FY26-09302025-011442-A	<2	FT-FY26-09302025-011442-B	<2
WS- 011443	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2313		WF-03192025-011443	10/28/2025	FT-FY26-09302025-011443-A	<2	FT-FY26-09302025-011443-B	<2
WS- 011444	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2321		WF-03192025-011444	10/28/2025	FT-FY26-09302025-011444-A	<2	FT-FY26-09302025-011444-B	<2
WS- 011445	3/19/2025	3/19/2026	2	Health Suite	In health suite in exam room 2309		WF-03192025-011445	10/28/2025	FT-FY26-09302025-011445-A	<2	FT-FY26-09302025-011445-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011363	11/18/2024	11/18/2025	2	Food Prep Sink	In kitchen room 2503 on north wall	Left	WF-11182024-011363	10/28/2025	FT-FY26-09302025-011363-A	<2	FT-FY26-09302025-011363-B	<2
WS- 011364	11/18/2024	11/18/2025	2	Food Prep Sink	In kitchen room 2503 on north wall		WF-11182024-011364	10/28/2025	FT-FY26-09302025-011364-A	<2	FT-FY26-09302025-011364-B	<2
WS- 011369	11/18/2024	11/18/2025	2	Food Prep Sink	In kitchen room 2503 on island	Mid	WF-11182024-011369	10/28/2025	FT-FY26-09302025-011369-A	<2	FT-FY26-09302025-011369-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.