



Ballou High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010370	4/5/2023	4/5/2024	3	Break Room	In staff break room 3304	WF-04052023-010370	10/22/2023	FT-FY24-09282023-010370-A	<1	FT-FY24-09282023-010370-B	<1	
WS- 010399	4/5/2023	4/5/2024	3	Cooler	In hallway adjacent to room 3012	Low Right	WF-04052023-010399	10/22/2023	FT-FY24-09282023-010399-A	<1	FT-FY24-09282023-010399-B	<1
WS- 010400	4/5/2023	4/5/2024	3	Cooler	In hallway adjacent to room 3012	High Left	WF-04052023-010400	10/22/2023	FT-FY24-09282023-010400-A	<1	FT-FY24-09282023-010400-B	<1
WS- 010959	4/5/2023	4/5/2024	3	Cooler	In hallway adjacent to room 3200	High Left	WF-04052023-010959	10/22/2023	FT-FY24-09282023-010959-A	<1	FT-FY24-09282023-010959-B	<1
WS- 010960	4/5/2023	4/5/2024	3	Cooler	In hallway adjacent to room 3200	Low Right	WF-04052023-010960	10/22/2023	FT-FY24-09282023-010960-A	<1	FT-FY24-09282023-010960-B	<1
WS- 011299	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1012	High Left	WF-04052023-011299	10/22/2023	FT-FY24-09282023-011299-A	1.4	FT-FY24-09282023-011299-B	<1
WS- 011300	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1012	Low Right	WF-04052023-011300	10/22/2023	FT-FY24-09282023-011300-A	<1	FT-FY24-09282023-011300-B	<1
WS- 011309	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1026	High Left	WF-04052023-011309	10/22/2023	FT-FY24-09282023-011309-A	<1	FT-FY24-09282023-011309-B	<1
WS- 011310	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1026	Low Right	WF-04052023-011310	10/22/2023	FT-FY24-09282023-011310-A	<1	FT-FY24-09282023-011310-B	<1
WS- 011327	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1204	High Left	WF-04052023-011327	10/22/2023	FT-FY24-09282023-011327-A	<1	FT-FY24-09282023-011327-B	<1
WS- 011328	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1204	Low Right	WF-04052023-011328	10/22/2023	FT-FY24-09282023-011328-A	<1	FT-FY24-09282023-011328-B	<1
WS- 011329	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1402	High Left	WF-04052023-011329	10/22/2023	FT-FY24-09282023-011329-A	<1	FT-FY24-09282023-011329-B	<1
WS- 011330	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1402	Low Right	WF-04052023-011330	10/22/2023	FT-FY24-09282023-011330-A	<1	FT-FY24-09282023-011330-B	<1
WS- 011338	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1306	High Left	WF-04052023-011338	10/22/2023	FT-FY24-09282023-011338-A	<1	FT-FY24-09282023-011338-B	<1
WS- 011339	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to room 1306	Low Right	WF-04052023-011339	10/22/2023	FT-FY24-09282023-011339-A	<1	FT-FY24-09282023-011339-B	<1
WS- 011344	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to day care room 1630	High Left	WF-04052023-011344	10/22/2023	FT-FY24-09282023-011344-A	<1	FT-FY24-09282023-011344-B	<1
WS- 011345	4/5/2023	4/5/2024	1	Cooler	In hallway adjacent to day care room 1630	Low Right	WF-04052023-011345	10/22/2023	FT-FY24-09282023-011345-A	<1	FT-FY24-09282023-011345-B	<1
WS- 011346	9/5/2023	9/5/2024	1	Classroom Faucet	In day care room 1630	Right	WF-09052023-011346	10/22/2023	FT-FY24-09282023-011346-A	1.6	FT-FY24-09282023-011346-B	<1
WS- 011347	9/5/2023	9/5/2024	1	Classroom Faucet	In day care room 1630		WF-09052023-011347	10/22/2023	FT-FY24-09282023-011347-A	4.4	FT-FY24-09282023-011347-B	<1
WS- 011349	9/5/2023	9/5/2024	1	Classroom Faucet	In day care room 1630		WF-09052023-011349	10/22/2023	FT-FY24-09282023-011349-A	<1	FT-FY24-09282023-011349-B	<1
WS- 011377	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2503	Low Right	WF-04052023-011377	10/22/2023	FT-FY24-09282023-011377-A	<1	FT-FY24-09282023-011377-B	<1
WS- 011378	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2623	Low Right	WF-04052023-011378	10/22/2023	FT-FY24-09282023-011378-A	<1	FT-FY24-09282023-011378-B	<1
WS- 011379	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2623	High Left	WF-04052023-011379	10/22/2023	FT-FY24-09282023-011379-A	<1	FT-FY24-09282023-011379-B	<1
WS- 011384	4/5/2023	4/5/2024	2	Cooler	In hallway across from room 2012	High Left	WF-04052023-011384	10/22/2023	FT-FY24-09282023-011384-A	<1	FT-FY24-09282023-011384-B	<1
WS- 011386	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2503	High Left	WF-04052023-011386	10/22/2023	FT-FY24-09282023-011386-A	<1	FT-FY24-09282023-011386-B	<1
WS- 011399	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2026	High Left	WF-04052023-011399	10/22/2023	FT-FY24-09282023-011399-A	<1	FT-FY24-09282023-011399-B	<1
WS- 011400	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2026	Low Right	WF-04052023-011400	10/22/2023	FT-FY24-09282023-011400-A	<1	FT-FY24-09282023-011400-B	<1
WS- 011414	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2201	High Left	WF-04052023-011414	10/22/2023	FT-FY24-09282023-011414-A	<1	FT-FY24-09282023-011414-B	<1
WS- 011415	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2201	Low Right	WF-04052023-011415	10/22/2023	FT-FY24-09282023-011415-A	<1	FT-FY24-09282023-011415-B	<1
WS- 011416	4/5/2023	4/5/2024	2	Cooler	In pool area left of pool	High Left	WF-04052023-011416	10/22/2023	FT-FY24-09282023-011416-A	<1	FT-FY24-09282023-011416-B	<1
WS- 011417	4/5/2023	4/5/2024	2	Cooler	In pool area left of pool	Low Right	WF-04052023-011417	10/22/2023	FT-FY24-09282023-011417-A	<1	FT-FY24-09282023-011417-B	<1
WS- 011418	4/5/2023	4/5/2024	2	Cooler	In pool area right of pool	High Left	WF-04052023-011418	10/22/2023	FT-FY24-09282023-011418-A	<1	FT-FY24-09282023-011418-B	<1
WS- 011419	4/5/2023	4/5/2024	2	Cooler	In pool area right of pool	Low Right	WF-04052023-011419	10/22/2023	FT-FY24-09282023-011419-A	<1	FT-FY24-09282023-011419-B	<1
WS- 011421	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2205	High Left	WF-04052023-011421	10/22/2023	FT-FY24-09282023-011421-A	<1	FT-FY24-09282023-011421-B	<1
WS- 011422	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2205	Low Right	WF-04052023-011422	10/22/2023	FT-FY24-09282023-011422-A	<1	FT-FY24-09282023-011422-B	<1

WS- 011426	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to stairwell 6	High	Left	WF-04052023-011426	10/22/2023	FT-FY24-09282023-011426-A	<1	FT-FY24-09282023-011426-B	<1
WS- 011427	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to stairwell 6	Low	Right	WF-04052023-011427	10/22/2023	FT-FY24-09282023-011427-A	<1	FT-FY24-09282023-011427-B	<1
WS- 011435	4/5/2023	4/5/2024	2	Cooler	In hallway adjacent to room 2200	High	Right	WF-04052023-011435	10/22/2023	FT-FY24-09282023-011435-A	<1	FT-FY24-09282023-011435-B	<1
WS- 011439	4/5/2023	4/5/2024	2	Health Suite	In health suite in break room 2322			WF-04052023-011439	10/22/2023	FT-FY24-09282023-011439-A	<1	FT-FY24-09282023-011439-B	<1
WS- 011440	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2317			WF-04052023-011440	10/22/2023	FT-FY24-09282023-011440-A	2.0	FT-FY24-09282023-011440-B	<1
WS- 011441	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2316			WF-04052023-011441	10/22/2023	FT-FY24-09282023-011441-A	1.1	FT-FY24-09282023-011441-B	<1
WS- 011442	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2315			WF-04052023-011442	10/22/2023	FT-FY24-09282023-011442-A	<1	FT-FY24-09282023-011442-B	<1
WS- 011443	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2313			WF-04052023-011443	10/22/2023	FT-FY24-09282023-011443-A	1.4	FT-FY24-09282023-011443-B	<1
WS- 011444	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2321			WF-04052023-011444	10/22/2023	FT-FY24-09282023-011444-A	1.0	FT-FY24-09282023-011444-B	<1
WS- 011445	4/5/2023	4/5/2024	2	Health Suite	In health suite in exam room 2309			WF-04052023-011445	10/22/2023	FT-FY24-09282023-011445-A	<1	FT-FY24-09282023-011445-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011363	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on north wall	Left	WF-12292022-011363	10/22/2023	FT-FY24-09282023-011363-A	<1	FT-FY24-09282023-011363-B	<1
WS- 011364	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on north wall		WF-12292022-011364	10/22/2023	FT-FY24-09282023-011364-A	<1	FT-FY24-09282023-011364-B	<1
WS- 011366	12/29/2022	12/29/2023	2	Food Prep Sink	In kitchen room 2503 on east wall		WF-12292022-011366	10/22/2023	FT-FY24-09282023-011366-A	<1	FT-FY24-09282023-011366-B	<1