



BALLOU HS LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	BALLOU HIGH SCHOOL	WS- 010370	1/7/2017	3	Break Room	In staff break room 3304	FT-102016-010370-A	< 1	FT-102016-010370-B	< 1
2	BALLOU HIGH SCHOOL	WS- 011349	1/7/2017	1	Classroom Faucet	In day care room 1630	FT-112016-011349-A	< 1	FT-112016-011349-B	< 1
3	BALLOU HIGH SCHOOL	WS- 011346	1/7/2017	1	Classroom Faucet	In day care room 1630 Right	FT-112016-011346-A	< 1	FT-112016-011346-B	< 1
4	BALLOU HIGH SCHOOL	WS- 011347	1/7/2017	1	Classroom Faucet	In day care room 1630	FT-112016-011347-A	< 1	FT-112016-011347-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb