



# Ballou Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010377	6/22/17	6/22/18	3	Fountain	In hallway adjacent to room 3622	Right	Low	WF-62017-010377	12/20/17	FT-FY18-62017-010377-A	<1	FT-FY18-62017-010377-B	<1
WS-010914	6/22/17	6/22/18	3	Fountain	In hallway adjacent to gym 3210	Left	High	WF-62017-010914	12/20/17	FT-FY18-62017-010914-A	<1	FT-FY18-62017-010914-B	<1
WS-010916	6/22/17	6/22/18	3	Fountain	In the gym 3210	Right	Low	WF-62017-010916	12/20/17	FT-FY18-62017-010916-A	<1	FT-FY18-62017-010916-B	<1
WS-010917	6/22/17	6/22/18	3	Fountain	In gym 3210	Left	High	WF-62017-010917	12/20/17	FT-FY18-62017-010917-A	<1	FT-FY18-62017-010917-B	<1
WS-010962	6/22/17	6/22/18	3	Fountain	In fitness room 3215	Right	Low	WF-62017-010962	12/20/17	FT-FY18-62017-010962-A	<1	FT-FY18-62017-010962-B	<1
WS-010964	6/22/17	6/22/18	3	Fountain	In fitness room 3215	Right	Low	WF-62017-010964	12/20/17	FT-FY18-62017-010964-A	<1	FT-FY18-62017-010964-B	<1
WS-011310	6/22/17	6/22/18	1	Fountain	In hallway adjacent to room 1026	Right	Low	WF-62017-011310	12/20/17	FT-FY18-62017-011310-A	<1	FT-FY18-62017-011310-B	<1
WS-011327	6/22/17	6/22/18	1	Fountain	In hallway adjacent to room 1204	Left	High	WF-62017-011327	12/20/17	FT-FY18-62017-011327-A	<1	FT-FY18-62017-011327-B	<1
WS-011328	6/22/17	6/22/18	1	Fountain	In hallway adjacent to room 1204	Right	Low	WF-62017-011328	12/20/17	FT-FY18-62017-011328-A	<1	FT-FY18-62017-011328-B	<1
WS-011329	6/22/17	6/22/18	1	Fountain	In hallway adjacent to room 1402	Left	High	WF-62017-011329	12/20/17	FT-FY18-62017-011329-A	<1	FT-FY18-62017-011329-B	<1
WS-011330	6/22/17	6/22/18	1	Fountain	In hallway adjacent to room 1402	Right	Low	WF-62017-011330	12/20/17	FT-FY18-62017-011330-A	<1	FT-FY18-62017-011330-B	<1
WS-011340	6/22/17	6/22/18	1	Fountain	In hallway adjacent to auditorium 1600	Right	Low	WF-62017-011340	12/20/17	FT-FY18-62017-011340-A	<1	FT-FY18-62017-011340-B	<1
WS-011341	6/22/17	6/22/18	1	Fountain	In hallway adjacent to auditorium 1600	Right	High	WF-62017-011341	12/20/17	FT-FY18-62017-011341-A	<1	FT-FY18-62017-011341-B	<1
WS-011342	6/22/17	6/22/18	1	Fountain	In hallway adjacent to dressing room 1612	Left	High	WF-62017-011342	12/20/17	FT-FY18-62017-011342-A	<1	FT-FY18-62017-011342-B	<1
WS-011343	6/22/17	6/22/18	1	Fountain	In hallway adjacent to dressing room 1612	Right	Low	WF-62017-011343	12/20/17	FT-FY18-62017-011343-A	<1	FT-FY18-62017-011343-B	<1
WS-011345	6/22/17	6/22/18	1	Fountain	In hallway adjacent to day care room 1630	Right	Low	WF-62017-011345	12/20/17	FT-FY18-62017-011345-A	<1	FT-FY18-62017-011345-B	<1
WS-011349	11/15/17	11/15/18	1	Classroom Faucet	In day care room 1630			WF-112017-011349	12/20/17	FT-FY18-112017-011349-A	<1	FT-FY18-112017-011349-B	<1
WS-011377	6/22/17	6/22/18	2	Fountain	In hallway adjacent to room 2503	Right	Low	WF-62017-011377	12/20/17	FT-FY18-62017-011377-A	<1	FT-FY18-62017-011377-B	<1
WS-011379	6/22/17	6/22/18	2	Fountain	In hallway adjacent to room 2623	Left	High	WF-62017-011379	12/20/17	FT-FY18-62017-011379-A	<1	FT-FY18-62017-011379-B	<1
WS-011385	6/22/17	6/22/18	2	Fountain	In hallway across from room 2012	Right	Low	WF-62017-011385	12/20/17	FT-FY18-62017-011385-A	<1	FT-FY18-62017-011385-B	<1
WS-011418	6/22/17	6/22/18	2	Fountain	In pool area right of pool	Left	High	WF-62017-011418	12/20/17	FT-FY18-62017-011418-A	<1	FT-FY18-62017-011418-B	<1
WS-011434	6/22/17	6/22/18	2	Fountain	In hallway adjacent to room 2320	Left	Low	WF-62017-011434	12/20/17	FT-FY18-62017-011434-A	<1	FT-FY18-62017-011434-B	<1
WS-011437	6/22/17	6/22/18	2	Fountain	In hallway adjacent to football locker room	Left	High	WF-62017-011437	12/20/17	FT-FY18-62017-011437-A	<1	FT-FY18-62017-011437-B	<1
WS-011441	6/22/17	6/22/18	2	Health Suite	In health suite in exam room 2316			WF-62017-011441	12/20/17	FT-FY18-62017-011441-A	<1	FT-FY18-62017-011441-B	<1
WS-011442	6/22/17	6/22/18	2	Health Suite	In health suite in exam room 2315			WF-62017-011442	12/20/17	FT-FY18-62017-011442-A	<1	FT-FY18-62017-011442-B	<1
WS-011443	6/22/17	6/22/18	2	Health Suite	In health suite in exam room 2313			WF-62017-011443	12/20/17	FT-FY18-62017-011443-A	<1	FT-FY18-62017-011443-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011366	2	Food Prep Sink	In kitchen room 2503 on east wall			12/20/17	FT-FY18-102017-011366-A	<1	FT-FY18-102017-011366-B	<1