



Bancroft @ Sharpe Health Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008565	6/26/2017	6/26/2018	1	Cooler	In hallway adjacent to room 314	WF-62017-008565	11/7/2017	FT-FY18-62017-008565-A	<1	FT-FY18-62017-008565-B	<1
WS- 008593	6/26/2017	6/26/2018	1	Cooler	In hallway adjacent to classroom 119	WF-62017-008593	11/7/2017	FT-FY18-62017-008593-A	<1	FT-FY18-62017-008593-B	<1
WS- 009168	6/26/2017	6/26/2018	1	Health Suite	In health suite 202	WF-62017-009168	11/7/2017	FT-FY18-62017-009168-A	<1	FT-FY18-62017-009168-B	<1
WS- 010541	6/26/2017	6/26/2018	1	Break Room	In room 111B	WF-62017-010541	11/7/2017	FT-FY18-62017-010541-A	<1	FT-FY18-62017-010541-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008574	1	Food Prep Sink	In kitchen Right	11/7/2017	FT-FY18-102017-008574-A	<1	FT-FY18-102017-008574-B	<1