



Bancroft ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013600	8/14/2018	8/14/2019	Ground Floor	Bottle Filler	In gym	WF-08142018-013600	8/27/2018	FT-FY19-082018-013600-A	< 1	FT-FY19-082018-013600-B	< 1
WS-013601	8/14/2018	8/14/2019	Ground Floor	Cooler	In gym High Left	WF-08142018-013601	8/27/2018	FT-FY19-082018-013601-A	< 1	FT-FY19-082018-013601-B	< 1
WS-013602	8/14/2018	8/14/2019	Ground Floor	Cooler	In gym Low Right	WF-08142018-013602	8/27/2018	FT-FY19-082018-013602-A	< 1	FT-FY19-082018-013602-B	< 1
WS-013603	8/14/2018	8/14/2019	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-08142018-013603	8/27/2018	FT-FY19-082018-013603-A	< 1	FT-FY19-082018-013603-B	< 1
WS-013604	8/14/2018	8/14/2019	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-08142018-013604	8/27/2018	FT-FY19-082018-013604-A	< 1	FT-FY19-082018-013604-B	< 1
WS-013605	8/14/2018	8/14/2019	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-08142018-013605	8/27/2018	FT-FY19-082018-013605-A	< 1	FT-FY19-082018-013605-B	< 1
WS-013606	8/14/2018	8/14/2019	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-08142018-013606	8/27/2018	FT-FY19-082018-013606-A	< 1	FT-FY19-082018-013606-B	< 1
WS-013607	8/14/2018	8/14/2019	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-08142018-013607	8/27/2018	FT-FY19-082018-013607-A	< 1	FT-FY19-082018-013607-B	< 1
WS-013608	8/14/2018	8/14/2019	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-08142018-013608	8/27/2018	FT-FY19-082018-013608-A	< 1	FT-FY19-082018-013608-B	< 1
WS-013609	8/14/2018	8/14/2019	Ground Floor	Health Suite	In health suite treatment room 026C	WF-08142018-013609	8/27/2018	FT-FY19-082018-013609-A	< 1	FT-FY19-082018-013609-B	< 1
WS-013610	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In health suite treatment room 026C	WF-08142018-013610	8/27/2018	FT-FY19-082018-013610-A	< 1	FT-FY19-082018-013610-B	< 1
WS-013611	8/14/2018	8/14/2019	Ground Floor	Bottle Filler	In cafeteria (left set)	WF-08142018-013611	8/27/2018	FT-FY19-082018-013611-A	< 1	FT-FY19-082018-013611-B	< 1
WS-013612	8/14/2018	8/14/2019	Ground Floor	Cooler	In cafeteria (left set) High Left	WF-08142018-013612	8/27/2018	FT-FY19-082018-013612-A	< 1	FT-FY19-082018-013612-B	< 1
WS-013613	8/14/2018	8/14/2019	Ground Floor	Cooler	In cafeteria (left set) Low Right	WF-08142018-013613	8/27/2018	FT-FY19-082018-013613-A	< 1	FT-FY19-082018-013613-B	< 1
WS-013614	8/14/2018	8/14/2019	Ground Floor	Bottle Filler	In cafeteria (right set)	WF-08142018-013614	8/27/2018	FT-FY19-082018-013614-A	< 1	FT-FY19-082018-013614-B	< 1
WS-013615	8/14/2018	8/14/2019	Ground Floor	Cooler	In cafeteria (right set) High Left	WF-08142018-013615	8/27/2018	FT-FY19-082018-013615-A	< 1	FT-FY19-082018-013615-B	< 1
WS-013616	8/14/2018	8/14/2019	Ground Floor	Cooler	In cafeteria (right set) Low Right	WF-08142018-013616	8/27/2018	FT-FY19-082018-013616-A	< 1	FT-FY19-082018-013616-B	< 1
WS-013628	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 033	WF-08142018-013628	8/27/2018	FT-FY19-082018-013628-A	< 1	FT-FY19-082018-013628-B	< 1
WS-013630	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 042	WF-08142018-013630	8/27/2018	FT-FY19-082018-013630-A	< 1	FT-FY19-082018-013630-B	< 1
WS-013632	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 041	WF-08142018-013632	8/27/2018	FT-FY19-082018-013632-A	< 1	FT-FY19-082018-013632-B	< 1
WS-013634	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 038	WF-08142018-013634	8/27/2018	FT-FY19-082018-013634-A	< 1	FT-FY19-082018-013634-B	< 1
WS-013636	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 040	WF-08142018-013636	8/27/2018	FT-FY19-082018-013636-A	< 1	FT-FY19-082018-013636-B	< 1
WS-013638	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In classroom 039	WF-08142018-013638	8/27/2018	FT-FY19-082018-013638-A	< 1	FT-FY19-082018-013638-B	< 1
WS-013640	8/14/2018	8/14/2019	Ground Floor	Combo Fountain	In music room 024	WF-08142018-013640	8/27/2018	FT-FY19-082018-013640-A	< 1	FT-FY19-082018-013640-B	< 1
WS-013644	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 109W	WF-08142018-013644	8/27/2018	FT-FY19-082018-013644-A	< 1	FT-FY19-082018-013644-B	< 1
WS-013645	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 114E	WF-08142018-013645	8/27/2018	FT-FY19-082018-013645-A	< 1	FT-FY19-082018-013645-B	< 1
WS-013646	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 114E	WF-08142018-013646	8/27/2018	FT-FY19-082018-013646-A	< 1	FT-FY19-082018-013646-B	< 1
WS-013647	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 116E	WF-08142018-013647	8/27/2018	FT-FY19-082018-013647-A	< 1	FT-FY19-082018-013647-B	< 1
WS-013648	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 116E	WF-08142018-013648	8/27/2018	FT-FY19-082018-013648-A	< 1	FT-FY19-082018-013648-B	< 1
WS-013649	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 117E	WF-08142018-013649	8/27/2018	FT-FY19-082018-013649-A	< 1	FT-FY19-082018-013649-B	< 1
WS-013650	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 117E	WF-08142018-013650	8/27/2018	FT-FY19-082018-013650-A	< 1	FT-FY19-082018-013650-B	< 1
WS-013651	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 120E	WF-08142018-013651	8/27/2018	FT-FY19-082018-013651-A	< 1	FT-FY19-082018-013651-B	< 1
WS-013652	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 120E	WF-08142018-013652	8/27/2018	FT-FY19-082018-013652-A	< 1	FT-FY19-082018-013652-B	< 1
WS-013653	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 121	WF-08142018-013653	8/27/2018	FT-FY19-082018-013653-A	< 1	FT-FY19-082018-013653-B	< 1

WS-013654	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 121	WF-08142018-013654	8/27/2018	FT-FY19-082018-013654-A	< 1	FT-FY19-082018-013654-B	< 1
WS-013655	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 131	WF-08142018-013655	8/27/2018	FT-FY19-082018-013655-A	< 1	FT-FY19-082018-013655-B	< 1
WS-013656	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 131	WF-08142018-013656	8/27/2018	FT-FY19-082018-013656-A	< 1	FT-FY19-082018-013656-B	< 1
WS-013657	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 122	WF-08142018-013657	8/27/2018	FT-FY19-082018-013657-A	< 1	FT-FY19-082018-013657-B	< 1
WS-013658	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 122	WF-08142018-013658	8/27/2018	FT-FY19-082018-013658-A	< 1	FT-FY19-082018-013658-B	< 1
WS-013659	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 130	WF-08142018-013659	8/27/2018	FT-FY19-082018-013659-A	< 1	FT-FY19-082018-013659-B	< 1
WS-013660	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 130	WF-08142018-013660	8/27/2018	FT-FY19-082018-013660-A	< 1	FT-FY19-082018-013660-B	< 1
WS-013661	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 129	WF-08142018-013661	8/27/2018	FT-FY19-082018-013661-A	< 1	FT-FY19-082018-013661-B	< 1
WS-013662	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 129	WF-08142018-013662	8/27/2018	FT-FY19-082018-013662-A	< 1	FT-FY19-082018-013662-B	< 1
WS-013663	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 128	WF-08142018-013663	8/27/2018	FT-FY19-082018-013663-A	< 1	FT-FY19-082018-013663-B	< 1
WS-013664	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 128	WF-08142018-013664	8/27/2018	FT-FY19-082018-013664-A	< 1	FT-FY19-082018-013664-B	< 1
WS-013665	8/14/2018	8/14/2019	1	Combo Faucet	In classroom 133	WF-08142018-013665	8/27/2018	FT-FY19-082018-013665-A	< 1	FT-FY19-082018-013665-B	< 1
WS-013666	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 133	WF-08142018-013666	8/27/2018	FT-FY19-082018-013666-A	< 1	FT-FY19-082018-013666-B	< 1
WS-013668	8/14/2018	8/14/2019	1	Combo Fountain	In media production room 135-A	WF-08142018-013668	8/27/2018	FT-FY19-082018-013668-A	< 1	FT-FY19-082018-013668-B	< 1
WS-013670	8/14/2018	8/14/2019	1	Combo Fountain	In media center 135 behind receptionist desk	WF-08142018-013670	8/27/2018	FT-FY19-082018-013670-A	< 1	FT-FY19-082018-013670-B	< 1
WS-013672	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 143	WF-08142018-013672	8/27/2018	FT-FY19-082018-013672-A	< 1	FT-FY19-082018-013672-B	< 1
WS-013674	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 152	WF-08142018-013674	8/27/2018	FT-FY19-082018-013674-A	< 1	FT-FY19-082018-013674-B	< 1
WS-013676	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 151	WF-08142018-013676	8/27/2018	FT-FY19-082018-013676-A	< 1	FT-FY19-082018-013676-B	< 1
WS-013678	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 148	WF-08142018-013678	8/27/2018	FT-FY19-082018-013678-A	< 1	FT-FY19-082018-013678-B	< 1
WS-013680	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 150	WF-08142018-013680	8/27/2018	FT-FY19-082018-013680-A	< 1	FT-FY19-082018-013680-B	< 1
WS-013682	8/14/2018	8/14/2019	1	Combo Fountain	In classroom 149	WF-08142018-013682	8/27/2018	FT-FY19-082018-013682-A	< 1	FT-FY19-082018-013682-B	< 1
WS-013684	8/14/2018	8/14/2019	2	Combo Fountain	In classroom 208W	WF-08142018-013684	8/27/2018	FT-FY19-082018-013684-A	< 1	FT-FY19-082018-013684-B	< 1
WS-013685	8/14/2018	8/14/2019	2	Break Room	In staff lounge 201W	WF-08142018-013685	8/27/2018	FT-FY19-082018-013685-A	< 1	FT-FY19-082018-013685-B	< 1
WS-013686	8/14/2018	8/14/2019	2	Combo Fountain	In staff lounge 201W	WF-08142018-013686	8/27/2018	FT-FY19-082018-013686-A	< 1	FT-FY19-082018-013686-B	< 1
WS-013688	8/14/2018	8/14/2019	2	Combo Fountain	In classroom 217E	WF-08142018-013688	8/27/2018	FT-FY19-082018-013688-A	< 1	FT-FY19-082018-013688-B	< 1
WS-013690	8/14/2018	8/14/2019	2	Combo Fountain	In classroom 218E	WF-08142018-013690	8/27/2018	FT-FY19-082018-013690-A	< 1	FT-FY19-082018-013690-B	1.3
WS-013692	8/14/2018	8/14/2019	2	Combo Fountain	In classroom 219E	WF-08142018-013692	8/27/2018	FT-FY19-082018-013692-A	< 1	FT-FY19-082018-013692-B	< 1
WS-013694	8/14/2018	8/14/2019	2	Combo Fountain	In classroom 220E	WF-08142018-013694	8/27/2018	FT-FY19-082018-013694-A	< 1	FT-FY19-082018-013694-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-013618	Ground Floor	Food Prep Sink	In kitchen	8/27/2018	FT-FY19-082018-013618-A	< 1	FT-FY19-082018-013618-B	< 1	