



Bancroft Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013600	3/22/2021	3/22/2022	Ground Floor	Bottle Filler	In gym	WF-03222021-013600	4/1/2021	FT-FY21-032021-013600-A	<1	FT-FY21-032021-013600-B	<1
WS-013601	3/22/2021	3/22/2022	Ground Floor	Cooler	In gym High Left	WF-03222021-013601	4/1/2021	FT-FY21-032021-013601-A	<1	FT-FY21-032021-013601-B	<1
WS-013602	3/22/2021	3/22/2022	Ground Floor	Cooler	In gym Low Right	WF-03222021-013602	4/1/2021	FT-FY21-032021-013602-A	<1	FT-FY21-032021-013602-B	<1
WS-013603	3/22/2021	3/22/2022	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-03222021-013603	4/1/2021	FT-FY21-032021-013603-A	<1	FT-FY21-032021-013603-B	<1
WS-013604	3/22/2021	3/22/2022	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-03222021-013604	4/1/2021	FT-FY21-032021-013604-A	<1	FT-FY21-032021-013604-B	<1
WS-013605	3/22/2021	3/22/2022	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-03222021-013605	4/1/2021	FT-FY21-032021-013605-A	<1	FT-FY21-032021-013605-B	<1
WS-013606	3/22/2021	3/22/2022	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-03222021-013606	4/1/2021	FT-FY21-032021-013606-A	<1	FT-FY21-032021-013606-B	<1
WS-013607	3/22/2021	3/22/2022	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-03222021-013607	4/1/2021	FT-FY21-032021-013607-A	<1	FT-FY21-032021-013607-B	<1
WS-013608	3/22/2021	3/22/2022	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-03222021-013608	4/1/2021	FT-FY21-032021-013608-A	<1	FT-FY21-032021-013608-B	<1
WS-013609	3/22/2021	3/22/2022	Ground Floor	Health Suite	In health suite treatment room 026C	WF-03222021-013609	4/1/2021	FT-FY21-032021-013609-A	<1	FT-FY21-032021-013609-B	<1
WS-013610	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In health suite treatment room 026C	WF-03222021-013610	4/1/2021	FT-FY21-032021-013610-A	<1	FT-FY21-032021-013610-B	<1
WS-013611	3/22/2021	3/22/2022	Ground Floor	Bottle Filler	In cafeteria (left set)	WF-03222021-013611	4/1/2021	FT-FY21-032021-013611-A	<1	FT-FY21-032021-013611-B	<1
WS-013612	3/22/2021	3/22/2022	Ground Floor	Cooler	In cafeteria (left set) High Left	WF-03222021-013612	4/1/2021	FT-FY21-032021-013612-A	<1	FT-FY21-032021-013612-B	<1
WS-013613	3/22/2021	3/22/2022	Ground Floor	Cooler	In cafeteria (left set) Low Right	WF-03222021-013613	4/1/2021	FT-FY21-032021-013613-A	<1	FT-FY21-032021-013613-B	<1
WS-013614	3/22/2021	3/22/2022	Ground Floor	Bottle Filler	In cafeteria (right set)	WF-03222021-013614	4/1/2021	FT-FY21-032021-013614-A	<1	FT-FY21-032021-013614-B	<1
WS-013615	3/22/2021	3/22/2022	Ground Floor	Cooler	In cafeteria (right set) High Left	WF-03222021-013615	4/1/2021	FT-FY21-032021-013615-A	<1	FT-FY21-032021-013615-B	<1
WS-013616	3/22/2021	3/22/2022	Ground Floor	Cooler	In cafeteria (right set) Low Right	WF-03222021-013616	4/1/2021	FT-FY21-032021-013616-A	<1	FT-FY21-032021-013616-B	<1
WS-013628	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 033	WF-03222021-013628	4/1/2021	FT-FY21-032021-013628-A	<1	FT-FY21-032021-013628-B	<1
WS-013630	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 042	WF-03222021-013630	4/1/2021	FT-FY21-032021-013630-A	<1	FT-FY21-032021-013630-B	<1
WS-013632	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 041	WF-03222021-013632	4/1/2021	FT-FY21-032021-013632-A	<1	FT-FY21-032021-013632-B	<1
WS-013634	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 038	WF-03222021-013634	4/1/2021	FT-FY21-032021-013634-A	<1	FT-FY21-032021-013634-B	<1
WS-013636	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 040	WF-03222021-013636	4/1/2021	FT-FY21-032021-013636-A	<1	FT-FY21-032021-013636-B	<1
WS-013638	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In classroom 039	WF-03222021-013638	4/1/2021	FT-FY21-032021-013638-A	<1	FT-FY21-032021-013638-B	<1
WS-013640	3/22/2021	3/22/2022	Ground Floor	Combo Fountain	In music room 024	WF-03222021-013640	4/1/2021	FT-FY21-032021-013640-A	<1	FT-FY21-032021-013640-B	<1
WS-013644	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 109W	WF-03222021-013644	4/1/2021	FT-FY21-032021-013644-A	<1	FT-FY21-032021-013644-B	<1
WS-013645	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 114E	WF-10152020-013645	4/1/2021	FT-FY21-032021-013645-A	<1	FT-FY21-032021-013645-B	<1
WS-013646	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 114E	WF-03222021-013646	4/1/2021	FT-FY21-032021-013646-A	<1	FT-FY21-032021-013646-B	<1
WS-013647	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 116E	WF-10152020-013647	4/1/2021	FT-FY21-032021-013647-A	<1	FT-FY21-032021-013647-B	<1
WS-013648	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 116E	WF-03222021-013648	4/1/2021	FT-FY21-032021-013648-A	<1	FT-FY21-032021-013648-B	<1
WS-013649	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 117E	WF-10152020-013649	4/1/2021	FT-FY21-032021-013649-A	2.7	FT-FY21-032021-013649-B	<1
WS-013650	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 117E	WF-03222021-013650	4/1/2021	FT-FY21-032021-013650-A	<1	FT-FY21-032021-013650-B	<1
WS-013651	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 120E	WF-10152020-013651	4/1/2021	FT-FY21-032021-013651-A	<1	FT-FY21-032021-013651-B	<1
WS-013652	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 120E	WF-03222021-013652	4/1/2021	FT-FY21-032021-013652-A	<1	FT-FY21-032021-013652-B	<1
WS-013653	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 121	WF-10152020-013653	4/1/2021	FT-FY21-032021-013653-A	<1	FT-FY21-032021-013653-B	<1

WS-013654	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 121	WF-03222021-013654	4/1/2021	FT-FY21-032021-013654-A	<1	FT-FY21-032021-013654-B	<1
WS-013655	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 131	WF-10152020-013655	4/1/2021	FT-FY21-032021-013655-A	<1	FT-FY21-032021-013655-B	<1
WS-013656	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 131	WF-03222021-013656	4/1/2021	FT-FY21-032021-013656-A	<1	FT-FY21-032021-013656-B	<1
WS-013657	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 122	WF-10152020-013657	4/1/2021	FT-FY21-032021-013657-A	<1	FT-FY21-032021-013657-B	<1
WS-013658	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 122	WF-03222021-013658	4/1/2021	FT-FY21-032021-013658-A	<1	FT-FY21-032021-013658-B	<1
WS-013659	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 130	WF-10152020-013659	4/1/2021	FT-FY21-032021-013659-A	<1	FT-FY21-032021-013659-B	<1
WS-013660	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 130	WF-03222021-013660	4/1/2021	FT-FY21-032021-013660-A	<1	FT-FY21-032021-013660-B	<1
WS-013661	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 129	WF-10152020-013661	4/1/2021	FT-FY21-032021-013661-A	3.7	FT-FY21-032021-013661-B	<1
WS-013662	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 129	WF-03222021-013662	4/1/2021	FT-FY21-032021-013662-A	<1	FT-FY21-032021-013662-B	<1
WS-013663	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 128	WF-10152020-013663	4/1/2021	FT-FY21-032021-013663-A	<1	FT-FY21-032021-013663-B	<1
WS-013664	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 128	WF-03222021-013664	4/1/2021	FT-FY21-032021-013664-A	<1	FT-FY21-032021-013664-B	<1
WS-013665	10/15/2020	10/15/2021	1	Combo Faucet	In classroom 133	WF-10152020-013665	4/1/2021	FT-FY21-032021-013665-A	<1	FT-FY21-032021-013665-B	<1
WS-013666	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 133	WF-03222021-013666	4/1/2021	FT-FY21-032021-013666-A	<1	FT-FY21-032021-013666-B	<1
WS-013668	3/22/2021	3/22/2022	1	Combo Fountain	In media production room 135-A	WF-03222021-013668	4/1/2021	FT-FY21-032021-013668-A	<1	FT-FY21-032021-013668-B	<1
WS-013670	3/22/2021	3/22/2022	1	Combo Fountain	In media center 135 behind receptionist desk	WF-03222021-013670	4/1/2021	FT-FY21-032021-013670-A	<1	FT-FY21-032021-013670-B	<1
WS-013672	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 143	WF-03222021-013672	4/1/2021	FT-FY21-032021-013672-A	<1	FT-FY21-032021-013672-B	<1
WS-013674	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 152	WF-03222021-013674	4/1/2021	FT-FY21-032021-013674-A	<1	FT-FY21-032021-013674-B	<1
WS-013676	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 151	WF-03222021-013676	4/1/2021	FT-FY21-032021-013676-A	<1	FT-FY21-032021-013676-B	<1
WS-013678	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 148	WF-03222021-013678	4/1/2021	FT-FY21-032021-013678-A	<1	FT-FY21-032021-013678-B	<1
WS-013680	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 150	WF-03222021-013680	4/1/2021	FT-FY21-032021-013680-A	<1	FT-FY21-032021-013680-B	<1
WS-013682	3/22/2021	3/22/2022	1	Combo Fountain	In classroom 149	WF-03222021-013682	4/1/2021	FT-FY21-032021-013682-A	<1	FT-FY21-032021-013682-B	<1
WS-013684	3/22/2021	3/22/2022	2	Combo Fountain	In classroom 208W	WF-03222021-013684	4/1/2021	FT-FY21-032021-013684-A	<1	FT-FY21-032021-013684-B	<1
WS-013685	3/22/2021	3/22/2022	2	Break Room	In staff lounge 201W	WF-03222021-013685	4/1/2021	FT-FY21-032021-013685-A	<1	FT-FY21-032021-013685-B	<1
WS-013686	3/22/2021	3/22/2022	2	Combo Fountain	In staff lounge 201W	WF-03222021-013686	4/1/2021	FT-FY21-032021-013686-A	<1	FT-FY21-032021-013686-B	<1
WS-013688	3/22/2021	3/22/2022	2	Combo Fountain	In classroom 217E	WF-03222021-013688	4/1/2021	FT-FY21-032021-013688-A	<1	FT-FY21-032021-013688-B	<1
WS-013690	3/22/2021	3/22/2022	2	Combo Fountain	In classroom 218E	WF-03222021-013690	4/1/2021	FT-FY21-032021-013690-A	<1	FT-FY21-032021-013690-B	<1
WS-013692	3/22/2021	3/22/2022	2	Combo Fountain	In classroom 219E	WF-03222021-013692	4/1/2021	FT-FY21-032021-013692-A	<1	FT-FY21-032021-013692-B	<1
WS-013694	3/22/2021	3/22/2022	2	Combo Fountain	In classroom 220E	WF-03222021-013694	4/1/2021	FT-FY21-032021-013694-A	<1	FT-FY21-032021-013694-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013618	1/12/2021	1/12/2022	Ground Floor	Food Prep Sink	In kitchen	WF-01122021-013618	4/1/2021	FT-FY21-032021-013618-A	<1	FT-FY21-032021-013618-B	<1