



# Bancroft ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013600	4/9/2019	4/9/2020	Ground Floor	Bottle Filler	In gym	WF-04092019-013600	10/18/2019	FT-FY20-102019-013600-A	<1	FT-FY20-102019-013600-B	<1
WS-013601	4/9/2019	4/9/2020	Ground Floor	Cooler	In gym High Left	WF-04092019-013601	10/18/2019	FT-FY20-102019-013601-A	<1	FT-FY20-102019-013601-B	<1
WS-013602	4/9/2019	4/9/2020	Ground Floor	Cooler	In gym Low Right	WF-04092019-013602	10/18/2019	FT-FY20-102019-013602-A	<1	FT-FY20-102019-013602-B	<1
WS-013603	4/9/2019	4/9/2020	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-04092019-013603	10/18/2019	FT-FY20-102019-013603-A	<1	FT-FY20-102019-013603-B	<1
WS-013604	4/9/2019	4/9/2020	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-04092019-013604	10/18/2019	FT-FY20-102019-013604-A	<1	FT-FY20-102019-013604-B	<1
WS-013605	4/9/2019	4/9/2020	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-04092019-013605	10/18/2019	FT-FY20-102019-013605-A	<1	FT-FY20-102019-013605-B	<1
WS-013606	4/9/2019	4/9/2020	Ground Floor	Bottle Filler	In hallway adjacent to the gym	WF-04092019-013606	10/18/2019	FT-FY20-102019-013606-A	<1	FT-FY20-102019-013606-B	<1
WS-013607	4/9/2019	4/9/2020	Ground Floor	Cooler	In hallway adjacent to the gym High Left	WF-04092019-013607	10/18/2019	FT-FY20-102019-013607-A	<1	FT-FY20-102019-013607-B	<1
WS-013608	4/9/2019	4/9/2020	Ground Floor	Cooler	In hallway adjacent to the gym Low Right	WF-04092019-013608	10/18/2019	FT-FY20-102019-013608-A	<1	FT-FY20-102019-013608-B	<1
WS-013609	4/9/2019	4/9/2020	Ground Floor	Health Suite	In health suite treatment room 026C	WF-04092019-013609	10/18/2019	FT-FY20-102019-013609-A	<1	FT-FY20-102019-013609-B	<1
WS-013610	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In health suite treatment room 026C	WF-04092019-013610	10/18/2019	FT-FY20-102019-013610-A	<1	FT-FY20-102019-013610-B	<1
WS-013611	4/9/2019	4/9/2020	Ground Floor	Bottle Filler	In cafeteria (left set)	WF-04092019-013611	10/18/2019	FT-FY20-102019-013611-A	<1	FT-FY20-102019-013611-B	<1
WS-013612	4/9/2019	4/9/2020	Ground Floor	Cooler	In cafeteria (left set) High Left	WF-04092019-013612	10/18/2019	FT-FY20-102019-013612-A	<1	FT-FY20-102019-013612-B	<1
WS-013613	4/9/2019	4/9/2020	Ground Floor	Cooler	In cafeteria (left set) Low Right	WF-04092019-013613	10/18/2019	FT-FY20-102019-013613-A	<1	FT-FY20-102019-013613-B	<1
WS-013614	4/9/2019	4/9/2020	Ground Floor	Bottle Filler	In cafeteria (right set)	WF-04092019-013614	10/18/2019	FT-FY20-102019-013614-A	<1	FT-FY20-102019-013614-B	<1
WS-013615	4/9/2019	4/9/2020	Ground Floor	Cooler	In cafeteria (right set) High Left	WF-04092019-013615	10/18/2019	FT-FY20-102019-013615-A	<1	FT-FY20-102019-013615-B	<1
WS-013616	4/9/2019	4/9/2020	Ground Floor	Cooler	In cafeteria (right set) Low Right	WF-04092019-013616	10/18/2019	FT-FY20-102019-013616-A	<1	FT-FY20-102019-013616-B	<1
WS-013628	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 033	WF-04092019-013628	10/18/2019	FT-FY20-102019-013628-A	<1	FT-FY20-102019-013628-B	<1
WS-013630	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 042	WF-04092019-013630	10/18/2019	FT-FY20-102019-013630-A	<1	FT-FY20-102019-013630-B	<1
WS-013632	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 041	WF-04092019-013632	10/18/2019	FT-FY20-102019-013632-A	<1	FT-FY20-102019-013632-B	<1
WS-013634	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 038	WF-04092019-013634	10/18/2019	FT-FY20-102019-013634-A	<1	FT-FY20-102019-013634-B	<1
WS-013636	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 040	WF-04092019-013636	10/18/2019	FT-FY20-102019-013636-A	<1	FT-FY20-102019-013636-B	<1
WS-013638	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In classroom 039	WF-04092019-013638	10/18/2019	FT-FY20-102019-013638-A	<1	FT-FY20-102019-013638-B	<1
WS-013640	4/9/2019	4/9/2020	Ground Floor	Combo Fountain	In music room 024	WF-04092019-013640	10/18/2019	FT-FY20-102019-013640-A	<1	FT-FY20-102019-013640-B	<1
WS-013644	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 109W	WF-04092019-013644	10/18/2019	FT-FY20-102019-013644-A	<1	FT-FY20-102019-013644-B	<1
WS-013645	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 114E	WF-10212019-013645	10/18/2019	FT-FY20-102019-013645-A	<1	FT-FY20-102019-013645-B	<1
WS-013646	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 114E	WF-04092019-013646	10/18/2019	FT-FY20-102019-013646-A	<1	FT-FY20-102019-013646-B	<1
WS-013647	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 116E	WF-10212019-013647	10/18/2019	FT-FY20-102019-013647-A	1.5	FT-FY20-102019-013647-B	<1
WS-013648	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 116E	WF-04092019-013648	10/18/2019	FT-FY20-102019-013648-A	<1	FT-FY20-102019-013648-B	<1
WS-013649	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 117E	WF-10212019-013649	10/18/2019	FT-FY20-102019-013649-A	<1	FT-FY20-102019-013649-B	<1
WS-013650	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 117E	WF-04092019-013650	10/18/2019	FT-FY20-102019-013650-A	<1	FT-FY20-102019-013650-B	<1
WS-013651	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 120E	WF-10212019-013651	10/18/2019	FT-FY20-102019-013651-A	1.7	FT-FY20-102019-013651-B	<1
WS-013652	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 120E	WF-04092019-013652	10/18/2019	FT-FY20-102019-013652-A	<1	FT-FY20-102019-013652-B	<1
WS-013653	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 121	WF-10212019-013653	10/18/2019	FT-FY20-102019-013653-A	3.9	FT-FY20-102019-013653-B	<1

WS-013654	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 121	WF-04092019-013654	10/18/2019	FT-FY20-102019-013654-A	<1	FT-FY20-102019-013654-B	<1
WS-013655	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 131	WF-10212019-013655	10/18/2019	FT-FY20-102019-013655-A	<1	FT-FY20-102019-013655-B	<1
WS-013656	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 131	WF-04092019-013656	10/18/2019	FT-FY20-102019-013656-A	<1	FT-FY20-102019-013656-B	<1
WS-013657	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 122	WF-10212019-013657	10/18/2019	FT-FY20-102019-013657-A	1.8	FT-FY20-102019-013657-B	<1
WS-013658	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 122	WF-04092019-013658	10/18/2019	FT-FY20-102019-013658-A	<1	FT-FY20-102019-013658-B	<1
WS-013659	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 130	WF-10212019-013659	10/18/2019	FT-FY20-102019-013659-A	<1	FT-FY20-102019-013659-B	<1
WS-013660	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 130	WF-04092019-013660	10/18/2019	FT-FY20-102019-013660-A	<1	FT-FY20-102019-013660-B	<1
WS-013661	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 129	WF-10212019-013661	10/18/2019	FT-FY20-102019-013661-A	<1	FT-FY20-102019-013661-B	<1
WS-013662	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 129	WF-04092019-013662	10/18/2019	FT-FY20-102019-013662-A	<1	FT-FY20-102019-013662-B	<1
WS-013663	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 128	WF-10212019-013663	10/18/2019	FT-FY20-102019-013663-A	1.8	FT-FY20-102019-013663-B	<1
WS-013664	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 128	WF-04092019-013664	10/18/2019	FT-FY20-102019-013664-A	<1	FT-FY20-102019-013664-B	<1
WS-013665	10/21/2019	10/21/2020	1	Combo Faucet	In classroom 133	WF-10212019-013665	10/18/2019	FT-FY20-102019-013665-A	3.3	FT-FY20-102019-013665-B	<1
WS-013666	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 133	WF-04092019-013666	10/18/2019	FT-FY20-102019-013666-A	<1	FT-FY20-102019-013666-B	<1
WS-013668	4/9/2019	4/9/2020	1	Combo Fountain	In media production room 135-A	WF-04092019-013668	10/18/2019	FT-FY20-102019-013668-A	<1	FT-FY20-102019-013668-B	<1
WS-013670	4/9/2019	4/9/2020	1	Combo Fountain	In media center 135 behind receptionist desk	WF-04092019-013670	10/18/2019	FT-FY20-102019-013670-A	<1	FT-FY20-102019-013670-B	<1
WS-013672	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 143	WF-04092019-013672	10/18/2019	FT-FY20-102019-013672-A	<1	FT-FY20-102019-013672-B	<1
WS-013674	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 152	WF-04092019-013674	10/18/2019	FT-FY20-102019-013674-A	<1	FT-FY20-102019-013674-B	<1
WS-013676	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 151	WF-04092019-013676	10/18/2019	FT-FY20-102019-013676-A	<1	FT-FY20-102019-013676-B	<1
WS-013678	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 148	WF-04092019-013678	10/18/2019	FT-FY20-102019-013678-A	<1	FT-FY20-102019-013678-B	<1
WS-013680	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 150	WF-04092019-013680	10/18/2019	FT-FY20-102019-013680-A	<1	FT-FY20-102019-013680-B	<1
WS-013682	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 149	WF-04092019-013682	10/18/2019	FT-FY20-102019-013682-A	<1	FT-FY20-102019-013682-B	<1
WS-013684	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 208W	WF-04092019-013684	10/18/2019	FT-FY20-102019-013684-A	<1	FT-FY20-102019-013684-B	<1
WS-013685	4/9/2019	4/9/2020	2	Break Room	In staff lounge 201W	WF-04092019-013685	10/18/2019	FT-FY20-102019-013685-A	<1	FT-FY20-102019-013685-B	<1
WS-013686	4/9/2019	4/9/2020	2	Combo Fountain	In staff lounge 201W	WF-04092019-013686	10/18/2019	FT-FY20-102019-013686-A	<1	FT-FY20-102019-013686-B	<1
WS-013688	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 217E	WF-04092019-013688	10/18/2019	FT-FY20-102019-013688-A	<1	FT-FY20-102019-013688-B	<1
WS-013690	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 218E	WF-04092019-013690	10/18/2019	FT-FY20-102019-013690-A	<1	FT-FY20-102019-013690-B	<1
WS-013692	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 219E	WF-04092019-013692	10/18/2019	FT-FY20-102019-013692-A	<1	FT-FY20-102019-013692-B	<1
WS-013694	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 220E	WF-04092019-013694	10/18/2019	FT-FY20-102019-013694-A	<1	FT-FY20-102019-013694-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013618	7/23/2019	7/23/2020	Ground Floor	Food Prep Sink	In kitchen	WF-07232019-013618	10/18/2019	FT-FY20-102019-013618-A	<1	FT-FY20-102019-013618-B	<1