



Banneker Community Center Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation														
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-012668	6/30/17	6/30/18	1	Cooler	In hallway adjacent to room 102 in lobby	Right	Low	WF-72017-012668	1/12/18	FT-FY18-072017-012668-A	<1	FT-FY18-072017-012668-B	<1	
WS-012670	6/30/17	6/30/18	Basement	Cooler	In hallway adjacent to men's locker room	Left	High	WF-72017-012670	1/12/18	FT-FY18-072017-012670-A	<1	FT-FY18-072017-012670-B	<1	

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-012655	1	Food Prep Sink	In kitchenette in gym				1/12/18	FT-FY18-082017-012655-A	<1	FT-FY18-082017-012655-B	<1