



BANNEKER HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BANNEKER HIGH SCHOOL	WS- 011899	8/16/2016	Basement	Cooler	In hallway adjacent to stairwell 6	FT-82016-011899-A	< 1	FT-82016-011899-B	< 1
2	BANNEKER HIGH SCHOOL	WS- 011900	8/16/2016	Basement	Cooler	In cafeteria adjacent to kitchen area	FT-82016-011900-A	< 1	FT-82016-011900-B	< 1
3	BANNEKER HIGH SCHOOL	WS- 011901	8/16/2016	Basement	Cooler	In cafeteria across from kitchen area	FT-82016-011901-A	< 1	FT-82016-011901-B	< 1
4	BANNEKER HIGH SCHOOL	WS- 011902	8/16/2016	Basement	Food Prep Sink	In kitchen first clockwise from cafeteria entry door	FT-72016-011902-A	< 1	FT-72016-011902-B	< 1
5	BANNEKER HIGH SCHOOL	WS- 011906	8/16/2016	Basement	Ice Maker	In kitchen (ice maker)	FT-82016-011906-A	< 1	FT-82016-011906-B	< 1
6	BANNEKER HIGH SCHOOL	WS- 011907	8/16/2016	Basement	Cooler	In hallway across from room 006	FT-82016-011907-A	< 1	FT-82016-011907-B	< 1
7	BANNEKER HIGH SCHOOL	WS- 011908	8/16/2016	Basement	Cooler	In hallway across from fitness center	FT-82016-011908-A	< 1	FT-82016-011908-B	< 1
8	BANNEKER HIGH SCHOOL	WS- 011928	8/16/2016	Basement	Cooler	In hallway adjacent to head custodian's office	FT-82016-011928-A	< 1	FT-82016-011928-B	< 1
9	BANNEKER HIGH SCHOOL	WS- 011929	8/16/2016	1	Cooler	In hallway adjacent to room 102	FT-82016-011929-A	< 1	FT-82016-011929-B	< 1
10	BANNEKER HIGH SCHOOL	WS- 011935	8/16/2016	1	Health Suite	In health suite 112	FT-82016-011935-A	< 1	FT-82016-011935-B	< 1
11	BANNEKER HIGH SCHOOL	WS- 011937	8/16/2016	1	Cooler	In gym	FT-82016-011937-A	< 1	FT-82016-011937-B	< 1
12	BANNEKER HIGH SCHOOL	WS- 011938	8/16/2016	1	Cooler	In gym	FT-82016-011938-A	< 1	FT-82016-011938-B	< 1
13	BANNEKER HIGH SCHOOL	WS- 011939	8/16/2016	1	Cooler	In hallway adjacent to room 113A	FT-82016-011939-A	< 1	FT-82016-011939-B	< 1
14	BANNEKER HIGH SCHOOL	WS- 011940	8/16/2016	1	Cooler	In hallway across from gym	FT-82016-011940-A	< 1	FT-82016-011940-B	< 1
15	BANNEKER HIGH SCHOOL	WS- 011961	8/16/2016	1	Cooler	In hallway adjacent to guidance room 103	FT-82016-011961-A	< 1	FT-82016-011961-B	< 1
16	BANNEKER HIGH SCHOOL	WS- 012497	8/16/2016	2	Cooler	In hallway across from boys' restrooms	FT-82016-012497-A	< 1	FT-82016-012497-B	< 1
17	BANNEKER HIGH SCHOOL	WS- 012498	8/16/2016	2	Cooler	In hallway across from stairwell 3	FT-82016-012498-A	< 1	FT-82016-012498-B	< 1
18	BANNEKER HIGH SCHOOL	WS- 012499	8/16/2016	2	Cooler	In hallway across from stairwell 4	FT-82016-012499-A	< 1	FT-82016-012499-B	< 1
19	BANNEKER HIGH SCHOOL	WS- 012501	8/16/2016	2	Cooler	In hallway adjacent to stairwell 6	FT-82016-012501-A	< 1	FT-82016-012501-B	< 1
20	BANNEKER HIGH SCHOOL	WS- 012503	8/16/2016	3	Cooler	In hallway adjacent to room 305	FT-82016-012503-A	< 1	FT-82016-012503-B	< 1
21	BANNEKER HIGH SCHOOL	WS- 012505	8/16/2016	3	Cooler	In hallway across from stairwell 3	FT-82016-012505-A	< 1	FT-82016-012505-B	< 1
22	BANNEKER HIGH SCHOOL	WS- 012506	8/16/2016	3	Cooler	In hallway across from stairwell 5	FT-82016-012506-A	< 1	FT-82016-012506-B	< 1
23	BANNEKER HIGH SCHOOL	WS- 012526	8/16/2016	3	Cooler	In hallway adjacent to room 306	FT-82016-012526-A	< 1	FT-82016-012526-B	< 1
24	BANNEKER HIGH SCHOOL	WS- 012568	8/16/2016	Basement	Cooler	In fitness center near day care center	FT-82016-012568-A	< 1	FT-82016-012568-B	< 1