



Banneker High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015601	8/9/2021	8/9/2022	1	Break Room	In open area by front entrance	WF-08092021-015601	8/18/2021	FT-FY21-082021-015601-A	<1	FT-FY21-082021-015601-B	<1	
WS-015604	8/9/2021	8/9/2022	1	Combo Fountain	In room A112	WF-08092021-015604	8/18/2021	FT-FY21-082021-015604-A	<1	FT-FY21-082021-015604-B	<1	
WS-015605	8/9/2021	8/9/2022	1	Health Suite	In training room B101	WF-08092021-015605	8/18/2021	FT-FY21-082021-015605-A	<1	FT-FY21-082021-015605-B	<1	
WS-015606	8/9/2021	8/9/2022	1	Bottle Filler	In hallway adjacent to training room B101	WF-08092021-015606	8/18/2021	FT-FY21-082021-015606-A	<1	FT-FY21-082021-015606-B	<1	
WS-015607	8/9/2021	8/9/2022	1	Cooler	In hallway adjacent to training room B101	High Left	WF-08092021-015607	8/18/2021	FT-FY21-082021-015607-A	<1	FT-FY21-082021-015607-B	<1
WS-015608	8/9/2021	8/9/2022	1	Cooler	In hallway adjacent to training room B101	Low Right	WF-08092021-015608	8/18/2021	FT-FY21-082021-015608-A	<1	FT-FY21-082021-015608-B	<1
WS-015610	8/9/2021	8/9/2022	1	Cooler	In cafeteria	High Left	WF-08092021-015610	8/18/2021	FT-FY21-082021-015610-A	<1	FT-FY21-082021-015610-B	<1
WS-015611	8/9/2021	8/9/2022	1	Cooler	In cafeteria	Low Right	WF-08092021-015611	8/18/2021	FT-FY21-082021-015611-A	<1	FT-FY21-082021-015611-B	<1
WS-015622	8/9/2021	8/9/2022	1	Combo Fountain	In parent resource room A125	WF-08092021-015622	8/18/2021	FT-FY21-082021-015622-A	<1	FT-FY21-082021-015622-B	<1	
WS-015623	8/9/2021	8/9/2022	2	Break Room	In teacher collaboration room A207	WF-08092021-015623	8/18/2021	FT-FY21-082021-015623-A	<1	FT-FY21-082021-015623-B	<1	
WS-015624	8/9/2021	8/9/2022	2	Bottle Filler	In hallway adjacent to room B211	WF-08092021-015624	8/18/2021	FT-FY21-082021-015624-A	<1	FT-FY21-082021-015624-B	<1	
WS-015625	8/9/2021	8/9/2022	2	Cooler	In hallway adjacent to room B211	High Left	WF-08092021-015625	8/18/2021	FT-FY21-082021-015625-A	<1	FT-FY21-082021-015625-B	<1
WS-015626	8/9/2021	8/9/2022	2	Cooler	In hallway adjacent to room B211	Low Right	WF-08092021-015626	8/18/2021	FT-FY21-082021-015626-A	<1	FT-FY21-082021-015626-B	<1
WS-015627	8/9/2021	8/9/2022	2	Bottle Filler	In hallway adjacent to room B220	WF-08092021-015627	8/18/2021	FT-FY21-082021-015627-A	<1	FT-FY21-082021-015627-B	<1	
WS-015628	8/9/2021	8/9/2022	2	Cooler	In hallway adjacent to room B220	High Left	WF-08092021-015628	8/18/2021	FT-FY21-082021-015628-A	<1	FT-FY21-082021-015628-B	<1
WS-015629	8/9/2021	8/9/2022	2	Cooler	In hallway adjacent to room B220	Low Right	WF-08092021-015629	8/18/2021	FT-FY21-082021-015629-A	<1	FT-FY21-082021-015629-B	<1
WS-015631	8/9/2021	8/9/2022	2	Health Suite	In health suite room A217A	WF-08092021-015631	8/18/2021	FT-FY21-082021-015631-A	<1	FT-FY21-082021-015631-B	<1	
WS-015632	8/9/2021	8/9/2022	2	Combo Fountain	In health suite room A217A	WF-08092021-015632	8/18/2021	FT-FY21-082021-015632-A	<1	FT-FY21-082021-015632-B	<1	
WS-015634	8/9/2021	8/9/2022	2	Combo Fountain	In classroom A219	WF-08092021-015634	8/18/2021	FT-FY21-082021-015634-A	<1	FT-FY21-082021-015634-B	<1	
WS-015636	8/9/2021	8/9/2022	2	Combo Fountain	In classroom A220	WF-08092021-015636	8/18/2021	FT-FY21-082021-015636-A	<1	FT-FY21-082021-015636-B	<1	
WS-015638	8/9/2021	8/9/2022	2	Combo Fountain	In classroom A226	WF-08092021-015638	8/18/2021	FT-FY21-082021-015638-A	<1	FT-FY21-082021-015638-B	<1	
WS-015640	8/9/2021	8/9/2022	2	Combo Fountain	In classroom A201	Left	WF-08092021-015640	8/18/2021	FT-FY21-082021-015640-A	<1	FT-FY21-082021-015640-B	<1
WS-015642	8/9/2021	8/9/2022	2	Combo Fountain	In classroom A201	Right	WF-08092021-015642	8/18/2021	FT-FY21-082021-015642-A	<1	FT-FY21-082021-015642-B	<1
WS-015643	8/9/2021	8/9/2022	3	Break Room	In teacher collaboration room A307	WF-08092021-015643	8/18/2021	FT-FY21-082021-015643-A	<1	FT-FY21-082021-015643-B	<1	
WS-015645	8/9/2021	8/9/2022	3	Combo Fountain	In classroom A312	WF-08092021-015645	8/18/2021	FT-FY21-082021-015645-A	<1	FT-FY21-082021-015645-B	<1	
WS-015646	8/9/2021	8/9/2022	3	Bottle Filler	In hallway adjacent to stairwell B level 3	WF-08092021-015646	8/18/2021	FT-FY21-082021-015646-A	<1	FT-FY21-082021-015646-B	<1	
WS-015647	8/9/2021	8/9/2022	3	Cooler	In hallway adjacent to stairwell B level 3	High Left	WF-08092021-015647	8/18/2021	FT-FY21-082021-015647-A	<1	FT-FY21-082021-015647-B	<1
WS-015648	8/9/2021	8/9/2022	3	Cooler	In hallway adjacent to stairwell B level 3	Low Right	WF-08092021-015648	8/18/2021	FT-FY21-082021-015648-A	<1	FT-FY21-082021-015648-B	<1
WS-015650	8/9/2021	8/9/2022	3	Combo Fountain	In classroom A318	WF-08092021-015650	8/18/2021	FT-FY21-082021-015650-A	<1	FT-FY21-082021-015650-B	<1	
WS-015651	8/9/2021	8/9/2022	3	Break Room	In staff lounge A320	WF-08092021-015651	8/18/2021	FT-FY21-082021-015651-A	<1	FT-FY21-082021-015651-B	<1	
WS-015653	8/9/2021	8/9/2022	3	Combo Fountain	In wellness/lactation room A321	WF-08092021-015653	8/18/2021	FT-FY21-082021-015653-A	<1	FT-FY21-082021-015653-B	<1	
WS-015654	8/9/2021	8/9/2022	3	Bottle Filler	In hallway adjacent to room A328	WF-08092021-015654	8/18/2021	FT-FY21-082021-015654-A	<1	FT-FY21-082021-015654-B	<1	
WS-015655	8/9/2021	8/9/2022	3	Cooler	In hallway adjacent to room A328	High Left	WF-08092021-015655	8/18/2021	FT-FY21-082021-015655-A	<1	FT-FY21-082021-015655-B	<1
WS-015656	8/9/2021	8/9/2022	3	Cooler	In hallway adjacent to room A328	Low Right	WF-08092021-015656	8/18/2021	FT-FY21-082021-015656-A	<1	FT-FY21-082021-015656-B	<1

WS-015670	8/9/2021	8/9/2022	4	Break Room	In teacher collaboration room A407	WF-08092021-015670	8/18/2021	FT-FY21-082021-015670-A	<1	FT-FY21-082021-015670-B	<1	
WS-015671	8/9/2021	8/9/2022	4	Bottle Filler	In hallway adjacent to stairwell B level 4	WF-08092021-015671	8/18/2021	FT-FY21-082021-015671-A	<1	FT-FY21-082021-015671-B	<1	
WS-015672	8/9/2021	8/9/2022	4	Cooler	In hallway adjacent to stairwell B level 4	High Left	WF-08092021-015672	8/18/2021	FT-FY21-082021-015672-A	<1	FT-FY21-082021-015672-B	<1
WS-015673	8/9/2021	8/9/2022	4	Cooler	In hallway adjacent to stairwell B level 4	Low Right	WF-08092021-015673	8/18/2021	FT-FY21-082021-015673-A	<1	FT-FY21-082021-015673-B	<1
WS-015682	8/9/2021	8/9/2022	4	Bottle Filler	In hallway adjacent to A414		WF-08092021-015682	8/18/2021	FT-FY21-082021-015682-A	<1	FT-FY21-082021-015682-B	<1
WS-015683	8/9/2021	8/9/2022	4	Cooler	In hallway adjacent to A414	High Left	WF-08092021-015683	8/18/2021	FT-FY21-082021-015683-A	<1	FT-FY21-082021-015683-B	<1
WS-015684	8/9/2021	8/9/2022	4	Cooler	In hallway adjacent to A414	Low Right	WF-08092021-015684	8/18/2021	FT-FY21-082021-015684-A	<1	FT-FY21-082021-015684-B	<1
WS-015686	8/9/2021	8/9/2022	4	Combo Fountain	In speech/OT/PT office A417		WF-08092021-015686	8/18/2021	FT-FY21-082021-015686-A	<1	FT-FY21-082021-015686-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015618	8/9/2021	8/9/2022	1	Food Prep Sink	In kitchen 7th clockwise from entry	WF-08092021-015618	8/18/2021	FT-FY21-082021-015618-A	<1	FT-FY21-082021-015618-B	<1
WS-015630	8/9/2021	8/9/2022	2	Food Prep Sink	In concessions B220	WF-08092021-015630	8/18/2021	FT-FY21-082021-015630-A	<1	FT-FY21-082021-015630-B	<1
WS-015725	8/9/2021	8/9/2022	Ground Floor	Food Prep Sink	In outdoor concessions by soccer field	WF-08092021-015725	8/18/2021	FT-FY21-082021-015725-A	<1	FT-FY21-082021-015725-B	<1