



Banneker High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011907	4/19/2021	4/19/2022	Basement	Cooler	In hallway across from room 006	WF-04192021-011907	4/28/2021	FT-FY21-042021-011907-A	<1	FT-FY21-042021-011907-B	<1	
WS- 011908	4/19/2021	4/19/2022	Basement	Cooler	In hallway across from fitness center	WF-04192021-011908	4/28/2021	FT-FY21-042021-011908-A	<1	FT-FY21-042021-011908-B	<1	
WS- 011928	4/19/2021	4/19/2022	Basement	Cooler	In hallway adjacent to head custodian's office	WF-04192021-011928	4/28/2021	FT-FY21-042021-011928-A	<1	FT-FY21-042021-011928-B	<1	
WS- 011929	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to room 102	WF-04192021-011929	4/28/2021	FT-FY21-042021-011929-A	<1	FT-FY21-042021-011929-B	<1	
WS- 011935	4/19/2021	4/19/2022	1	Health Suite	In health suite 112	WF-04192021-011935	4/28/2021	FT-FY21-042021-011935-A	<1	FT-FY21-042021-011935-B	<1	
WS- 011937	4/19/2021	4/19/2022	1	Cooler	In gym	Right	WF-04192021-011937	4/28/2021	FT-FY21-042021-011937-A	<1	FT-FY21-042021-011937-B	<1
WS- 011938	4/19/2021	4/19/2022	1	Cooler	In gym	Left	WF-04192021-011938	4/28/2021	FT-FY21-042021-011938-A	<1	FT-FY21-042021-011938-B	<1
WS- 011961	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to guidance room 103	WF-04192021-011961	4/28/2021	FT-FY21-042021-011961-A	<1	FT-FY21-042021-011961-B	<1	
WS- 012040	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to stairwell 6	WF-04192021-012040	4/28/2021	FT-FY21-042021-012040-A	<1	FT-FY21-042021-012040-B	<1	
WS- 012041	4/19/2021	4/19/2022	2	Bottle Filler	In hallway adjacent to stairwell 6	WF-04192021-012041	4/28/2021	FT-FY21-042021-012041-A	<1	FT-FY21-042021-012041-B	<1	
WS- 012042	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to stairwell 1	WF-04192021-012042	4/28/2021	FT-FY21-042021-012042-A	<1	FT-FY21-042021-012042-B	<1	
WS- 012043	4/19/2021	4/19/2022	2	Bottle Filler	In hallway adjacent to stairwell 1	WF-04192021-012043	4/28/2021	FT-FY21-042021-012043-A	<1	FT-FY21-042021-012043-B	<1	
WS- 012046	4/19/2021	4/19/2022	2	Combo Fountain	In media center work room	WF-04192021-012046	4/28/2021	FT-FY21-042021-012046-A	<1	FT-FY21-042021-012046-B	<1	
WS- 012499	4/19/2021	4/19/2022	2	Cooler	In hallway across from stairwell 4	WF-04192021-012499	4/28/2021	FT-FY21-042021-012499-A	<1	FT-FY21-042021-012499-B	<1	
WS- 012500	4/19/2021	4/19/2022	2	Break Room	In staff lounge in restroom	WF-04192021-012500	4/28/2021	FT-FY21-042021-012500-A	<1	FT-FY21-042021-012500-B	<1	
WS- 012503	4/19/2021	4/19/2022	3	Cooler	In hallway adjacent to room 305	WF-04192021-012503	4/28/2021	FT-FY21-042021-012503-A	<1	FT-FY21-042021-012503-B	<1	
WS- 012506	4/19/2021	4/19/2022	3	Cooler	In hallway across from stairwell 5	WF-04192021-012506	4/28/2021	FT-FY21-042021-012506-A	<1	FT-FY21-042021-012506-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011902	1/5/2021	1/5/2022	Basement	Food Prep Sink	In kitchen first clockwise from cafeteria entry door	WF-01052021-011902	4/28/2021	FT-FY21-042021-011902-A	<1	FT-FY21-042021-011902-B	<1