



Banneker High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015601	5/15/2023	5/15/2024	1	Break Room	In open area by front entrance	WF-05152023-015601	1/10/2024	FT-FY24-11012023-015601-A	<1	FT-FY24-11012023-015601-B	<1	
WS-015604	5/15/2023	5/15/2024	1	Combo Fountain	In room A112	WF-05152023-015604	1/10/2024	FT-FY24-11012023-015604-A	<1	FT-FY24-11012023-015604-B	<1	
WS-015605	5/15/2023	5/15/2024	1	Health Suite	In training room B101	WF-05152023-015605	1/10/2024	FT-FY24-11012023-015605-A	<1	FT-FY24-11012023-015605-B	<1	
WS-015606	5/15/2023	5/15/2024	1	Bottle Filler	In hallway adjacent to training room B101	WF-05152023-015606	1/10/2024	FT-FY24-11012023-015606-A	<1	FT-FY24-11012023-015606-B	<1	
WS-015607	5/15/2023	5/15/2024	1	Cooler	In hallway adjacent to training room B101	High Left	WF-05152023-015607	1/10/2024	FT-FY24-11012023-015607-A	<1	FT-FY24-11012023-015607-B	<1
WS-015608	5/15/2023	5/15/2024	1	Cooler	In hallway adjacent to training room B101	Low Right	WF-05152023-015608	1/10/2024	FT-FY24-11012023-015608-A	<1	FT-FY24-11012023-015608-B	<1
WS-015609	5/15/2023	5/15/2024	1	Bottle Filler	In cafeteria	WF-05152023-015609	1/10/2024	FT-FY24-11012023-015609-A	<1	FT-FY24-11012023-015609-B	<1	
WS-015610	5/15/2023	5/15/2024	1	Cooler	In cafeteria	High Left	WF-05152023-015610	1/10/2024	FT-FY24-11012023-015610-A	<1	FT-FY24-11012023-015610-B	<1
WS-015611	5/15/2023	5/15/2024	1	Cooler	In cafeteria	Low Right	WF-05152023-015611	1/10/2024	FT-FY24-11012023-015611-A	<1	FT-FY24-11012023-015611-B	<1
WS-015622	5/15/2023	5/15/2024	1	Combo Fountain	In parent resource room A125	WF-05152023-015622	1/10/2024	FT-FY24-11012023-015622-A	<1	FT-FY24-11012023-015622-B	<1	
WS-015623	5/15/2023	5/15/2024	2	Break Room	In teacher collaboration room A207	WF-05152023-015623	1/10/2024	FT-FY24-11012023-015623-A	<1	FT-FY24-11012023-015623-B	<1	
WS-015624	5/15/2023	5/15/2024	2	Bottle Filler	In hallway adjacent to room B211	WF-05152023-015624	1/10/2024	FT-FY24-11012023-015624-A	<1	FT-FY24-11012023-015624-B	<1	
WS-015625	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room B211	High Left	WF-05152023-015625	1/10/2024	FT-FY24-11012023-015625-A	<1	FT-FY24-11012023-015625-B	<1
WS-015626	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room B211	Low Right	WF-05152023-015626	1/10/2024	FT-FY24-11012023-015626-A	<1	FT-FY24-11012023-015626-B	<1
WS-015628	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room B220	High Left	WF-05152023-015628	1/10/2024	FT-FY24-11012023-015628-A	<1	FT-FY24-11012023-015628-B	<1
WS-015631	5/15/2023	5/15/2024	2	Health Suite	In health suite room A217A	WF-05152023-015631	1/10/2024	FT-FY24-11012023-015631-A	<1	FT-FY24-11012023-015631-B	<1	
WS-015632	5/15/2023	5/15/2024	2	Combo Fountain	In health suite room A217A	WF-05152023-015632	1/10/2024	FT-FY24-11012023-015632-A	<1	FT-FY24-11012023-015632-B	<1	
WS-015634	5/15/2023	5/15/2024	2	Combo Fountain	In classroom A219	WF-05152023-015634	1/10/2024	FT-FY24-11012023-015634-A	<1	FT-FY24-11012023-015634-B	<1	
WS-015636	5/15/2023	5/15/2024	2	Combo Fountain	In classroom A220	WF-05152023-015636	1/10/2024	FT-FY24-11012023-015636-A	<1	FT-FY24-11012023-015636-B	<1	
WS-015638	5/15/2023	5/15/2024	2	Combo Fountain	In classroom A226	WF-05152023-015638	1/10/2024	FT-FY24-11012023-015638-A	<1	FT-FY24-11012023-015638-B	<1	
WS-015640	5/15/2023	5/15/2024	2	Combo Fountain	In classroom A201	Left	WF-05152023-015640	1/10/2024	FT-FY24-11012023-015640-A	<1	FT-FY24-11012023-015640-B	<1
WS-015642	5/15/2023	5/15/2024	2	Combo Fountain	In classroom A201	Right	WF-05152023-015642	1/10/2024	FT-FY24-11012023-015642-A	<1	FT-FY24-11012023-015642-B	<1
WS-015643	5/15/2023	5/15/2024	3	Break Room	In teacher collaboration room A307	WF-05152023-015643	1/10/2024	FT-FY24-11012023-015643-A	<1	FT-FY24-11012023-015643-B	<1	
WS-015645	5/15/2023	5/15/2024	3	Combo Fountain	In classroom A312	WF-05152023-015645	1/10/2024	FT-FY24-11012023-015645-A	<1	FT-FY24-11012023-015645-B	<1	
WS-015646	5/15/2023	5/15/2024	3	Bottle Filler	In hallway adjacent to stairwell B level 3	WF-05152023-015646	1/10/2024	FT-FY24-11012023-015646-A	<1	FT-FY24-11012023-015646-B	<1	
WS-015647	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to stairwell B level 3	High Left	WF-05152023-015647	1/10/2024	FT-FY24-11012023-015647-A	<1	FT-FY24-11012023-015647-B	<1
WS-015648	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to stairwell B level 3	Low Right	WF-05152023-015648	1/10/2024	FT-FY24-11012023-015648-A	<1	FT-FY24-11012023-015648-B	<1
WS-015650	5/15/2023	5/15/2024	3	Combo Fountain	In classroom A318	WF-05152023-015650	1/10/2024	FT-FY24-11012023-015650-A	2.5	FT-FY24-11012023-015650-B	1.1	
WS-015651	5/15/2023	5/15/2024	3	Break Room	In staff lounge A320	WF-05152023-015651	1/10/2024	FT-FY24-11012023-015651-A	<1	FT-FY24-11012023-015651-B	<1	
WS-015654	5/15/2023	5/15/2024	3	Bottle Filler	In hallway adjacent to room A328	WF-05152023-015654	1/10/2024	FT-FY24-11012023-015654-A	<1	FT-FY24-11012023-015654-B	<1	
WS-015655	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room A328	High Left	WF-05152023-015655	1/10/2024	FT-FY24-11012023-015655-A	<1	FT-FY24-11012023-015655-B	<1
WS-015656	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room A328	Low Right	WF-05152023-015656	1/10/2024	FT-FY24-11012023-015656-A	<1	FT-FY24-11012023-015656-B	<1
WS-015670	5/15/2023	5/15/2024	4	Break Room	In teacher collaboration room A407	WF-05152023-015670	1/10/2024	FT-FY24-11012023-015670-A	1.7	FT-FY24-11012023-015670-B	<1	
WS-015671	5/15/2023	5/15/2024	4	Bottle Filler	In hallway adjacent to stairwell B level 4	WF-05152023-015671	1/10/2024	FT-FY24-11012023-015671-A	<1	FT-FY24-11012023-015671-B	<1	
WS-015672	5/15/2023	5/15/2024	4	Cooler	In hallway adjacent to stairwell B level 4	High Left	WF-05152023-015672	1/10/2024	FT-FY24-11012023-015672-A	<1	FT-FY24-11012023-015672-B	<1

WS-015673	5/15/2023	5/15/2024	4	Cooler	In hallway adjacent to stairwell B level 4	Low Right	WF-05152023-015673	1/10/2024	FT-FY24-11012023-015673-A	<1	FT-FY24-11012023-015673-B	<1
WS-015682	5/15/2023	5/15/2024	4	Bottle Filler	In hallway adjacent to A414		WF-05152023-015682	1/10/2024	FT-FY24-11012023-015682-A	<1	FT-FY24-11012023-015682-B	<1
WS-015683	5/15/2023	5/15/2024	4	Cooler	In hallway adjacent to A414	High Left	WF-05152023-015683	1/10/2024	FT-FY24-11012023-015683-A	<1	FT-FY24-11012023-015683-B	<1
WS-015684	5/15/2023	5/15/2024	4	Cooler	In hallway adjacent to A414	Low Right	WF-05152023-015684	1/10/2024	FT-FY24-11012023-015684-A	<1	FT-FY24-11012023-015684-B	<1
WS-015686	5/15/2023	5/15/2024	4	Combo Fountain	In speech/OT/PT office A417		WF-05152023-015686	1/10/2024	FT-FY24-11012023-015686-A	1.2	FT-FY24-11012023-015686-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015618	1/25/2023	1/25/2024	1	Food Prep Sink	In kitchen 7th clockwise from entry	WF-01252023-015618	1/10/2024	FT-FY24-11012023-015618-A	<1	FT-FY24-11012023-015618-B	<1
WS-015630	1/25/2023	1/25/2024	2	Food Prep Sink	In concessions B220	WF-01252023-015630	1/10/2024	FT-FY24-11012023-015630-A	<1	FT-FY24-11012023-015630-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015653	5/15/2023	5/15/2024	3	Combo Fountain	In wellness/lactation room A321	WF-05152023-015653	1/10/2024	FT-FY24-11012023-015653-A	6.5	FT-FY24-11012023-015653-B	<1

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015653	1/12/2024	1/12/2025	3	Combo Fountain	In wellness/lactation room A321	WF-01122024-015653	1/25/2024	FT-FY24-01122024-015653-A	<1	FT-FY24-01122024-015653-B	<1