



Banneker High School Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015601	4/29/2025	4/29/2026	1	Break Room	In open area by front entrance	WF-04292025-015601	12/17/2025	FT-FY26-12082025-015601-A	<2	FT-FY26-12082025-015601-B	<2	
WS-015604	4/29/2025	4/29/2026	1	Combo Fountain	In room A112	WF-04292025-015604	12/17/2025	FT-FY26-12082025-015604-A	<2	FT-FY26-12082025-015604-B	<2	
WS-015605	4/29/2025	4/29/2026	1	Health Suite	In training room B101	WF-04292025-015605	12/17/2025	FT-FY26-12082025-015605-A	<2	FT-FY26-12082025-015605-B	<2	
WS-015606	4/29/2025	4/29/2026	1	Bottle Filler	In hallway adjacent to training room B101	WF-04292025-015606	12/17/2025	FT-FY26-12082025-015606-A	<2	FT-FY26-12082025-015606-B	<2	
WS-015607	4/29/2025	4/29/2026	1	Cooler	In hallway adjacent to training room B101	High Left	WF-04292025-015607	12/17/2025	FT-FY26-12082025-015607-A	<2	FT-FY26-12082025-015607-B	<2
WS-015608	4/29/2025	4/29/2026	1	Cooler	In hallway adjacent to training room B101	Low Right	WF-04292025-015608	12/17/2025	FT-FY26-12082025-015608-A	<2	FT-FY26-12082025-015608-B	<2
WS-015609	4/29/2025	4/29/2026	1	Bottle Filler	In cafeteria	WF-04292025-015609	12/17/2025	FT-FY26-12082025-015609-A	<2	FT-FY26-12082025-015609-B	<2	
WS-015610	4/29/2025	4/29/2026	1	Cooler	In cafeteria	High Left	WF-04292025-015610	12/17/2025	FT-FY26-12082025-015610-A	<2	FT-FY26-12082025-015610-B	<2
WS-015611	4/29/2025	4/29/2026	1	Cooler	In cafeteria	Low Right	WF-04292025-015611	12/17/2025	FT-FY26-12082025-015611-A	<2	FT-FY26-12082025-015611-B	<2
WS-015622	4/29/2025	4/29/2026	1	Combo Fountain	In parent resource room A125	WF-04292025-015622	12/17/2025	FT-FY26-12082025-015622-A	<2	FT-FY26-12082025-015622-B	<2	
WS-015623	4/29/2025	4/29/2026	2	Break Room	In teacher collaboration room A207	WF-04292025-015623	12/17/2025	FT-FY26-12082025-015623-A	<2	FT-FY26-12082025-015623-B	<2	
WS-015624	4/29/2025	4/29/2026	2	Bottle Filler	In hallway adjacent to room B211	WF-04292025-015624	12/17/2025	FT-FY26-12082025-015624-A	<2	FT-FY26-12082025-015624-B	<2	
WS-015625	4/29/2025	4/29/2026	2	Cooler	In hallway adjacent to room B211	High Left	WF-04292025-015625	12/17/2025	FT-FY26-12082025-015625-A	<2	FT-FY26-12082025-015625-B	<2
WS-015626	4/29/2025	4/29/2026	2	Cooler	In hallway adjacent to room B211	Low Right	WF-04292025-015626	12/17/2025	FT-FY26-12082025-015626-A	<2	FT-FY26-12082025-015626-B	<2
WS-015627	4/29/2025	4/29/2026	2	Bottle Filler	In hallway adjacent to room B220	WF-04292025-015627	12/17/2025	FT-FY26-12082025-015627-A	<2	FT-FY26-12082025-015627-B	<2	
WS-015628	4/29/2025	4/29/2026	2	Cooler	In hallway adjacent to room B220	High Left	WF-04292025-015628	12/17/2025	FT-FY26-12082025-015628-A	<2	FT-FY26-12082025-015628-B	<2
WS-015629	4/29/2025	4/29/2026	2	Cooler	In hallway adjacent to room B220	Low Right	WF-04292025-015629	12/17/2025	FT-FY26-12082025-015629-A	<2	FT-FY26-12082025-015629-B	<2
WS-015631	4/29/2025	4/29/2026	2	Health Suite	In health suite room A217A	WF-04292025-015631	12/17/2025	FT-FY26-12082025-015631-A	4.5	FT-FY26-12082025-015631-B	<2	
WS-015632	4/29/2025	4/29/2026	2	Combo Fountain	In health suite room A217A	WF-04292025-015632	12/17/2025	FT-FY26-12082025-015632-A	<2	FT-FY26-12082025-015632-B	<2	
WS-015634	4/29/2025	4/29/2026	2	Combo Fountain	In classroom A219	WF-04292025-015634	12/17/2025	FT-FY26-12082025-015634-A	4.2	FT-FY26-12082025-015634-B	<2	
WS-015636	4/29/2025	4/29/2026	2	Combo Fountain	In classroom A220	WF-04292025-015636	12/17/2025	FT-FY26-12082025-015636-A	<2	FT-FY26-12082025-015636-B	<2	
WS-015640	4/29/2025	4/29/2026	2	Combo Fountain	In classroom A201	Left	WF-04292025-015640	12/17/2025	FT-FY26-12082025-015640-A	<2	FT-FY26-12082025-015640-B	<2
WS-015642	4/29/2025	4/29/2026	2	Combo Fountain	In classroom A201	Right	WF-04292025-015642	12/17/2025	FT-FY26-12082025-015642-A	<2	FT-FY26-12082025-015642-B	<2
WS-015643	4/29/2025	4/29/2026	3	Break Room	In teacher collaboration room A307	WF-04292025-015643	12/17/2025	FT-FY26-12082025-015643-A	<2	FT-FY26-12082025-015643-B	<2	
WS-015645	4/29/2025	4/29/2026	3	Combo Fountain	In classroom A312	WF-04292025-015645	12/17/2025	FT-FY26-12082025-015645-A	<2	FT-FY26-12082025-015645-B	<2	
WS-015646	4/29/2025	4/29/2026	3	Bottle Filler	In hallway adjacent to stairwell B level 3	WF-04292025-015646	12/17/2025	FT-FY26-12082025-015646-A	<2	FT-FY26-12082025-015646-B	<2	
WS-015647	4/29/2025	4/29/2026	3	Cooler	In hallway adjacent to stairwell B level 3	High Left	WF-04292025-015647	12/17/2025	FT-FY26-12082025-015647-A	<2	FT-FY26-12082025-015647-B	<2
WS-015648	4/29/2025	4/29/2026	3	Cooler	In hallway adjacent to stairwell B level 3	Low Right	WF-04292025-015648	12/17/2025	FT-FY26-12082025-015648-A	<2	FT-FY26-12082025-015648-B	<2
WS-015650	4/29/2025	4/29/2026	3	Combo Fountain	In classroom A318	WF-04292025-015650	12/17/2025	FT-FY26-12082025-015650-A	<2	FT-FY26-12082025-015650-B	<2	
WS-015651	4/29/2025	4/29/2026	3	Break Room	In staff lounge A320	WF-04292025-015651	12/17/2025	FT-FY26-12082025-015651-A	<2	FT-FY26-12082025-015651-B	<2	
WS-015653	4/29/2025	4/29/2026	3	Combo Fountain	In wellness/lactation room A321	WF-04292025-015653	12/17/2025	FT-FY26-12082025-015653-A	<2	FT-FY26-12082025-015653-B	<2	
WS-015654	4/29/2025	4/29/2026	3	Bottle Filler	In hallway adjacent to room A328	WF-04292025-015654	12/17/2025	FT-FY26-12082025-015654-A	<2	FT-FY26-12082025-015654-B	<2	
WS-015655	4/29/2025	4/29/2026	3	Cooler	In hallway adjacent to room A328	High Left	WF-04292025-015655	12/17/2025	FT-FY26-12082025-015655-A	<2	FT-FY26-12082025-015655-B	<2
WS-015656	4/29/2025	4/29/2026	3	Cooler	In hallway adjacent to room A328	Low Right	WF-04292025-015656	12/17/2025	FT-FY26-12082025-015656-A	<2	FT-FY26-12082025-015656-B	<2

WS-015670	4/29/2025	4/29/2026	4	Break Room	In teacher collaboration room A407	WF-04292025-015670	12/17/2025	FT-FY26-12082025-015670-A	<2	FT-FY26-12082025-015670-B	<2	
WS-015671	4/29/2025	4/29/2026	4	Bottle Filler	In hallway adjacent to stairwell B level 4	WF-04292025-015671	12/17/2025	FT-FY26-12082025-015671-A	<2	FT-FY26-12082025-015671-B	<2	
WS-015672	4/29/2025	4/29/2026	4	Cooler	In hallway adjacent to stairwell B level 4	High Left	WF-04292025-015672	12/17/2025	FT-FY26-12082025-015672-A	<2	FT-FY26-12082025-015672-B	<2
WS-015673	4/29/2025	4/29/2026	4	Cooler	In hallway adjacent to stairwell B level 4	Low Right	WF-04292025-015673	12/17/2025	FT-FY26-12082025-015673-A	<2	FT-FY26-12082025-015673-B	<2
WS-015682	4/29/2025	4/29/2026	4	Bottle Filler	In hallway adjacent to A414	WF-04292025-015682	12/17/2025	FT-FY26-12082025-015682-A	<2	FT-FY26-12082025-015682-B	<2	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015630	11/24/2025	11/24/2026	2	Food Prep Sink	In concessions B220	WF-11242025-015630	12/17/2025	FT-FY26-12082025-015630-A	1.3	FT-FY26-12082025-015630-B	<2
WS-015618	11/24/2025	11/24/2026	1	Food Prep Sink	In kitchen 7th clockwise from entry	WF-11242025-015618	12/17/2025	FT-FY26-12082025-015618-A	<2	FT-FY26-12082025-015618-B	<2

FY26 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015638	4/29/2025	4/29/2026	2	Combo Fountain	In classroom A226	WF-04292025-015638	12/17/2025	FT-FY26-12082025-015638-A	8.5	FT-FY26-12082025-015638-B	<2

First Re-Test (After Plumbing Check)

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015638	12/19/2025	12/19/2026	2	Combo Fountain	In classroom A226	WF-12192025-015638	1/19/2026	FT-FY26-12192025-015638-A	<2	FT-FY26-12192025-015638-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.