



BANNEKER LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	BANNEKER HIGH SCHOOL	5/17/2016	WS-012528	Other	2	In classroom library in dark room (rounded black door)	WT-042916-12545-A	58.2	WT-042916-12545-B	< 1	Filter will be installed and then retested			
2	BANNEKER HIGH SCHOOL	5/17/2016	WS-012527	Classroom	3	In classroom 302	WT-042916-12544-A	< 1	WT-042916-12544-B	< 1				
3	BANNEKER HIGH SCHOOL	5/17/2016	WS-012526	Cooler	3	In third floor hallway adjacent to classroom 306	WT-042916-12543-A	< 1	WT-042916-12543-B	< 1				
4	BANNEKER HIGH SCHOOL	5/17/2016	WS-012525	Classroom	3	In classroom 321 (mobile sink)	WT-042916-12542-A		WT-042916-12542-B					
5	BANNEKER HIGH SCHOOL	5/17/2016	WS-012524	Classroom	3	In classroom 321 biology (ninth sink clockwise from door) Left	WT-042916-12541-A	< 1	WT-042916-12541-B	< 1				
6	BANNEKER HIGH SCHOOL	5/17/2016	WS-012523	Classroom	3	In classroom 321 biology (ninth sink clockwise from door) Right	WT-042916-12540-A	< 1	WT-042916-12540-B	< 1				
7	BANNEKER HIGH SCHOOL	5/17/2016	WS-012522	Classroom	3	In classroom 321 biology (eighth sink clockwise from door) Left	WT-042916-12539-A	< 1	WT-042916-12539-B	< 1				
8	BANNEKER HIGH SCHOOL	5/17/2016	WS-012521	Classroom	3	In classroom 321 biology (eighth sink clockwise from door) Right	WT-042916-12538-A	< 1	WT-042916-12538-B	< 1				
9	BANNEKER HIGH SCHOOL	5/17/2016	WS-012520	Classroom	3	In classroom 321 biology (seventh sink clockwise from door) Left	WT-042916-12537-A	< 1	WT-042916-12537-B	< 1				
10	BANNEKER HIGH SCHOOL	5/17/2016	WS-012519	Classroom	3	In classroom 321 biology (seventh sink clockwise from door) Right	WT-042916-12536-A	1.9	WT-042916-12536-B	< 1				
11	BANNEKER HIGH SCHOOL	5/17/2016	WS-012518	Classroom	3	In classroom 321 biology (sixth sink clockwise from door) Left	WT-042916-12535-A	< 1	WT-042916-12535-B	2.1				
12	BANNEKER HIGH SCHOOL	5/17/2016	WS-012517	Classroom	3	In classroom 321 biology (sixth sink clockwise from door) Right	WT-042916-12534-A	< 1	WT-042916-12534-B	1.4				
13	BANNEKER HIGH SCHOOL	5/17/2016	WS-012516	Classroom	3	In classroom 321 biology in office	WT-042916-12533-A	6.1	WT-042916-12533-B	3.9				
14	BANNEKER HIGH SCHOOL	5/17/2016	WS-012515	Classroom	3	In classroom 321 biology (fifth sink clockwise from door) Right	WT-042916-12532-A	< 1	WT-042916-12532-B	< 1				
15	BANNEKER HIGH SCHOOL	5/17/2016	WS-012514	Classroom	3	In classroom 321 biology (fifth sink clockwise from door) Left	WT-042916-12531-A	< 1	WT-042916-12531-B	< 1				
16	BANNEKER HIGH SCHOOL	5/17/2016	WS-012513	Classroom	3	In classroom 321 biology (fourth sink clockwise from door) Right	WT-042916-12530-A	1.7	WT-042916-12530-B	< 1				
17	BANNEKER HIGH SCHOOL	5/17/2016	WS-012512	Classroom	3	In classroom 321 biology (fourth sink clockwise from door) Left	WT-042916-12529-A	1.7	WT-042916-12529-B	< 1				
18	BANNEKER HIGH SCHOOL	5/17/2016	WS-012511	Classroom	3	In classroom 321 biology (third sink clockwise from door) Right	WT-042916-12528-A	< 1	WT-042916-12528-B	< 1				
19	BANNEKER HIGH SCHOOL	5/17/2016	WS-012510	Classroom	3	In classroom 321 biology (third sink clockwise from door) Left	WT-042916-12527-A	1.5	WT-042916-12527-B	1				
20	BANNEKER HIGH SCHOOL	5/17/2016	WS-012509	Classroom	3	In classroom 321 biology (second sink clockwise from door) Right	WT-042916-12526-A	< 1	WT-042916-12526-B	3.6				
21	BANNEKER HIGH SCHOOL	5/17/2016	WS-012508	Classroom	3	In classroom 321 biology (second sink clockwise from door) Left	WT-042916-12525-A	< 1	WT-042916-12525-B	< 1				
22	BANNEKER HIGH SCHOOL	5/17/2016	WS-012507	Classroom	3	In classroom 321 biology (first sink clockwise from door)	WT-042916-12524-A	3.5	WT-042916-12524-B	14.8				
23	BANNEKER HIGH SCHOOL	5/17/2016	WS-012506	Cooler	3	In hallway across from stairwell 5	WT-042916-12523-A	< 1	WT-042916-12523-B	< 1				
24	BANNEKER HIGH SCHOOL	5/17/2016	WS-012505	Cooler	3	In hallway across from stairwell 3	WT-042916-12522-A	< 1	WT-042916-12522-B	< 1				
25	BANNEKER HIGH SCHOOL	5/17/2016	WS-012504	Classroom	3	In classroom 309	WT-042916-12521-A		WT-042916-12521-B					
26	BANNEKER HIGH SCHOOL	5/17/2016	WS-012503	Cooler	3	In hallway adjacent to classroom 305	WT-042916-12520-A	< 1	WT-042916-12520-B	< 1				
27	BANNEKER HIGH SCHOOL	5/17/2016	WS-012502	Classroom	2	In library in office	WT-042916-12519-A	114	WT-042916-12519-B	< 1	Filter will be installed and then retested			
28	BANNEKER HIGH SCHOOL	5/17/2016	WS-012501	Cooler	2	In hallway across from elevator	WT-042916-12518-A	< 1	WT-042916-12518-B	< 1				
29	BANNEKER HIGH SCHOOL	5/17/2016	WS-012500	Break Room	2	In teachers lounge in restroom	WT-042916-12517-A	< 1	WT-042916-12517-B	< 1				
30	BANNEKER HIGH SCHOOL	5/17/2016	WS-012499	Cooler	2	In second floor hallway across from stairwell 4	WT-042916-12516-A	< 1	WT-042916-12516-B	< 1				
31	BANNEKER HIGH SCHOOL	5/17/2016	WS-012498	Cooler	2	In second floor hallway across from stairwell 3	WT-042916-12515-A	< 1	WT-042916-12515-B	< 1				
32	BANNEKER HIGH SCHOOL	5/17/2016	WS-012497	Cooler	2	In hallway across from men's room	WT-042916-12514-A	< 1	WT-042916-12514-B	< 1				
33	BANNEKER HIGH SCHOOL	5/17/2016	WS-011961	Cooler	1	In hallway adjacent to room 103 guidance suite	WT-042916-11978-A	< 1	WT-042916-11978-B	< 1				
34	BANNEKER HIGH SCHOOL	5/17/2016	WS-011960	Classroom	1	In room 105 vestibule Left	WT-042916-11977-A	3.1	WT-042916-11977-B	< 1				



BANNEKER LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
35 BANNEKER HIGH SCHOOL	5/17/2016	WS-011959	Classroom	1	In room 105 prep room Mid	WT-042916-11976-A	79	WT-042916-11976-B	2	Filter will be installed and then retested			
36 BANNEKER HIGH SCHOOL	5/17/2016	WS-011958	Classroom	1	In room 105 prep room Right	WT-042916-11975-A	26.4	WT-042916-11975-B	< 1	Filter will be installed and then retested			
37 BANNEKER HIGH SCHOOL	5/17/2016	WS-011957	Classroom	1	In classroom 105 (eighth sink clockwise from door)	WT-042916-11974-A	5.8	WT-042916-11974-B	< 1				
38 BANNEKER HIGH SCHOOL	5/17/2016	WS-011956	Classroom	1	In classroom 105 (seventh sink clockwise from door) Left	WT-042916-11973-A	2	WT-042916-11973-B	< 1				
39 BANNEKER HIGH SCHOOL	5/17/2016	WS-011955	Classroom	1	In classroom 105 (seventh sink clockwise from door) Right	WT-042916-11972-A	3.1	WT-042916-11972-B	< 1				
40 BANNEKER HIGH SCHOOL	5/17/2016	WS-011954	Classroom	1	In classroom 105 (sixth sink clockwise from door) Left	WT-042916-11971-A	3.6	WT-042916-11971-B	< 1				
41 BANNEKER HIGH SCHOOL	5/17/2016	WS-011953	Classroom	1	In classroom 105 (sixth sink clockwise from door) Right	WT-042916-11970-A	3.1	WT-042916-11970-B	< 1				
42 BANNEKER HIGH SCHOOL	5/17/2016	WS-011952	Classroom	1	In classroom 105 (fifth sink clockwise from door) Left	WT-042916-11969-A	2.7	WT-042916-11969-B	< 1				
43 BANNEKER HIGH SCHOOL	5/17/2016	WS-011951	Classroom	1	In classroom 105 (fifth sink clockwise from door) Right	WT-042916-11968-A	6.5	WT-042916-11968-B	1				
44 BANNEKER HIGH SCHOOL	5/17/2016	WS-011950	Classroom	1	In classroom 105 (fourth sink clockwise from door) Right	WT-042916-11967-A	27.4	WT-042916-11967-B	< 1	Filter will be installed and then retested			
45 BANNEKER HIGH SCHOOL	5/17/2016	WS-011949	Classroom	1	In classroom 105 (fourth sink clockwise from door) Left	WT-042916-11966-A	11.8	WT-042916-11966-B	1.1				
46 BANNEKER HIGH SCHOOL	5/17/2016	WS-011948	Classroom	1	In classroom 105 (tap in oven)	WT-042916-11965-A		WT-042916-11965-B					
47 BANNEKER HIGH SCHOOL	5/17/2016	WS-011947	Classroom	1	In classroom 105 (third sink clockwise from door) Left	WT-042916-11964-A	5.4	WT-042916-11964-B	< 1				
48 BANNEKER HIGH SCHOOL	5/17/2016	WS-011946	Classroom	1	In classroom 105 (third sink clockwise from door) Right	WT-042916-11963-A	4.9	WT-042916-11963-B	1				
49 BANNEKER HIGH SCHOOL	5/17/2016	WS-011945	Classroom	1	In classroom 105 (second sink clockwise from door) Left	WT-042916-11962-A	3.8	WT-042916-11962-B	< 1				
50 BANNEKER HIGH SCHOOL	5/17/2016	WS-011944	Classroom	1	In classroom 105 (second sink clockwise from door) Right	WT-042916-11961-A	36.7	WT-042916-11961-B	5.3	Filter will be installed and then retested			
51 BANNEKER HIGH SCHOOL	5/17/2016	WS-011943	Classroom	1	In classroom 105 (first sink clockwise from door) Left	WT-042916-11960-A	3.9	WT-042916-11960-B	< 1				
52 BANNEKER HIGH SCHOOL	5/17/2016	WS-011942	Classroom	1	In classroom 105 (first sink clockwise from door) Right	WT-042916-11959-A	4.3	WT-042916-11959-B	1.3				
53 BANNEKER HIGH SCHOOL	5/18/2016	WS-011941	Classroom	1	In classroom 105 on island	WT-042916-11958-A	1.8	WT-042916-11958-B	< 1				
54 BANNEKER HIGH SCHOOL	5/17/2016	WS-011940	Cooler	1	In first floor hallway across from gymnasium	WT-042916-11957-A	< 1	WT-042916-11957-B	< 1				
55 BANNEKER HIGH SCHOOL	5/17/2016	WS-011939	Cooler	1	In first floor hallway adjacent to room 113 A	WT-042916-11956-A	< 1	WT-042916-11956-B	< 1				
56 BANNEKER HIGH SCHOOL	5/17/2016	WS-011938	Cooler	1	In gymnasium (first cooler clockwise from door)	WT-042916-11955-A	< 1	WT-042916-11955-B	< 1				
57 BANNEKER HIGH SCHOOL	5/17/2016	WS-011937	Cooler	1	In gymnasium (second cooler clockwise from door)	WT-042916-11954-A	< 1	WT-042916-11954-B	< 1				
58 BANNEKER HIGH SCHOOL	5/17/2016	WS-011936	Classroom	1	In classroom 104 (fourth sink clockwise from door)	WT-042916-11953-A	1.9	WT-042916-11953-B	< 1				
59 BANNEKER HIGH SCHOOL	5/17/2016	WS-011935	Classroom	1	In health room 112	WT-042916-11952-A	2.2	WT-042916-11952-B	7.5				
60 BANNEKER HIGH SCHOOL	5/17/2016	WS-011934	Classroom	1	In classroom 104 (third sink clockwise from door)	WT-042916-11951-A	< 1	WT-042916-11951-B	< 1				
61 BANNEKER HIGH SCHOOL	5/17/2016	WS-011933	Classroom	1	In classroom 104 (second sink clockwise from door)	WT-042916-11950-A	3.3	WT-042916-11950-B	< 1				
62 BANNEKER HIGH SCHOOL	5/17/2016	WS-011932	Classroom	1	In classroom 104 (first sink clockwise from door)	WT-042916-11949-A	3.5	WT-042916-11949-B	< 1				
63 BANNEKER HIGH SCHOOL	5/17/2016	WS-011931	Classroom	1	In classroom 106 Right	WT-042916-11948-A	< 1	WT-042916-11948-B	< 1				



BANNEKER LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
64 BANNEKER HIGH SCHOOL	5/17/2016	WS-011930	Utility	1	In classroom 106 Left	WT-042916-11947- A	< 1	WT-042916-11947- B	< 1				
65 BANNEKER HIGH SCHOOL	5/17/2016	WS-011929	Cooler	1	In first floor hallway adjacent to room 102 principal's office	WT-042916-11946- A	< 1	WT-042916-11946- B	< 1				
66 BANNEKER HIGH SCHOOL	5/17/2016	WS-011928	Cooler	Basement	In basement hallway adjacent to head custodian's office	WT-042916-11945- A	< 1	WT-042916-11945- B	< 1				
67 BANNEKER HIGH SCHOOL	5/17/2016	WS-011927	Classroom	Basement	In classroom 005 on island	WT-042916-11944- A	18.6	WT-042916-11944- B	1.4	Filter will be installed and then retested			
68 BANNEKER HIGH SCHOOL	5/17/2016	WS-011926	Classroom	Basement	In classroom 005 (in office) Right	WT-042916-11943- A	141	WT-042916-11943- B	2.7	Filter will be installed and then retested			
69 BANNEKER HIGH SCHOOL	5/17/2016	WS-011925	Classroom	Basement	In classroom 005 (in office) Mid	WT-042916-11942- A	136	WT-042916-11942- B	2.3	Filter will be installed and then retested			
70 BANNEKER HIGH SCHOOL	5/17/2016	WS-011924	Classroom	Basement	In classroom 005 (in office) Left	WT-042916-11941- A	22.3	WT-042916-11941- B	1.2	Filter will be installed and then retested			
71 BANNEKER HIGH SCHOOL	5/17/2016	WS-011923	Classroom	Basement	In classroom 005 (seventh sink clockwise from door) Right	WT-042916-11940- A	1.8	WT-042916-11940- B	< 1				
72 BANNEKER HIGH SCHOOL	5/17/2016	WS-011922	Classroom	Basement	In classroom 005 (sixth sink clockwise from door) Left	WT-042916-11939- A	1.6	WT-042916-11939- B	< 1				
73 BANNEKER HIGH SCHOOL	5/17/2016	WS-011921	Classroom	Basement	In classroom 005 (sixth sink clockwise from door) Right	WT-042916-11938- A	< 1	WT-042916-11938- B	< 1				
74 BANNEKER HIGH SCHOOL	5/17/2016	WS-011920	Cooler	Basement	In classroom 005 (fifth sink clockwise from door)	WT-042916-11937- A	3.2	WT-042916-11937- B	< 1				
75 BANNEKER HIGH SCHOOL	5/17/2016	WS-011919	Classroom	Basement	In classroom 005 (fifth sink clockwise from door) Right	WT-042916-11936- A	15	WT-042916-11936- B	1.3	Filter will be installed and then retested			
76 BANNEKER HIGH SCHOOL	5/17/2016	WS-011918	Classroom	Basement	In classroom 005 (fourth sink clockwise from door) Left	WT-042916-11935- A	5.2	WT-042916-11935- B	< 1				
77 BANNEKER HIGH SCHOOL	5/17/2016	WS-011917	Classroom	Basement	In classroom 005 (fourth sink clockwise from door) Right	WT-042916-11934- A	2.6	WT-042916-11934- B	< 1				
78 BANNEKER HIGH SCHOOL	5/17/2016	WS-011916	Classroom	Basement	In classroom 005 (third sink clockwise from door) Left	WT-042916-11933- A	1.9	WT-042916-11933- B	< 1				
79 BANNEKER HIGH SCHOOL	5/17/2016	WS-011915	Classroom	Basement	In classroom 005 (third sink clockwise from door) Right	WT-042916-11932- A	5.6	WT-042916-11932- B	< 1				
80 BANNEKER HIGH SCHOOL	5/17/2016	WS-011914	Classroom	Basement	In classroom 005 (second sink clockwise from door) Left	WT-042916-11931- A	2.2	WT-042916-11931- B	< 1				
81 BANNEKER HIGH SCHOOL	5/17/2016	WS-011913	Classroom	Basement	In classroom 005 (second sink clockwise from door) Right	WT-042916-11930- A	1.1	WT-042916-11930- B	< 1				
82 BANNEKER HIGH SCHOOL	5/17/2016	WS-011912	Classroom	Basement	In classroom 005 (first sink clockwise from door) Left	WT-042916-11929- A	4.1	WT-042916-11929- B	< 1				
83 BANNEKER HIGH SCHOOL	5/17/2016	WS-011911	Classroom	Basement	In classroom 005 (first sink clockwise from door) Right	WT-042916-11928- A	6.3	WT-042916-11928- B	< 1				
84 BANNEKER HIGH SCHOOL	5/17/2016	WS-011910	Classroom	Basement	In classroom 006 (in office)	WT-042916-11927- A	< 1	WT-042916-11927- B	2.1				
85 BANNEKER HIGH SCHOOL	5/17/2016	WS-011909	Classroom	Basement	In classroom 006	WT-042916-11926- A	< 1	WT-042916-11926- B	< 1				
86 BANNEKER HIGH SCHOOL	5/17/2016	WS-011908	Cooler	Basement	In basement hallway across from fitness center	WT-042916-11925- A	< 1	WT-042916-11925- B	< 1				
87 BANNEKER HIGH SCHOOL	5/17/2016	WS-011907	Cooler	Basement	In basement hallway first cooler adjacent to kitchen	WT-042916-11924- A	< 1	WT-042916-11924- B	< 1				
88 BANNEKER HIGH SCHOOL	5/17/2016	WS-011906	Other	Basement	In kitchen (ice maker)	WT-042916-11923- A	< 1	WT-042916-11923- B	< 1				
89 BANNEKER HIGH SCHOOL	5/17/2016	WS-011904	Kitchen	Basement	In kitchen (third sink clockwise from cafeteria entry door)	WT-042916-11921- A	< 1	WT-042916-11921- B	< 1				
90 BANNEKER HIGH SCHOOL	5/17/2016	WS-011903	Kitchen	Basement	In kitchen (second sink clockwise from cafeteria entry door)	WT-042916-11920- A	< 1	WT-042916-11920- B	< 1				
91 BANNEKER HIGH SCHOOL	5/17/2016	WS-011902	Kitchen	Basement	In kitchen (first sink clockwise from cafeteria entry door)	WT-042916-11919- A	< 1	WT-042916-11919- B	< 1				



BANNEKER LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
92	BANNEKER HIGH SCHOOL	5/17/2016	WS-011901	Cooler	Basement	In cafeteria adjacent to snack machine	WT-042916-11918- A	< 1	WT-042916-11918- B	< 1				
93	BANNEKER HIGH SCHOOL	5/17/2016	WS-011900	Cooler	Basement	In cafeteria adjacent to soda machine	WT-042916-11917- A	< 1	WT-042916-11917- B	< 1				
94	BANNEKER HIGH SCHOOL	5/17/2016	WS-011899	Cooler	Basement	In basement hallway adjacent to stairwell 6	WT-042916-11916- A	< 1	WT-042916-11916- B	< 1				
95	BANNEKER HIGH SCHOOL	5/17/2016	WS-011898	Utility	Basement	In water meter room	WT-042916-11915- A	2.8	WT-042916-11915- B	1.8				
96	BANNEKER HIGH SCHOOL	5/17/2016	WS-011897	Utility	Basement	In boiler room (closest tap to main source)	WT-042916-11914- A	8.4	WT-042916-11914- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.