



Banneker High School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011908	6/26/17	6/26/18	Basement	Cooler	In hallway across from fitness center	WF-62017-011908	12/13/17	FT-FY18--62017-011908-A	<1	FT-FY18--62017-011908-B	<1
WS- 011937	6/26/17	6/26/18	1	Cooler	In gym Right	WF-62017-011937	12/13/17	FT-FY18--62017-011937-A	<1	FT-FY18--62017-011937-B	<1
WS- 011939	6/26/17	6/26/18	1	Cooler	In hallway adjacent to room 113A	WF-62017-011939	12/13/17	FT-FY18--62017-011939-A	<1	FT-FY18--62017-011939-B	<1
WS- 011961	6/26/17	6/26/18	1	Cooler	In hallway adjacent to guidance room 103	WF-62017-011961	12/13/17	FT-FY18--62017-011961-A	<1	FT-FY18--62017-011961-B	<1
WS- 012506	6/26/17	6/26/18	3	Cooler	In hallway across from stairwell 5	WF-62017-012506	12/13/17	FT-FY18--62017-012506-A	<1	FT-FY18--62017-012506-B	<1
WS- 012526	6/26/17	6/26/18	3	Cooler	In hallway adjacent to room 306	WF-62017-012526	12/13/17	FT-FY18--62017-012526-A	<1	FT-FY18--62017-012526-B	<1
WS- 012568	6/26/17	6/26/18	Basement	Cooler	In fitness center near day care center	WF-62017-012568	12/13/17	FT-FY18--62017-012568-A	<1	FT-FY18--62017-012568-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011902	Basement	Food Prep Sink	In kitchen first clockwise from cafeteria entry door	12/13/17	FT-FY18-102017-011902-A	<1	FT-FY18-102017-011902-B	<1	