



Bard HS @ Davis Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 007499	6/10/2019	6/10/2020	1	Combo Fountain	In classroom c109	WF-06102019-007499	11/6/2019	FT-FY20-102019-007499-A	<1	FT-FY20-102019-007499-B	<1
WS- 007500	6/10/2019	6/10/2020	2	Cooler	In hallway adjacent to janitors closet b201c	WF-06102019-007500	11/6/2019	FT-FY20-102019-007500-A	<1	FT-FY20-102019-007500-B	<1
WS- 007501	6/10/2019	6/10/2020	2	Cooler	In hallway adjacent to classroom 204	WF-06102019-007501	11/6/2019	FT-FY20-102019-007501-A	<1	FT-FY20-102019-007501-B	<1
WS- 007502	6/10/2019	6/10/2020	2	Cooler	In hallway across from room 207	WF-06102019-007502	11/6/2019	FT-FY20-102019-007502-A	<1	FT-FY20-102019-007502-B	<1
WS- 007505	6/10/2019	6/10/2020	1	Cooler	In hallway adjacent to janitors closet c108	WF-06102019-007505	11/6/2019	FT-FY20-102019-007505-A	<1	FT-FY20-102019-007505-B	<1
WS- 007508	6/10/2019	6/10/2020	1	Cooler	In hallway adjacent to b101c janitor closet	WF-06102019-007508	11/6/2019	FT-FY20-102019-007508-A	<1	FT-FY20-102019-007508-B	<1
WS- 007509	6/10/2019	6/10/2020	1	Health Suite	In health suite room a103	WF-06102019-007509	11/6/2019	FT-FY20-102019-007509-A	<1	FT-FY20-102019-007509-B	<1
WS- 007510	6/10/2019	6/10/2020	1	Cooler	In hallway adjacent to classroom a102	WF-06102019-007510	11/6/2019	FT-FY20-102019-007510-A	<1	FT-FY20-102019-007510-B	<1
WS- 007511	6/10/2019	6/10/2020	Basement	Cooler	In kitchen hallway adjacent to custodian closet	WF-06102019-007511	11/6/2019	FT-FY20-102019-007511-A	<1	FT-FY20-102019-007511-B	<1
WS- 007518	6/10/2019	6/10/2020	1	Combo Fountain	In classroom c104	WF-06102019-007518	11/6/2019	FT-FY20-102019-007518-A	<1	FT-FY20-102019-007518-B	<1
WS- 007519	6/10/2019	6/10/2020	1	Combo Fountain	In classroom c102	WF-06102019-007519	11/6/2019	FT-FY20-102019-007519-A	<1	FT-FY20-102019-007519-B	<1
WS- 007520	6/10/2019	6/10/2020	1	Combo Fountain	In classroom c103	WF-06102019-007520	11/6/2019	FT-FY20-102019-007520-A	<1	FT-FY20-102019-007520-B	<1
WS- 007521	6/10/2019	6/10/2020	1	Combo Fountain	In classroom c110	WF-06102019-007521	11/6/2019	FT-FY20-102019-007521-A	<1	FT-FY20-102019-007521-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 007515	7/8/2019	7/8/2020	Basement	Food Prep Sink	In kitchen third from left Right	WF-07082019-007515	11/6/2019	FT-FY20-102019-007515-A	<1	FT-FY20-102019-007515-B	<1