



Barnard ES Lead in Water Test Results

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001149	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 105 in bathroom	WF-02232026-001149	8/11/2026	FT-FY27-08022026-001149-A	3.2	FT-FY27-08022026-001149-B	<1
WS- 001151	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 104	WF-08122025-001151	8/11/2026	FT-FY27-08022026-001151-A	<1	FT-FY27-08022026-001151-B	<1
WS- 001152	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 106	WF-08122025-001152	8/11/2026	FT-FY27-08022026-001152-A	<1	FT-FY27-08022026-001152-B	<1
WS- 001153	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 106 in bathroom	WF-02232026-001153	8/11/2026	FT-FY27-08022026-001153-A	3.5	FT-FY27-08022026-001153-B	<1
WS- 001154	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 105	WF-08122025-001154	8/11/2026	FT-FY27-08022026-001154-A	<1	FT-FY27-08022026-001154-B	<1
WS- 001155	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 109	WF-08122025-001155	8/11/2026	FT-FY27-08022026-001155-A	<1	FT-FY27-08022026-001155-B	<1
WS- 001156	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 109 in bathroom	WF-02232026-001156	8/11/2026	FT-FY27-08022026-001156-A	2.7	FT-FY27-08022026-001156-B	<1
WS- 001157	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 110	WF-08122025-001157	8/11/2026	FT-FY27-08022026-001157-A	<1	FT-FY27-08022026-001157-B	<1
WS- 001159	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 111	WF-08122025-001159	8/11/2026	FT-FY27-08022026-001159-A	1.2	FT-FY27-08022026-001159-B	<1
WS- 001160	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 111 in bathroom	WF-02232026-001160	8/11/2026	FT-FY27-08022026-001160-A	<1	FT-FY27-08022026-001160-B	<1
WS- 001161	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 112	WF-08122025-001161	8/11/2026	FT-FY27-08022026-001161-A	<1	FT-FY27-08022026-001161-B	<1
WS- 001162	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 112 in bathroom	WF-02232026-001162	8/11/2026	FT-FY27-08022026-001162-A	4.1	FT-FY27-08022026-001162-B	<1
WS- 001163	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 113	WF-08122025-001163	8/11/2026	FT-FY27-08022026-001163-A	<1	FT-FY27-08022026-001163-B	<1
WS- 001165	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 114	WF-08122025-001165	8/11/2026	FT-FY27-08022026-001165-A	3.8	FT-FY27-08022026-001165-B	<1
WS- 001166	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 114 in bathroom	WF-02232026-001166	8/11/2026	FT-FY27-08022026-001166-A	1.9	FT-FY27-08022026-001166-B	<1
WS- 001167	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 115	WF-08122025-001167	8/11/2026	FT-FY27-08022026-001167-A	1.1	FT-FY27-08022026-001167-B	<1
WS- 001168	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 116	WF-08122025-001168	8/11/2026	FT-FY27-08022026-001168-A	1.8	FT-FY27-08022026-001168-B	<1
WS- 001169	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 117	WF-08122025-001169	8/11/2026	FT-FY27-08022026-001169-A	<1	FT-FY27-08022026-001169-B	<1
WS- 001170	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 118	WF-08122025-001170	8/11/2026	FT-FY27-08022026-001170-A	3.4	FT-FY27-08022026-001170-B	<1
WS- 001171	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 118 in bathroom	WF-02232026-001171	8/11/2026	FT-FY27-08022026-001171-A	2.9	FT-FY27-08022026-001171-B	<1
WS- 001172	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 119	WF-08122025-001172	8/11/2026	FT-FY27-08022026-001172-A	<1	FT-FY27-08022026-001172-B	<1
WS- 001174	8/12/2025	8/12/2026	1	Classroom Faucet	In classroom 120	WF-08122025-001174	8/11/2026	FT-FY27-08022026-001174-A	1.2	FT-FY27-08022026-001174-B	<1
WS- 001175	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 120 in bathroom	WF-02232026-001175	8/11/2026	FT-FY27-08022026-001175-A	<1	FT-FY27-08022026-001175-B	<1
WS- 001176	4/24/2026	4/24/2027	1	Cooler	In hallway adjacent to room 121	WF-04242026-001176	8/11/2026	FT-FY27-08022026-001176-A	<1	FT-FY27-08022026-001176-B	<1
WS- 001180	2/23/2026	2/23/2027	1	Cooler	In hallway adjacent to girls' restroom	WF-02232026-001180	8/11/2026	FT-FY27-08022026-001180-A	<1	FT-FY27-08022026-001180-B	<1
WS- 001181	2/23/2026	2/23/2027	1	Cooler	In hallway adjacent to girls' restroom	WF-02232026-001181	8/11/2026	FT-FY27-08022026-001181-A	<1	FT-FY27-08022026-001181-B	<1
WS- 001182	2/23/2026	2/23/2027	1	Break Room	In staff lounge room 122	WF-02232026-001182	8/11/2026	FT-FY27-08022026-001182-A	<1	FT-FY27-08022026-001182-B	<1
WS- 001188	2/23/2026	2/23/2027	1	Health Suite	In health suite 157	WF-02232026-001188	8/11/2026	FT-FY27-08022026-001188-A	<1	FT-FY27-08022026-001188-B	<1
WS- 001208	2/23/2026	2/23/2027	2	Cooler	In hallway adjacent room 210	WF-02232026-001208	8/11/2026	FT-FY27-08022026-001208-A	<1	FT-FY27-08022026-001208-B	<1
WS- 001209	2/23/2026	2/23/2027	2	Cooler	In hallway adjacent room 210	WF-02232026-001209	8/11/2026	FT-FY27-08022026-001209-A	<1	FT-FY27-08022026-001209-B	<1
WS- 001210	2/23/2026	2/23/2027	2	Cooler	In hallway adjacent to room 206	WF-02232026-001210	8/11/2026	FT-FY27-08022026-001210-A	<1	FT-FY27-08022026-001210-B	<1
WS- 001212	2/23/2026	2/23/2027	2	Cooler	In hallway adjacent to art room 239	WF-02232026-001212	8/11/2026	FT-FY27-08022026-001212-A	<1	FT-FY27-08022026-001212-B	<1
WS- 001213	2/23/2026	2/23/2027	2	Cooler	In hallway adjacent to art room 239	WF-02232026-001213	8/11/2026	FT-FY27-08022026-001213-A	<1	FT-FY27-08022026-001213-B	<1
WS- 002475	2/23/2026	2/23/2027	1	Break Room	In unmarked room on the right just as you enter the main office	WF-02232026-002475	8/11/2026	FT-FY27-08022026-002475-A	<1	FT-FY27-08022026-002475-B	<1

WS- 002476	4/24/2026	4/24/2027	1	Bottle Filler	In hallway adjacent to room 121		WF-04242026-002476	8/11/2026	FT-FY27-08022026-002476-A	<1	FT-FY27-08022026-002476-B	<1
WS- 002477	2/23/2026	2/23/2027	1	Bottle Filler	In hallway adjacent to girls' restroom		WF-02232026-002477	8/11/2026	FT-FY27-08022026-002477-A	<1	FT-FY27-08022026-002477-B	<1
WS- 002478	2/23/2026	2/23/2027	2	Bottle Filler	In hallway adjacent to room 210		WF-02232026-002478	8/11/2026	FT-FY27-08022026-002478-A	<1	FT-FY27-08022026-002478-B	<1
WS- 002479	2/23/2026	2/23/2027	2	Bottle Filler	In hallway adjacent to art room 239		WF-02232026-002479	8/11/2026	FT-FY27-08022026-002479-A	<1	FT-FY27-08022026-002479-B	<1
WS- 006027	7/30/2026	7/30/2027	1	Combo Faucet	In room 108	Low Left	WF-07302026-006027	8/11/2026	FT-FY27-08022026-006027-A	<1	FT-FY27-08022026-006027-B	<1
WS- 006028	7/30/2026	7/30/2027	1	Combo Fountain	In room 108	Low Left	WF-07302026-006028	8/11/2026	FT-FY27-08022026-006028-A	<1	FT-FY27-08022026-006028-B	<1
WS- 006030	7/30/2026	7/30/2027	1	Combo Fountain	In room 108	High Right	WF-07302026-006030	8/11/2026	FT-FY27-08022026-006030-A	<1	FT-FY27-08022026-006030-B	<1
WS- 006032	7/30/2026	7/30/2027	1	Combo Fountain	In room 106	High Left	WF-07302026-006032	8/11/2026	FT-FY27-08022026-006032-A	<1	FT-FY27-08022026-006032-B	<1
WS- 006033	7/30/2026	7/30/2027	1	Combo Faucet	In room 106	Low Right	WF-07302026-006033	8/11/2026	FT-FY27-08022026-006033-A	<1	FT-FY27-08022026-006033-B	<1
WS- 006034	7/30/2026	7/30/2027	1	Combo Fountain	In room 106	Low Right	WF-07302026-006034	8/11/2026	FT-FY27-08022026-006034-A	<1	FT-FY27-08022026-006034-B	<1
WS- 006035	7/30/2026	7/30/2027	1	Break Room	In room 105 teacher collaboration		WF-07302026-006035	8/11/2026	FT-FY27-08022026-006035-A	<1	FT-FY27-08022026-006035-B	<1
WS- 006036	7/30/2026	7/30/2027	1	Bottle Filler	In hallway adjacent to room 110B		WF-07302026-006036	8/11/2026	FT-FY27-08022026-006036-A	<1	FT-FY27-08022026-006036-B	<1
WS- 006037	7/30/2026	7/30/2027	1	Cooler	In hallway adjacent to room 110B	High Left	WF-07302026-006037	8/11/2026	FT-FY27-08022026-006037-A	<1	FT-FY27-08022026-006037-B	<1
WS- 006038	7/30/2026	7/30/2027	1	Cooler	In hallway adjacent to room 110B	Low Right	WF-07302026-006038	8/11/2026	FT-FY27-08022026-006038-A	<1	FT-FY27-08022026-006038-B	<1
WS- 006039	7/30/2026	7/30/2027	1	Combo Faucet	In room 104	Low Left	WF-07302026-006039	8/11/2026	FT-FY27-08022026-006039-A	<1	FT-FY27-08022026-006039-B	<1
WS- 006040	7/30/2026	7/30/2027	1	Combo Fountain	In room 104	Low Left	WF-07302026-006040	8/11/2026	FT-FY27-08022026-006040-A	<1	FT-FY27-08022026-006040-B	<1
WS- 006042	7/30/2026	7/30/2027	1	Combo Fountain	In room 104	High Right	WF-07302026-006042	8/11/2026	FT-FY27-08022026-006042-A	<1	FT-FY27-08022026-006042-B	<1
WS- 006043	7/30/2026	7/30/2027	1	Combo Faucet	In room 103	Low Left	WF-07302026-006043	8/11/2026	FT-FY27-08022026-006043-A	<1	FT-FY27-08022026-006043-B	<1
WS- 006044	7/30/2026	7/30/2027	1	Combo Fountain	In room 103	Low Left	WF-07302026-006044	8/11/2026	FT-FY27-08022026-006044-A	<1	FT-FY27-08022026-006044-B	<1
WS- 006046	7/30/2026	7/30/2027	1	Combo Fountain	In room 103	High Right	WF-07302026-006046	8/11/2026	FT-FY27-08022026-006046-A	<1	FT-FY27-08022026-006046-B	<1
WS- 006047	7/30/2026	7/30/2027	1	Combo Faucet	In room 102	Low Left	WF-07302026-006047	8/11/2026	FT-FY27-08022026-006047-A	<1	FT-FY27-08022026-006047-B	<1
WS- 006048	7/30/2026	7/30/2027	1	Combo Fountain	In room 102	Low Left	WF-07302026-006048	8/11/2026	FT-FY27-08022026-006048-A	<1	FT-FY27-08022026-006048-B	<1
WS- 006050	7/30/2026	7/30/2027	1	Combo Fountain	In room 102	High Right	WF-07302026-006050	8/11/2026	FT-FY27-08022026-006050-A	<1	FT-FY27-08022026-006050-B	<1
WS- 006052	7/30/2026	7/30/2027	1	Combo Fountain	In room 101	High Left	WF-07302026-006052	8/11/2026	FT-FY27-08022026-006052-A	<1	FT-FY27-08022026-006052-B	<1
WS- 006053	7/30/2026	7/30/2027	1	Combo Faucet	In room 101	Low Right	WF-07302026-006053	8/11/2026	FT-FY27-08022026-006053-A	<1	FT-FY27-08022026-006053-B	<1
WS- 006054	7/30/2026	7/30/2027	1	Combo Fountain	In room 101	Low Right	WF-07302026-006054	8/11/2026	FT-FY27-08022026-006054-A	<1	FT-FY27-08022026-006054-B	<1
WS- 006056	7/30/2026	7/30/2027	2	Cooler	In hallway adjacent to room 215	High Left	WF-07302026-006056	8/11/2026	FT-FY27-08022026-006056-A	<1	FT-FY27-08022026-006056-B	<1
WS- 006057	7/30/2026	7/30/2027	2	Cooler	In hallway adjacent to room 215	Low Right	WF-07302026-006057	8/11/2026	FT-FY27-08022026-006057-A	<1	FT-FY27-08022026-006057-B	<1
WS- 006059	7/30/2026	7/30/2027	2	Combo Fountain	In room 208 first clockwise from entry		WF-07302026-006059	8/11/2026	FT-FY27-08022026-006059-A	<1	FT-FY27-08022026-006059-B	<1
WS- 006061	7/30/2026	7/30/2027	2	Combo Fountain	In room 208 second clockwise from entry		WF-07302026-006061	8/11/2026	FT-FY27-08022026-006061-A	<1	FT-FY27-08022026-006061-B	<1
WS- 006063	7/30/2026	7/30/2027	2	Combo Fountain	In room 208 third clockwise from entry		WF-07302026-006063	8/11/2026	FT-FY27-08022026-006063-A	<1	FT-FY27-08022026-006063-B	<1
WS- 006065	7/30/2026	7/30/2027	2	Combo Fountain	In room 208 fourth clockwise from entry		WF-07302026-006065	8/11/2026	FT-FY27-08022026-006065-A	<1	FT-FY27-08022026-006065-B	<1
WS- 006067	7/30/2026	7/30/2027	2	Combo Fountain	In room 206		WF-07302026-006067	8/11/2026	FT-FY27-08022026-006067-A	<1	FT-FY27-08022026-006067-B	<1
WS- 006069	7/30/2026	7/30/2027	2	Combo Fountain	In room 204		WF-07302026-006069	8/11/2026	FT-FY27-08022026-006069-A	<1	FT-FY27-08022026-006069-B	<1
WS- 006071	7/30/2026	7/30/2027	2	Combo Fountain	In room 203		WF-07302026-006071	8/11/2026	FT-FY27-08022026-006071-A	<1	FT-FY27-08022026-006071-B	<1
WS- 006073	7/30/2026	7/30/2027	2	Combo Fountain	In room 202		WF-07302026-006073	8/11/2026	FT-FY27-08022026-006073-A	<1	FT-FY27-08022026-006073-B	<1
WS- 006075	7/30/2026	7/30/2027	2	Combo Fountain	In room 201		WF-07302026-006075	8/11/2026	FT-FY27-08022026-006075-A	<1	FT-FY27-08022026-006075-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001185	11/17/2025	11/17/2026	1	Food Prep Sink	In kitchen south wall Mid	WF-11172025-001185	8/11/2026	FT-FY27-08022026-001185-A	<1	FT-FY27-08022026-001185-B	<1

FY27 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001158	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 110 in bathroom	WF-02232026-001158	8/11/2026	FT-FY27-08022026-001158-A	5.0	FT-FY27-08022026-001158-B	<1
WS- 001173	2/23/2026	2/23/2027	1	Combo Fountain	In classroom 119 in bathroom	WF-02232026-001173	8/11/2026	FT-FY27-08022026-001173-A	8.5	FT-FY27-08022026-001173-B	<1