



Barnard Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001149	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 105 in bathroom	WF-03292021-001149	12/20/2021	FT-FY22-12012021-001149-A	1.3	FT-FY22-12012021-001149-B	<1	
WS-001151	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 104	WF-09072021-001151	12/20/2021	FT-FY22-12012021-001151-A	<1	FT-FY22-12012021-001151-B	<1	
WS-001152	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 106	WF-09072021-001152	12/20/2021	FT-FY22-12012021-001152-A	<1	FT-FY22-12012021-001152-B	<1	
WS-001153	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 106 in bathroom	WF-03292021-001153	12/20/2021	FT-FY22-12012021-001153-A	1.2	FT-FY22-12012021-001153-B	<1	
WS-001154	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 105	WF-09072021-001154	12/20/2021	FT-FY22-12012021-001154-A	<1	FT-FY22-12012021-001154-B	<1	
WS-001155	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 109	WF-09072021-001155	12/20/2021	FT-FY22-12012021-001155-A	<1	FT-FY22-12012021-001155-B	<1	
WS-001156	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 109 in bathroom	WF-03292021-001156	12/20/2021	FT-FY22-12012021-001156-A	<1	FT-FY22-12012021-001156-B	<1	
WS-001158	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 110 in bathroom	WF-03292021-001158	12/20/2021	FT-FY22-12012021-001158-A	<1	FT-FY22-12012021-001158-B	<1	
WS-001159	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 111	WF-09072021-001159	12/20/2021	FT-FY22-12012021-001159-A	<1	FT-FY22-12012021-001159-B	<1	
WS-001160	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 111 in bathroom	WF-03292021-001160	12/20/2021	FT-FY22-12012021-001160-A	<1	FT-FY22-12012021-001160-B	<1	
WS-001161	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 112	WF-09072021-001161	12/20/2021	FT-FY22-12012021-001161-A	<1	FT-FY22-12012021-001161-B	<1	
WS-001162	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 112 in bathroom	WF-03292021-001162	12/20/2021	FT-FY22-12012021-001162-A	<1	FT-FY22-12012021-001162-B	<1	
WS-001164	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 113 in bathroom	WF-03292021-001164	12/20/2021	FT-FY22-12012021-001164-A	2.2	FT-FY22-12012021-001164-B	2.2	
WS-001165	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 114	WF-09072021-001165	12/20/2021	FT-FY22-12012021-001165-A	<1	FT-FY22-12012021-001165-B	<1	
WS-001166	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 114 in bathroom	WF-03292021-001166	12/20/2021	FT-FY22-12012021-001166-A	1.2	FT-FY22-12012021-001166-B	<1	
WS-001167	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 115	WF-09072021-001167	12/20/2021	FT-FY22-12012021-001167-A	<1	FT-FY22-12012021-001167-B	<1	
WS-001168	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 116	WF-09072021-001168	12/20/2021	FT-FY22-12012021-001168-A	<1	FT-FY22-12012021-001168-B	<1	
WS-001169	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 117	WF-09072021-001169	12/20/2021	FT-FY22-12012021-001169-A	<1	FT-FY22-12012021-001169-B	<1	
WS-001170	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 118	WF-09072021-001170	12/20/2021	FT-FY22-12012021-001170-A	<1	FT-FY22-12012021-001170-B	<1	
WS-001171	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 118 in bathroom	WF-03292021-001171	12/20/2021	FT-FY22-12012021-001171-A	<1	FT-FY22-12012021-001171-B	<1	
WS-001172	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 119	WF-09072021-001172	12/20/2021	FT-FY22-12012021-001172-A	<1	FT-FY22-12012021-001172-B	<1	
WS-001173	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 119 in bathroom	WF-03292021-001173	12/20/2021	FT-FY22-12012021-001173-A	<1	FT-FY22-12012021-001173-B	<1	
WS-001174	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 120	WF-09072021-001174	12/20/2021	FT-FY22-12012021-001174-A	<1	FT-FY22-12012021-001174-B	<1	
WS-001175	3/29/2021	3/29/2022	1	Combo Fountain	In classroom 120 in bathroom	WF-03292021-001175	12/20/2021	FT-FY22-12012021-001175-A	<1	FT-FY22-12012021-001175-B	<1	
WS-001176	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to room 121	Low Left	WF-03292021-001176	12/20/2021	FT-FY22-12012021-001176-A	<1	FT-FY22-12012021-001176-B	<1
WS-001177	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to room 121	High Right	WF-03292021-001177	12/20/2021	FT-FY22-12012021-001177-A	<1	FT-FY22-12012021-001177-B	<1
WS-001178	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-03292021-001178	12/20/2021	FT-FY22-12012021-001178-A	<1	FT-FY22-12012021-001178-B	1.0
WS-001179	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to boys' restroom	High Right	WF-03292021-001179	12/20/2021	FT-FY22-12012021-001179-A	<1	FT-FY22-12012021-001179-B	1.3
WS-001180	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03292021-001180	12/20/2021	FT-FY22-12012021-001180-A	<1	FT-FY22-12012021-001180-B	<1
WS-001181	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03292021-001181	12/20/2021	FT-FY22-12012021-001181-A	1.7	FT-FY22-12012021-001181-B	1.2
WS-001182	3/29/2021	3/29/2022	1	Break Room	In staff lounge room 122		WF-03292021-001182	12/20/2021	FT-FY22-12012021-001182-A	<1	FT-FY22-12012021-001182-B	<1
WS-001188	3/29/2021	3/29/2022	1	Health Suite	In health suite 157		WF-03292021-001188	12/20/2021	FT-FY22-12012021-001188-A	<1	FT-FY22-12012021-001188-B	<1
WS-001208	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent room 210	High Right	WF-03292021-001208	12/20/2021	FT-FY22-12012021-001208-A	<1	FT-FY22-12012021-001208-B	<1
WS-001209	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent room 210	Low Left	WF-03292021-001209	12/20/2021	FT-FY22-12012021-001209-A	<1	FT-FY22-12012021-001209-B	<1
WS-001210	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent to room 206	Low Right	WF-03292021-001210	12/20/2021	FT-FY22-12012021-001210-A	<1	FT-FY22-12012021-001210-B	<1

WS-001211	3/29/2021	3/29/2022	2	Cooler	In hallway to adjacent room 206	High Left	WF-03292021-001211	12/20/2021	FT-FY22-12012021-001211-A	<1	FT-FY22-12012021-001211-B	<1
WS-001212	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent to art room 239	Right	WF-03292021-001212	12/20/2021	FT-FY22-12012021-001212-A	<1	FT-FY22-12012021-001212-B	<1
WS-001213	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent to art room 239	Left	WF-03292021-001213	12/20/2021	FT-FY22-12012021-001213-A	<1	FT-FY22-12012021-001213-B	<1
WS-002475	3/29/2021	3/29/2022	1	Break Room	In unmarked room on the right in main office		WF-03292021-002475	12/20/2021	FT-FY22-12012021-002475-A	<1	FT-FY22-12012021-002475-B	<1
WS-002476	3/29/2021	3/29/2022	1	Bottle Filler	In hallway adjacent to room 121		WF-03292021-002476	12/20/2021	FT-FY22-12012021-002476-A	<1	FT-FY22-12012021-002476-B	<1
WS-002477	3/29/2021	3/29/2022	1	Bottle Filler	In hallway adjacent to girls' restroom		WF-03292021-002477	12/20/2021	FT-FY22-12012021-002477-A	<1	FT-FY22-12012021-002477-B	<1
WS-002478	3/29/2021	3/29/2022	2	Bottle Filler	In hallway adjacent to room 210		WF-03292021-002478	12/20/2021	FT-FY22-12012021-002478-A	<1	FT-FY22-12012021-002478-B	<1
WS-002479	3/29/2021	3/29/2022	2	Bottle Filler	In hallway adjacent to art room 239		WF-03292021-002479	12/20/2021	FT-FY22-12012021-002479-A	<1	FT-FY22-12012021-002479-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001185	1/5/2021	1/5/2022	1	Food Prep Sink	In kitchen south wall	Mid	WF-01052021-001185	12/20/2021	FT-FY22-12012021-001185-A	<1	FT-FY22-12012021-001185-B	<1