



Barnard Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001149	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 105 in bathroom	WF-03202022-001149	1/8/2023	FT-FY23-11182022-001149-A	<1	FT-FY23-11182022-001149-B	<1	
WS-001151	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 104	WF-08302022-001151	1/8/2023	FT-FY23-11182022-001151-A	<1	FT-FY23-11182022-001151-B	<1	
WS-001152	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 106	WF-08302022-001152	1/8/2023	FT-FY23-11182022-001152-A	<1	FT-FY23-11182022-001152-B	<1	
WS-001153	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 106 in bathroom	WF-03202022-001153	1/8/2023	FT-FY23-11182022-001153-A	<1	FT-FY23-11182022-001153-B	<1	
WS-001154	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 105	WF-08302022-001154	1/8/2023	FT-FY23-11182022-001154-A	<1	FT-FY23-11182022-001154-B	<1	
WS-001155	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 109	WF-08302022-001155	1/8/2023	FT-FY23-11182022-001155-A	<1	FT-FY23-11182022-001155-B	<1	
WS-001156	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 109 in bathroom	WF-03202022-001156	1/8/2023	FT-FY23-11182022-001156-A	<1	FT-FY23-11182022-001156-B	<1	
WS-001157	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 110	WF-08302022-001157	1/8/2023	FT-FY23-11182022-001157-A	<1	FT-FY23-11182022-001157-B	<1	
WS-001158	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 110 in bathroom	WF-03202022-001158	1/8/2023	FT-FY23-11182022-001158-A	<1	FT-FY23-11182022-001158-B	<1	
WS-001159	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 111	WF-08302022-001159	1/8/2023	FT-FY23-11182022-001159-A	<1	FT-FY23-11182022-001159-B	<1	
WS-001160	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 111 in bathroom	WF-03202022-001160	1/8/2023	FT-FY23-11182022-001160-A	<1	FT-FY23-11182022-001160-B	<1	
WS-001161	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 112	WF-08302022-001161	1/8/2023	FT-FY23-11182022-001161-A	<1	FT-FY23-11182022-001161-B	<1	
WS-001162	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 112 in bathroom	WF-03202022-001162	1/8/2023	FT-FY23-11182022-001162-A	<1	FT-FY23-11182022-001162-B	<1	
WS-001163	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 113	WF-08302022-001163	1/8/2023	FT-FY23-11182022-001163-A	<1	FT-FY23-11182022-001163-B	<1	
WS-001164	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 113 in bathroom	WF-03202022-001164	1/8/2023	FT-FY23-11182022-001164-A	<1	FT-FY23-11182022-001164-B	<1	
WS-001165	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 114	WF-08302022-001165	1/8/2023	FT-FY23-11182022-001165-A	<1	FT-FY23-11182022-001165-B	<1	
WS-001166	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 114 in bathroom	WF-03202022-001166	1/8/2023	FT-FY23-11182022-001166-A	<1	FT-FY23-11182022-001166-B	<1	
WS-001167	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 115	WF-08302022-001167	1/8/2023	FT-FY23-11182022-001167-A	<1	FT-FY23-11182022-001167-B	<1	
WS-001168	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 116	WF-08302022-001168	1/8/2023	FT-FY23-11182022-001168-A	<1	FT-FY23-11182022-001168-B	<1	
WS-001169	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 117	WF-08302022-001169	1/8/2023	FT-FY23-11182022-001169-A	<1	FT-FY23-11182022-001169-B	<1	
WS-001170	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 118	WF-08302022-001170	1/8/2023	FT-FY23-11182022-001170-A	<1	FT-FY23-11182022-001170-B	<1	
WS-001171	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 118 in bathroom	WF-03202022-001171	1/8/2023	FT-FY23-11182022-001171-A	<1	FT-FY23-11182022-001171-B	<1	
WS-001172	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 119	WF-08302022-001172	1/8/2023	FT-FY23-11182022-001172-A	<1	FT-FY23-11182022-001172-B	<1	
WS-001173	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 119 in bathroom	WF-03202022-001173	1/8/2023	FT-FY23-11182022-001173-A	<1	FT-FY23-11182022-001173-B	<1	
WS-001174	8/30/2022	8/30/2023	1	Classroom Faucet	In classroom 120	WF-08302022-001174	1/8/2023	FT-FY23-11182022-001174-A	<1	FT-FY23-11182022-001174-B	<1	
WS-001175	3/20/2022	3/20/2023	1	Combo Fountain	In classroom 120 in bathroom	WF-03202022-001175	1/8/2023	FT-FY23-11182022-001175-A	<1	FT-FY23-11182022-001175-B	<1	
WS-001176	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to room 121	Low Left	WF-03202022-001176	1/8/2023	FT-FY23-11182022-001176-A	<1	FT-FY23-11182022-001176-B	<1
WS-001177	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to room 121	High Right	WF-03202022-001177	1/8/2023	FT-FY23-11182022-001177-A	<1	FT-FY23-11182022-001177-B	<1
WS-001178	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-03202022-001178	1/8/2023	FT-FY23-11182022-001178-A	<1	FT-FY23-11182022-001178-B	<1
WS-001179	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to boys' restroom	High Right	WF-03202022-001179	1/8/2023	FT-FY23-11182022-001179-A	<1	FT-FY23-11182022-001179-B	<1
WS-001180	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03202022-001180	1/8/2023	FT-FY23-11182022-001180-A	<1	FT-FY23-11182022-001180-B	<1
WS-001181	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03202022-001181	1/8/2023	FT-FY23-11182022-001181-A	1.7	FT-FY23-11182022-001181-B	<1
WS-001182	3/20/2022	3/20/2023	1	Break Room	In staff lounge room 122		WF-03202022-001182	1/8/2023	FT-FY23-11182022-001182-A	<1	FT-FY23-11182022-001182-B	<1
WS-001188	3/20/2022	3/20/2023	1	Health Suite	In health suite 157		WF-03202022-001188	1/8/2023	FT-FY23-11182022-001188-A	<1	FT-FY23-11182022-001188-B	<1
WS-001208	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent room 210	High Right	WF-03202022-001208	1/8/2023	FT-FY23-11182022-001208-A	<1	FT-FY23-11182022-001208-B	<1
WS-001209	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent room 210	Low Left	WF-03202022-001209	1/8/2023	FT-FY23-11182022-001209-A	<1	FT-FY23-11182022-001209-B	<1
WS-001210	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to room 206	Low Right	WF-03202022-001210	1/8/2023	FT-FY23-11182022-001210-A	<1	FT-FY23-11182022-001210-B	<1

WS-001211	3/20/2022	3/20/2023	2	Cooler	In hallway to adjacent room 206	High Left	WF-03202022-001211	1/8/2023	FT-FY23-11182022-001211-A	<1	FT-FY23-11182022-001211-B	<1
WS-001212	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to art room 239	Right	WF-03202022-001212	1/8/2023	FT-FY23-11182022-001212-A	<1	FT-FY23-11182022-001212-B	<1
WS-001213	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to art room 239	Left	WF-03202022-001213	1/8/2023	FT-FY23-11182022-001213-A	<1	FT-FY23-11182022-001213-B	<1
WS-001214	3/20/2022	3/20/2023	1	Cooler	Annex B, in hallway	High Left	WF-03202022-001214	1/8/2023	FT-FY23-11182022-001214-A	<1	FT-FY23-11182022-001214-B	<1
WS-001215	3/20/2022	3/20/2023	1	Cooler	Annex B, in hallway	Low Right	WF-03202022-001215	1/8/2023	FT-FY23-11182022-001215-A	<1	FT-FY23-11182022-001215-B	<1
WS-001216	3/20/2022	3/20/2023	1	Cooler	Annex A, in hallway	High Left	WF-03202022-001216	1/8/2023	FT-FY23-11182022-001216-A	<1	FT-FY23-11182022-001216-B	<1
WS-001217	3/20/2022	3/20/2023	1	Cooler	Annex A, in hallway	Low Right	WF-03202022-001217	1/8/2023	FT-FY23-11182022-001217-A	<1	FT-FY23-11182022-001217-B	<1
WS-002475	3/20/2022	3/20/2023	1	Break Room	In unmarked room on the right just as you enter the main office		WF-03202022-002475	1/8/2023	FT-FY23-11182022-002475-A	<1	FT-FY23-11182022-002475-B	<1
WS-002476	3/20/2022	3/20/2023	1	Bottle Filler	In hallway adjacent to room 121		WF-03202022-002476	1/8/2023	FT-FY23-11182022-002476-A	<1	FT-FY23-11182022-002476-B	<1
WS-002477	3/20/2022	3/20/2023	1	Bottle Filler	In hallway adjacent to girls' restroom		WF-03202022-002477	1/8/2023	FT-FY23-11182022-002477-A	<1	FT-FY23-11182022-002477-B	<1
WS-002478	3/20/2022	3/20/2023	2	Bottle Filler	In hallway adjacent to room 210		WF-03202022-002478	1/8/2023	FT-FY23-11182022-002478-A	<1	FT-FY23-11182022-002478-B	<1
WS-002479	3/20/2022	3/20/2023	2	Bottle Filler	In hallway adjacent to art room 239		WF-03202022-002479	1/8/2023	FT-FY23-11182022-002479-A	<1	FT-FY23-11182022-002479-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001185	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen south wall	Mid	WF-12192022-001185	1/8/2023	FT-FY23-11182022-001185-A	<1	FT-FY23-11182022-001185-B	<1