



Barnard Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001149	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 105 in bathroom	WF-03152023-001149	11/17/2023	FT-FY24-10102023-001149-A	2.0	FT-FY24-10102023-001149-B	1.1	
WS-001151	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 104	WF-08212023-001151	11/17/2023	FT-FY24-10102023-001151-A	<1	FT-FY24-10102023-001151-B	<1	
WS-001152	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 106	WF-08212023-001152	11/17/2023	FT-FY24-10102023-001152-A	<1	FT-FY24-10102023-001152-B	<1	
WS-001153	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 106 in bathroom	WF-03152023-001153	11/17/2023	FT-FY24-10102023-001153-A	<1	FT-FY24-10102023-001153-B	<1	
WS-001154	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 105	WF-08212023-001154	11/17/2023	FT-FY24-10102023-001154-A	<1	FT-FY24-10102023-001154-B	<1	
WS-001155	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 109	WF-08212023-001155	11/17/2023	FT-FY24-10102023-001155-A	<1	FT-FY24-10102023-001155-B	<1	
WS-001156	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 109 in bathroom	WF-03152023-001156	11/17/2023	FT-FY24-10102023-001156-A	1.0	FT-FY24-10102023-001156-B	<1	
WS-001157	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 110	WF-08212023-001157	11/17/2023	FT-FY24-10102023-001157-A	<1	FT-FY24-10102023-001157-B	<1	
WS-001158	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 110 in bathroom	WF-03152023-001158	11/17/2023	FT-FY24-10102023-001158-A	1.2	FT-FY24-10102023-001158-B	<1	
WS-001159	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 111	WF-08212023-001159	11/17/2023	FT-FY24-10102023-001159-A	<1	FT-FY24-10102023-001159-B	<1	
WS-001161	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 112	WF-08212023-001161	11/17/2023	FT-FY24-10102023-001161-A	<1	FT-FY24-10102023-001161-B	<1	
WS-001162	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 112 in bathroom	WF-03152023-001162	11/17/2023	FT-FY24-10102023-001162-A	2.2	FT-FY24-10102023-001162-B	1.6	
WS-001163	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 113	WF-08212023-001163	11/17/2023	FT-FY24-10102023-001163-A	<1	FT-FY24-10102023-001163-B	<1	
WS-001164	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 113 in bathroom	WF-03152023-001164	11/17/2023	FT-FY24-10102023-001164-A	1.4	FT-FY24-10102023-001164-B	2.7	
WS-001166	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 114 in bathroom	WF-03152023-001166	11/17/2023	FT-FY24-10102023-001166-A	<1	FT-FY24-10102023-001166-B	<1	
WS-001167	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 115	WF-08212023-001167	11/17/2023	FT-FY24-10102023-001167-A	<1	FT-FY24-10102023-001167-B	<1	
WS-001168	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 116	WF-08212023-001168	11/17/2023	FT-FY24-10102023-001168-A	<1	FT-FY24-10102023-001168-B	<1	
WS-001169	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 117	WF-08212023-001169	11/17/2023	FT-FY24-10102023-001169-A	<1	FT-FY24-10102023-001169-B	<1	
WS-001170	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 118	WF-08212023-001170	11/17/2023	FT-FY24-10102023-001170-A	<1	FT-FY24-10102023-001170-B	<1	
WS-001171	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 118 in bathroom	WF-03152023-001171	11/17/2023	FT-FY24-10102023-001171-A	<1	FT-FY24-10102023-001171-B	<1	
WS-001172	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 119	WF-08212023-001172	11/17/2023	FT-FY24-10102023-001172-A	<1	FT-FY24-10102023-001172-B	<1	
WS-001174	8/21/2023	8/21/2024	1	Classroom Faucet	In classroom 120	WF-08212023-001174	11/17/2023	FT-FY24-10102023-001174-A	<1	FT-FY24-10102023-001174-B	<1	
WS-001175	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 120 in bathroom	WF-03152023-001175	11/17/2023	FT-FY24-10102023-001175-A	<1	FT-FY24-10102023-001175-B	<1	
WS-001176	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to room 121	Low Left	WF-03152023-001176	11/17/2023	FT-FY24-10102023-001176-A	<1	FT-FY24-10102023-001176-B	<1
WS-001177	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to room 121	High Right	WF-03152023-001177	11/17/2023	FT-FY24-10102023-001177-A	<1	FT-FY24-10102023-001177-B	<1
WS-001178	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-03152023-001178	11/17/2023	FT-FY24-10102023-001178-A	<1	FT-FY24-10102023-001178-B	<1
WS-001179	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to boys' restroom	High Right	WF-03152023-001179	11/17/2023	FT-FY24-10102023-001179-A	<1	FT-FY24-10102023-001179-B	<1
WS-001180	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03152023-001180	11/17/2023	FT-FY24-10102023-001180-A	1	FT-FY24-10102023-001180-B	<1
WS-001181	3/15/2023	3/15/2024	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03152023-001181	11/17/2023	FT-FY24-10102023-001181-A	<1	FT-FY24-10102023-001181-B	<1
WS-001182	3/15/2023	3/15/2024	1	Break Room	In staff lounge room 122		WF-03152023-001182	11/17/2023	FT-FY24-10102023-001182-A	<1	FT-FY24-10102023-001182-B	<1
WS-001188	3/15/2023	3/15/2024	1	Health Suite	In health suite 157		WF-03152023-001188	11/17/2023	FT-FY24-10102023-001188-A	<1	FT-FY24-10102023-001188-B	<1
WS-001208	3/15/2023	3/15/2024	2	Cooler	In hallway adjacent room 210	High Right	WF-03152023-001208	11/17/2023	FT-FY24-10102023-001208-A	<1	FT-FY24-10102023-001208-B	<1
WS-001209	3/15/2023	3/15/2024	2	Cooler	In hallway adjacent room 210	Low Left	WF-03152023-001209	11/17/2023	FT-FY24-10102023-001209-A	<1	FT-FY24-10102023-001209-B	<1
WS-001210	3/15/2023	3/15/2024	2	Cooler	In hallway adjacent to room 206	Low Right	WF-03152023-001210	11/17/2023	FT-FY24-10102023-001210-A	<1	FT-FY24-10102023-001210-B	<1

WS-001211	3/15/2023	3/15/2024	2	Cooler	In hallway to adjacent room 206	High Left	WF-03152023-001211	11/17/2023	FT-FY24-10102023-001211-A	<1	FT-FY24-10102023-001211-B	<1
WS-001212	3/15/2023	3/15/2024	2	Cooler	In hallway adjacent to art room 239	Right	WF-03152023-001212	11/17/2023	FT-FY24-10102023-001212-A	<1	FT-FY24-10102023-001212-B	<1
WS-001213	3/15/2023	3/15/2024	2	Cooler	In hallway adjacent to art room 239	Left	WF-03152023-001213	11/17/2023	FT-FY24-10102023-001213-A	<1	FT-FY24-10102023-001213-B	<1
WS-001214	3/15/2023	3/15/2024	1	Cooler	Annex B, in hallway	High Left	WF-03152023-001214	11/17/2023	FT-FY24-10102023-001214-A	<1	FT-FY24-10102023-001214-B	<1
WS-001215	3/15/2023	3/15/2024	1	Cooler	Annex B, in hallway	Low Right	WF-03152023-001215	11/17/2023	FT-FY24-10102023-001215-A	<1	FT-FY24-10102023-001215-B	<1
WS-001216	3/15/2023	3/15/2024	1	Cooler	Annex A, in hallway	High Left	WF-03152023-001216	11/17/2023	FT-FY24-10102023-001216-A	<1	FT-FY24-10102023-001216-B	<1
WS-001217	3/15/2023	3/15/2024	1	Cooler	Annex A, in hallway	Low Right	WF-03152023-001217	11/17/2023	FT-FY24-10102023-001217-A	<1	FT-FY24-10102023-001217-B	<1
WS-002475	3/15/2023	3/15/2024	1	Break Room	In unmarked room on the right just as you enter the main office		WF-03152023-002475	11/17/2023	FT-FY24-10102023-002475-A	<1	FT-FY24-10102023-002475-B	<1
WS-002476	3/15/2023	3/15/2024	1	Bottle Filler	In hallway adjacent to room 121		WF-03152023-002476	11/17/2023	FT-FY24-10102023-002476-A	<1	FT-FY24-10102023-002476-B	<1
WS-002477	3/15/2023	3/15/2024	1	Bottle Filler	In hallway adjacent to girls' restroom		WF-03152023-002477	11/17/2023	FT-FY24-10102023-002477-A	<1	FT-FY24-10102023-002477-B	<1
WS-002478	3/15/2023	3/15/2024	2	Bottle Filler	In hallway adjacent to room 210		WF-03152023-002478	11/17/2023	FT-FY24-10102023-002478-A	<1	FT-FY24-10102023-002478-B	<1
WS-002479	3/15/2023	3/15/2024	2	Bottle Filler	In hallway adjacent to art room 239		WF-03152023-002479	11/17/2023	FT-FY24-10102023-002479-A	<1	FT-FY24-10102023-002479-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001185	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen south wall	Mid	WF-12192022-001185	11/17/2023	FT-FY24-10102023-001185-A	<1	FT-FY24-10102023-001185-B	<1