



Barnard Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001149	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 105 in bathroom	WF-03122024-001149	11/22/2024	FT-FY25-10082024-001149-A	2.5	FT-FY25-10082024-001149-B	<2
WS-001151	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 104	WF-08192024-001151	11/22/2024	FT-FY25-10082024-001151-A	<2	FT-FY25-10082024-001151-B	<2
WS-001152	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 106	WF-08192024-001152	11/22/2024	FT-FY25-10082024-001152-A	<2	FT-FY25-10082024-001152-B	<2
WS-001153	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 106 in bathroom	WF-03122024-001153	11/22/2024	FT-FY25-10082024-001153-A	3.4	FT-FY25-10082024-001153-B	<2
WS-001154	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 105	WF-08192024-001154	11/22/2024	FT-FY25-10082024-001154-A	<2	FT-FY25-10082024-001154-B	<2
WS-001155	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 109	WF-08192024-001155	11/22/2024	FT-FY25-10082024-001155-A	<2	FT-FY25-10082024-001155-B	<2
WS-001156	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 109 in bathroom	WF-03122024-001156	11/22/2024	FT-FY25-10082024-001156-A	4.3	FT-FY25-10082024-001156-B	<2
WS-001157	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 110	WF-08192024-001157	11/22/2024	FT-FY25-10082024-001157-A	<2	FT-FY25-10082024-001157-B	<2
WS-001158	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 110 in bathroom	WF-03122024-001158	11/22/2024	FT-FY25-10082024-001158-A	3.9	FT-FY25-10082024-001158-B	<2
WS-001159	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 111	WF-08192024-001159	11/22/2024	FT-FY25-10082024-001159-A	<2	FT-FY25-10082024-001159-B	<2
WS-001161	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 112	WF-08192024-001161	11/22/2024	FT-FY25-10082024-001161-A	<2	FT-FY25-10082024-001161-B	<2
WS-001162	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 112 in bathroom	WF-03122024-001162	11/22/2024	FT-FY25-10082024-001162-A	2.1	FT-FY25-10082024-001162-B	<2
WS-001163	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 113	WF-08192024-001163	11/22/2024	FT-FY25-10082024-001163-A	<2	FT-FY25-10082024-001163-B	<2
WS-001165	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 114	WF-08192024-001165	11/22/2024	FT-FY25-10082024-001165-A	<2	FT-FY25-10082024-001165-B	<2
WS-001166	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 114 in bathroom	WF-03122024-001166	11/22/2024	FT-FY25-10082024-001166-A	4.7	FT-FY25-10082024-001166-B	<2
WS-001167	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 115	WF-08192024-001167	11/22/2024	FT-FY25-10082024-001167-A	4.9	FT-FY25-10082024-001167-B	<2
WS-001168	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 116	WF-08192024-001168	11/22/2024	FT-FY25-10082024-001168-A	<2	FT-FY25-10082024-001168-B	<2
WS-001169	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 117	WF-08192024-001169	11/22/2024	FT-FY25-10082024-001169-A	<2	FT-FY25-10082024-001169-B	<2
WS-001170	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 118	WF-08192024-001170	11/22/2024	FT-FY25-10082024-001170-A	<2	FT-FY25-10082024-001170-B	<2
WS-001171	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 118 in bathroom	WF-03122024-001171	11/22/2024	FT-FY25-10082024-001171-A	2.0	FT-FY25-10082024-001171-B	<2
WS-001172	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 119	WF-08192024-001172	11/22/2024	FT-FY25-10082024-001172-A	<2	FT-FY25-10082024-001172-B	<2
WS-001173	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 119 in bathroom	WF-03122024-001173	11/22/2024	FT-FY25-10082024-001173-A	<2	FT-FY25-10082024-001173-B	<2
WS-001174	8/19/2024	8/19/2025	1	Classroom Faucet	In classroom 120	WF-08192024-001174	11/22/2024	FT-FY25-10082024-001174-A	<2	FT-FY25-10082024-001174-B	<2
WS-001175	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 120 in bathroom	WF-03122024-001175	11/22/2024	FT-FY25-10082024-001175-A	<2	FT-FY25-10082024-001175-B	<2
WS-001176	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to room 121	WF-03122024-001176	11/22/2024	FT-FY25-10082024-001176-A	<2	FT-FY25-10082024-001176-B	<2
WS-001178	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to boys' restroom	WF-03122024-001178	11/22/2024	FT-FY25-10082024-001178-A	<2	FT-FY25-10082024-001178-B	<2
WS-001179	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to boys' restroom	WF-03122024-001179	11/22/2024	FT-FY25-10082024-001179-A	<2	FT-FY25-10082024-001179-B	<2
WS-001180	3/26/2024	3/26/2025	1	Cooler	In hallway adjacent to girls' restroom	WF-03262024-001180	11/22/2024	FT-FY25-10082024-001180-A	<2	FT-FY25-10082024-001180-B	<2
WS-001181	3/12/2024	3/12/2025	1	Cooler	In hallway adjacent to girls' restroom	WF-03122024-001181	11/22/2024	FT-FY25-10082024-001181-A	<2	FT-FY25-10082024-001181-B	<2
WS-001182	3/12/2024	3/12/2025	1	Break Room	In staff lounge room 122	WF-03122024-001182	11/22/2024	FT-FY25-10082024-001182-A	<2	FT-FY25-10082024-001182-B	<2
WS-001188	3/12/2024	3/12/2025	1	Health Suite	In health suite 157	WF-03122024-001188	11/22/2024	FT-FY25-10082024-001188-A	<2	FT-FY25-10082024-001188-B	<2
WS-001208	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent room 210	WF-03122024-001208	11/22/2024	FT-FY25-10082024-001208-A	<2	FT-FY25-10082024-001208-B	<2
WS-001209	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent room 210	WF-03122024-001209	11/22/2024	FT-FY25-10082024-001209-A	<2	FT-FY25-10082024-001209-B	<2

WS- 001210	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent to room 206	Low	Right	WF-03122024-001210	11/22/2024	FT-FY25-10082024-001210-A	<2	FT-FY25-10082024-001210-B	<2
WS- 001211	3/12/2024	3/12/2025	2	Cooler	In hallway to adjacent room 206	High	Left	WF-03122024-001211	11/22/2024	FT-FY25-10082024-001211-A	<2	FT-FY25-10082024-001211-B	<2
WS- 001212	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent to art room 239		Right	WF-03122024-001212	11/22/2024	FT-FY25-10082024-001212-A	<2	FT-FY25-10082024-001212-B	<2
WS- 001213	3/12/2024	3/12/2025	2	Cooler	In hallway adjacent to art room 239		Left	WF-03122024-001213	11/22/2024	FT-FY25-10082024-001213-A	<2	FT-FY25-10082024-001213-B	<2
WS- 001214	9/12/2024	9/12/2025	1	Cooler	Annex B, in hallway	High	Left	WF-09122024-001214	11/22/2024	FT-FY25-10082024-001214-A	<2	FT-FY25-10082024-001214-B	<2
WS- 001215	9/12/2024	9/12/2025	1	Cooler	Annex B, in hallway	Low	Right	WF-09122024-001215	11/22/2024	FT-FY25-10082024-001215-A	<2	FT-FY25-10082024-001215-B	<2
WS- 001216	3/12/2024	3/12/2025	1	Cooler	Annex A, in hallway	High	Left	WF-03122024-001216	11/22/2024	FT-FY25-10082024-001216-A	<2	FT-FY25-10082024-001216-B	<2
WS- 001217	3/12/2024	3/12/2025	1	Cooler	Annex A, in hallway	Low	Right	WF-03122024-001217	11/22/2024	FT-FY25-10082024-001217-A	<2	FT-FY25-10082024-001217-B	<2
WS- 002476	3/12/2024	3/12/2025	1	Bottle Filler	In hallway adjacent to room 121			WF-03122024-002476	11/22/2024	FT-FY25-10082024-002476-A	<2	FT-FY25-10082024-002476-B	<2
WS- 002477	3/26/2024	3/26/2025	1	Bottle Filler	In hallway adjacent to girls' restroom			WF-03262024-002477	11/22/2024	FT-FY25-10082024-002477-A	<2	FT-FY25-10082024-002477-B	<2
WS- 002478	3/12/2024	3/12/2025	2	Bottle Filler	In hallway adjacent to room 210			WF-03122024-002478	11/22/2024	FT-FY25-10082024-002478-A	<2	FT-FY25-10082024-002478-B	<2
WS- 002479	3/12/2024	3/12/2025	2	Bottle Filler	In hallway adjacent to art room 239			WF-03122024-002479	11/22/2024	FT-FY25-10082024-002479-A	<2	FT-FY25-10082024-002479-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001185	12/5/2023	12/5/2024	1	Food Prep Sink	In kitchen south wall	Mid	WF-12052023-001185	11/22/2024	FT-FY25-10082024-001185-A	<2	FT-FY25-10082024-001185-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001164	3/12/2024	3/12/2025	1	Combo Fountain	In classroom 113 in bathroom	WF-03122024-001164	11/22/2024	FT-FY25-10082024-001164-A	5.6	FT-FY25-10082024-001164-B	<2

After First Re-test (Plumbing Check)

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001164	11/26/2024	11/26/2025	1	Combo Fountain	In classroom 113 in bathroom	WF-11262024-001164	12/17/2024	FT-FY25-12022024-001164-A	<2	FT-FY25-12022024-001164-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.