



Barnard Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001149	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 105 in bathroom	WF-04072020-001149	2/6/2021	FT-FY21-012021-001149-A	<1	FT-FY21-012021-001149-B	<1	
WS-001151	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 104	WF-09142020-001151	2/6/2021	FT-FY21-012021-001151-A	<1	FT-FY21-012021-001151-B	<1	
WS-001152	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 106	WF-09142020-001152	2/6/2021	FT-FY21-012021-001152-A	<1	FT-FY21-012021-001152-B	<1	
WS-001153	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 106 in bathroom	WF-04072020-001153	2/6/2021	FT-FY21-012021-001153-A	1.3	FT-FY21-012021-001153-B	<1	
WS-001154	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 105	WF-09142020-001154	2/6/2021	FT-FY21-012021-001154-A	<1	FT-FY21-012021-001154-B	<1	
WS-001155	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 109	WF-09142020-001155	2/6/2021	FT-FY21-012021-001155-A	<1	FT-FY21-012021-001155-B	<1	
WS-001156	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 109 in bathroom	WF-04072020-001156	2/6/2021	FT-FY21-012021-001156-A	<1	FT-FY21-012021-001156-B	<1	
WS-001157	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 110	WF-09142020-001157	2/6/2021	FT-FY21-012021-001157-A	<1	FT-FY21-012021-001157-B	<1	
WS-001158	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 110 in bathroom	WF-04072020-001158	2/6/2021	FT-FY21-012021-001158-A	<1	FT-FY21-012021-001158-B	<1	
WS-001159	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 111	WF-09142020-001159	2/6/2021	FT-FY21-012021-001159-A	<1	FT-FY21-012021-001159-B	<1	
WS-001160	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 111 in bathroom	WF-04072020-001160	2/6/2021	FT-FY21-012021-001160-A	1.3	FT-FY21-012021-001160-B	<1	
WS-001161	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 112	WF-09142020-001161	2/6/2021	FT-FY21-012021-001161-A	<1	FT-FY21-012021-001161-B	<1	
WS-001162	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 112 in bathroom	WF-04072020-001162	2/6/2021	FT-FY21-012021-001162-A	<1	FT-FY21-012021-001162-B	<1	
WS-001164	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 113 in bathroom	WF-04072020-001164	2/6/2021	FT-FY21-012021-001164-A	1.1	FT-FY21-012021-001164-B	<1	
WS-001166	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 114 in bathroom	WF-04072020-001166	2/6/2021	FT-FY21-012021-001166-A	<1	FT-FY21-012021-001166-B	<1	
WS-001167	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 115	WF-09142020-001167	2/6/2021	FT-FY21-012021-001167-A	<1	FT-FY21-012021-001167-B	<1	
WS-001168	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 116	WF-09142020-001168	2/6/2021	FT-FY21-012021-001168-A	<1	FT-FY21-012021-001168-B	<1	
WS-001169	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 117	WF-09142020-001169	2/6/2021	FT-FY21-012021-001169-A	<1	FT-FY21-012021-001169-B	<1	
WS-001170	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 118	WF-09142020-001170	2/6/2021	FT-FY21-012021-001170-A	<1	FT-FY21-012021-001170-B	<1	
WS-001171	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 118 in bathroom	WF-04072020-001171	2/6/2021	FT-FY21-012021-001171-A	<1	FT-FY21-012021-001171-B	<1	
WS-001172	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 119	WF-09142020-001172	2/6/2021	FT-FY21-012021-001172-A	<1	FT-FY21-012021-001172-B	<1	
WS-001173	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 119 in bathroom	WF-04072020-001173	2/6/2021	FT-FY21-012021-001173-A	<1	FT-FY21-012021-001173-B	<1	
WS-001174	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 120	WF-09142020-001174	2/6/2021	FT-FY21-012021-001174-A	<1	FT-FY21-012021-001174-B	<1	
WS-001175	4/7/2020	4/7/2021	1	Combo Fountain	In classroom 120 in bathroom	WF-04072020-001175	2/6/2021	FT-FY21-012021-001175-A	<1	FT-FY21-012021-001175-B	<1	
WS-001177	4/7/2020	4/7/2021	1	Cooler	In hallway adjacent to room 121	High Right	WF-04072020-001177	2/6/2021	FT-FY21-012021-001177-A	<1	FT-FY21-012021-001177-B	<1
WS-001178	4/7/2020	4/7/2021	1	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-04072020-001178	2/6/2021	FT-FY21-012021-001178-A	<1	FT-FY21-012021-001178-B	<1
WS-001182	4/7/2020	4/7/2021	1	Break Room	In staff lounge room 122		WF-04072020-001182	2/6/2021	FT-FY21-012021-001182-A	<1	FT-FY21-012021-001182-B	<1
WS-001188	4/7/2020	4/7/2021	1	Health Suite	In health suite 157		WF-04072020-001188	2/6/2021	FT-FY21-012021-001188-A	<1	FT-FY21-012021-001188-B	<1
WS-001208	4/7/2020	4/7/2021	2	Cooler	In hallway adjacent room 210	High Right	WF-04072020-001208	2/6/2021	FT-FY21-012021-001208-A	<1	FT-FY21-012021-001208-B	<1
WS-001210	4/7/2020	4/7/2021	2	Cooler	In hallway adjacent to room 206	Low Right	WF-04072020-001210	2/6/2021	FT-FY21-012021-001210-A	<1	FT-FY21-012021-001210-B	<1
WS-001211	4/7/2020	4/7/2021	2	Cooler	In hallway to adjacent room 206	High Left	WF-04072020-001211	2/6/2021	FT-FY21-012021-001211-A	<1	FT-FY21-012021-001211-B	<1
WS-001212	10/12/2020	10/12/2021	2	Cooler	In hallway adjacent to art room 239	Right	WF-10122020-001212	2/6/2021	FT-FY21-012021-001212-A	<1	FT-FY21-012021-001212-B	<1
WS-001214	7/7/2020	7/7/2021	1	Cooler	Annex B, in hallway	High Left	WF-07072020-001214	2/6/2021	FT-FY21-012021-001214-A	1.1	FT-FY21-012021-001214-B	<1
WS-001215	7/7/2020	7/7/2021	1	Cooler	Annex B, in hallway	Low Right	WF-07072020-001215	2/6/2021	FT-FY21-012021-001215-A	1.3	FT-FY21-012021-001215-B	<1
WS-001216	7/7/2020	7/7/2021	1	Cooler	Annex A, in hallway	High Left	WF-07072020-001216	2/6/2021	FT-FY21-012021-001216-A	<1	FT-FY21-012021-001216-B	<1

WS-001217	7/7/2020	7/7/2021	1	Cooler	Annex A, in hallway	Low	Right	WF-07072020-001217	2/6/2021	FT-FY21-012021-001217-A	<1	FT-FY21-012021-001217-B	<1
WS-002475	4/7/2020	4/7/2021	1	Break Room	In unmarked room on the right just as you enter the main office			WF-04072020-002475	2/6/2021	FT-FY21-012021-002475-A	<1	FT-FY21-012021-002475-B	<1
WS-002477	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to girls' restroom			WF-10122020-002477	2/6/2021	FT-FY21-012021-002477-A	1.5	FT-FY21-012021-002477-B	<1
WS-002478	10/12/2020	10/12/2021	2	Bottle Filler	In hallway adjacent to room 210			WF-10122020-002478	2/6/2021	FT-FY21-012021-002478-A	<1	FT-FY21-012021-002478-B	<1
WS-002479	10/12/2020	10/12/2021	2	Bottle Filler	In hallway adjacent to art room 239			WF-10122020-002479	2/6/2021	FT-FY21-012021-002479-A	<1	FT-FY21-012021-002479-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001185	1/5/2021	1/5/2022	1	Food Prep Sink	In kitchen south wall	Mid	WF-01052021-001185	2/6/2021	FT-FY21-012021-001185-A	<1	FT-FY21-012021-001185-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002476	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to room 121		WF-10122020-002476	2/6/2021	FT-FY21-012021-002476-A	<1	FT-FY21-012021-002476-B	5.1

First Re-test (After Plumbing Check)

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002476	2/11/2021	2/11/2022	1	Bottle Filler	In hallway adjacent to room 121		WF-02112021-002476	2/15/2021	FT-FY21-022021-002476-A	<1	FT-FY21-022021-002476-B	<1