



# Barnard ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001149	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 105 in bathroom	WF-04152019-001149	11/18/2019	FT-FY20-112019-001149-A	<1	FT-FY20-112019-001149-B	<1	
WS-001151	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 104	WF-09232019-001151	11/18/2019	FT-FY20-112019-001151-A	<1	FT-FY20-112019-001151-B	<1	
WS-001152	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 106	WF-09232019-001152	11/18/2019	FT-FY20-112019-001152-A	<1	FT-FY20-112019-001152-B	<1	
WS-001153	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 106 in bathroom	WF-04152019-001153	11/18/2019	FT-FY20-112019-001153-A	<1	FT-FY20-112019-001153-B	<1	
WS-001154	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 105	WF-09232019-001154	11/18/2019	FT-FY20-112019-001154-A	<1	FT-FY20-112019-001154-B	<1	
WS-001155	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 109	WF-09232019-001155	11/18/2019	FT-FY20-112019-001155-A	<1	FT-FY20-112019-001155-B	<1	
WS-001156	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 109 in bathroom	WF-04152019-001156	11/18/2019	FT-FY20-112019-001156-A	<1	FT-FY20-112019-001156-B	<1	
WS-001157	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 110	WF-09232019-001157	11/18/2019	FT-FY20-112019-001157-A	<1	FT-FY20-112019-001157-B	<1	
WS-001158	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 110 in bathroom	WF-04152019-001158	11/18/2019	FT-FY20-112019-001158-A	3.3	FT-FY20-112019-001158-B	<1	
WS-001159	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 111	WF-09232019-001159	11/18/2019	FT-FY20-112019-001159-A	<1	FT-FY20-112019-001159-B	<1	
WS-001160	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 111 in bathroom	WF-04152019-001160	11/18/2019	FT-FY20-112019-001160-A	2.7	FT-FY20-112019-001160-B	<1	
WS-001161	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 112	WF-09232019-001161	11/18/2019	FT-FY20-112019-001161-A	<1	FT-FY20-112019-001161-B	<1	
WS-001162	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 112 in bathroom	WF-04152019-001162	11/18/2019	FT-FY20-112019-001162-A	3.4	FT-FY20-112019-001162-B	<1	
WS-001163	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 113	WF-09232019-001163	11/18/2019	FT-FY20-112019-001163-A	<1	FT-FY20-112019-001163-B	<1	
WS-001164	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 113 in bathroom	WF-04152019-001164	11/18/2019	FT-FY20-112019-001164-A	<1	FT-FY20-112019-001164-B	<1	
WS-001165	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 114	WF-09232019-001165	11/18/2019	FT-FY20-112019-001165-A	<1	FT-FY20-112019-001165-B	<1	
WS-001166	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 114 in bathroom	WF-04152019-001166	11/18/2019	FT-FY20-112019-001166-A	<1	FT-FY20-112019-001166-B	<1	
WS-001167	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 115	WF-09232019-001167	11/18/2019	FT-FY20-112019-001167-A	<1	FT-FY20-112019-001167-B	<1	
WS-001168	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 116	WF-09232019-001168	11/18/2019	FT-FY20-112019-001168-A	1.4	FT-FY20-112019-001168-B	<1	
WS-001169	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 117	WF-09232019-001169	11/18/2019	FT-FY20-112019-001169-A	<1	FT-FY20-112019-001169-B	<1	
WS-001170	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 118	WF-09232019-001170	11/18/2019	FT-FY20-112019-001170-A	<1	FT-FY20-112019-001170-B	<1	
WS-001171	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 118 in bathroom	WF-04152019-001171	11/18/2019	FT-FY20-112019-001171-A	1.8	FT-FY20-112019-001171-B	<1	
WS-001172	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 119	WF-09232019-001172	11/18/2019	FT-FY20-112019-001172-A	<1	FT-FY20-112019-001172-B	<1	
WS-001174	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom 120	WF-09232019-001174	11/18/2019	FT-FY20-112019-001174-A	<1	FT-FY20-112019-001174-B	<1	
WS-001175	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 120 in bathroom	WF-04152019-001175	11/18/2019	FT-FY20-112019-001175-A	<1	FT-FY20-112019-001175-B	<1	
WS-001177	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 121	High Right	WF-04152019-001177	11/18/2019	FT-FY20-112019-001177-A	<1	FT-FY20-112019-001177-B	<1
WS-001178	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-04152019-001178	11/18/2019	FT-FY20-112019-001178-A	<1	FT-FY20-112019-001178-B	<1
WS-001179	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to boys' restroom	High Right	WF-04152019-001179	11/18/2019	FT-FY20-112019-001179-A	<1	FT-FY20-112019-001179-B	<1
WS-001180	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04152019-001180	11/18/2019	FT-FY20-112019-001180-A	<1	FT-FY20-112019-001180-B	<1
WS-001181	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to girls' restroom	High Left	WF-04152019-001181	11/18/2019	FT-FY20-112019-001181-A	<1	FT-FY20-112019-001181-B	<1
WS-001182	4/15/2019	4/15/2020	1	Break Room	In staff lounge room 122		WF-04152019-001182	11/18/2019	FT-FY20-112019-001182-A	<1	FT-FY20-112019-001182-B	<1
WS-001188	4/15/2019	4/15/2020	1	Health Suite	In health suite 157		WF-04152019-001188	11/18/2019	FT-FY20-112019-001188-A	<1	FT-FY20-112019-001188-B	<1
WS-001208	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent room 210	High Right	WF-04152019-001208	11/18/2019	FT-FY20-112019-001208-A	<1	FT-FY20-112019-001208-B	<1
WS-001209	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent room 210	Low Left	WF-04152019-001209	11/18/2019	FT-FY20-112019-001209-A	<1	FT-FY20-112019-001209-B	<1
WS-001210	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 206	Low Right	WF-04152019-001210	11/18/2019	FT-FY20-112019-001210-A	<1	FT-FY20-112019-001210-B	<1
WS-001211	4/15/2019	4/15/2020	2	Cooler	In hallway to adjacent room 206	High Left	WF-04152019-001211	11/18/2019	FT-FY20-112019-001211-A	<1	FT-FY20-112019-001211-B	<1
WS-001212	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to art room 239	Right	WF-04152019-001212	11/18/2019	FT-FY20-112019-001212-A	<1	FT-FY20-112019-001212-B	<1

WS-001215	4/15/2019	4/15/2020	1	Cooler	Annex B, in hallway	Low Right	WF-04152019-001215	11/18/2019	FT-FY20-112019-001215-A	<1	FT-FY20-112019-001215-B	<1
WS-001216	4/15/2019	4/15/2020	1	Cooler	Annex A, in hallway	High Left	WF-04152019-001216	11/18/2019	FT-FY20-112019-001216-A	<1	FT-FY20-112019-001216-B	<1
WS-001217	4/15/2019	4/15/2020	1	Cooler	Annex A, in hallway	Low Right	WF-04152019-001217	11/18/2019	FT-FY20-112019-001217-A	<1	FT-FY20-112019-001217-B	<1
WS-002475	4/15/2019	4/15/2020	1	Break Room	In unmarked room on the right just as you enter the main office		WF-04152019-002475	11/18/2019	FT-FY20-112019-002475-A	<1	FT-FY20-112019-002475-B	<1

### FY20 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001173	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 119 in bathroom	WF-04152019-001173	11/18/2019	FT-FY20-112019-001173-A	6.1	FT-FY20-112019-001173-B	<1

### FY20 Filter Test (After Plumbing Check)

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001173	1/28/2020	1/28/2021	1	Combo Fountain	In classroom 119 in bathroom	WF-01282020-001173	2/7/2020	FT-FY20-012020-001173-A	<1	FT-FY20-012020-001173-B	<1