



# Barnard Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type      | Device Location                       | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |    |
|-----------|-----------------------|------------------------|-------|------------------|---------------------------------------|---------------------|--------------------|-------------------------|----------------------------------|-------------------------|----------------------------------|----|
| WS-001149 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 105 in bathroom          | WF-04072020-001149  | 2/6/2021           | FT-FY21-012021-001149-A | <1                               | FT-FY21-012021-001149-B | <1                               |    |
| WS-001151 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 104                      | WF-09142020-001151  | 2/6/2021           | FT-FY21-012021-001151-A | <1                               | FT-FY21-012021-001151-B | <1                               |    |
| WS-001152 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 106                      | WF-09142020-001152  | 2/6/2021           | FT-FY21-012021-001152-A | <1                               | FT-FY21-012021-001152-B | <1                               |    |
| WS-001153 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 106 in bathroom          | WF-04072020-001153  | 2/6/2021           | FT-FY21-012021-001153-A | 1.3                              | FT-FY21-012021-001153-B | <1                               |    |
| WS-001154 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 105                      | WF-09142020-001154  | 2/6/2021           | FT-FY21-012021-001154-A | <1                               | FT-FY21-012021-001154-B | <1                               |    |
| WS-001155 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 109                      | WF-09142020-001155  | 2/6/2021           | FT-FY21-012021-001155-A | <1                               | FT-FY21-012021-001155-B | <1                               |    |
| WS-001156 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 109 in bathroom          | WF-04072020-001156  | 2/6/2021           | FT-FY21-012021-001156-A | <1                               | FT-FY21-012021-001156-B | <1                               |    |
| WS-001157 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 110                      | WF-09142020-001157  | 2/6/2021           | FT-FY21-012021-001157-A | <1                               | FT-FY21-012021-001157-B | <1                               |    |
| WS-001158 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 110 in bathroom          | WF-04072020-001158  | 2/6/2021           | FT-FY21-012021-001158-A | <1                               | FT-FY21-012021-001158-B | <1                               |    |
| WS-001159 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 111                      | WF-09142020-001159  | 2/6/2021           | FT-FY21-012021-001159-A | <1                               | FT-FY21-012021-001159-B | <1                               |    |
| WS-001160 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 111 in bathroom          | WF-04072020-001160  | 2/6/2021           | FT-FY21-012021-001160-A | 1.3                              | FT-FY21-012021-001160-B | <1                               |    |
| WS-001161 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 112                      | WF-09142020-001161  | 2/6/2021           | FT-FY21-012021-001161-A | <1                               | FT-FY21-012021-001161-B | <1                               |    |
| WS-001162 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 112 in bathroom          | WF-04072020-001162  | 2/6/2021           | FT-FY21-012021-001162-A | <1                               | FT-FY21-012021-001162-B | <1                               |    |
| WS-001164 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 113 in bathroom          | WF-04072020-001164  | 2/6/2021           | FT-FY21-012021-001164-A | 1.1                              | FT-FY21-012021-001164-B | <1                               |    |
| WS-001166 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 114 in bathroom          | WF-04072020-001166  | 2/6/2021           | FT-FY21-012021-001166-A | <1                               | FT-FY21-012021-001166-B | <1                               |    |
| WS-001167 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 115                      | WF-09142020-001167  | 2/6/2021           | FT-FY21-012021-001167-A | <1                               | FT-FY21-012021-001167-B | <1                               |    |
| WS-001168 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 116                      | WF-09142020-001168  | 2/6/2021           | FT-FY21-012021-001168-A | <1                               | FT-FY21-012021-001168-B | <1                               |    |
| WS-001169 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 117                      | WF-09142020-001169  | 2/6/2021           | FT-FY21-012021-001169-A | <1                               | FT-FY21-012021-001169-B | <1                               |    |
| WS-001170 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 118                      | WF-09142020-001170  | 2/6/2021           | FT-FY21-012021-001170-A | <1                               | FT-FY21-012021-001170-B | <1                               |    |
| WS-001171 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 118 in bathroom          | WF-04072020-001171  | 2/6/2021           | FT-FY21-012021-001171-A | <1                               | FT-FY21-012021-001171-B | <1                               |    |
| WS-001172 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 119                      | WF-09142020-001172  | 2/6/2021           | FT-FY21-012021-001172-A | <1                               | FT-FY21-012021-001172-B | <1                               |    |
| WS-001173 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 119 in bathroom          | WF-04072020-001173  | 2/6/2021           | FT-FY21-012021-001173-A | <1                               | FT-FY21-012021-001173-B | <1                               |    |
| WS-001174 | 9/14/2020             | 9/14/2021              | 1     | Classroom Faucet | In classroom 120                      | WF-09142020-001174  | 2/6/2021           | FT-FY21-012021-001174-A | <1                               | FT-FY21-012021-001174-B | <1                               |    |
| WS-001175 | 4/7/2020              | 4/7/2021               | 1     | Combo Fountain   | In classroom 120 in bathroom          | WF-04072020-001175  | 2/6/2021           | FT-FY21-012021-001175-A | <1                               | FT-FY21-012021-001175-B | <1                               |    |
| WS-001177 | 4/7/2020              | 4/7/2021               | 1     | Cooler           | In hallway adjacent to room 121       | High Right          | WF-04072020-001177 | 2/6/2021                | FT-FY21-012021-001177-A          | <1                      | FT-FY21-012021-001177-B          | <1 |
| WS-001178 | 4/7/2020              | 4/7/2021               | 1     | Cooler           | In hallway adjacent to boys' restroom | Low Left            | WF-04072020-001178 | 2/6/2021                | FT-FY21-012021-001178-A          | <1                      | FT-FY21-012021-001178-B          | <1 |
| WS-001182 | 4/7/2020              | 4/7/2021               | 1     | Break Room       | In staff lounge room 122              |                     | WF-04072020-001182 | 2/6/2021                | FT-FY21-012021-001182-A          | <1                      | FT-FY21-012021-001182-B          | <1 |
| WS-001188 | 4/7/2020              | 4/7/2021               | 1     | Health Suite     | In health suite 157                   |                     | WF-04072020-001188 | 2/6/2021                | FT-FY21-012021-001188-A          | <1                      | FT-FY21-012021-001188-B          | <1 |
| WS-001208 | 4/7/2020              | 4/7/2021               | 2     | Cooler           | In hallway adjacent room 210          | High Right          | WF-04072020-001208 | 2/6/2021                | FT-FY21-012021-001208-A          | <1                      | FT-FY21-012021-001208-B          | <1 |
| WS-001210 | 4/7/2020              | 4/7/2021               | 2     | Cooler           | In hallway adjacent to room 206       | Low Right           | WF-04072020-001210 | 2/6/2021                | FT-FY21-012021-001210-A          | <1                      | FT-FY21-012021-001210-B          | <1 |
| WS-001211 | 4/7/2020              | 4/7/2021               | 2     | Cooler           | In hallway to adjacent room 206       | High Left           | WF-04072020-001211 | 2/6/2021                | FT-FY21-012021-001211-A          | <1                      | FT-FY21-012021-001211-B          | <1 |
| WS-001212 | 10/12/2020            | 10/12/2021             | 2     | Cooler           | In hallway adjacent to art room 239   | Right               | WF-10122020-001212 | 2/6/2021                | FT-FY21-012021-001212-A          | <1                      | FT-FY21-012021-001212-B          | <1 |
| WS-001214 | 7/7/2020              | 7/7/2021               | 1     | Cooler           | Annex B, in hallway                   | High Left           | WF-07072020-001214 | 2/6/2021                | FT-FY21-012021-001214-A          | 1.1                     | FT-FY21-012021-001214-B          | <1 |
| WS-001215 | 7/7/2020              | 7/7/2021               | 1     | Cooler           | Annex B, in hallway                   | Low Right           | WF-07072020-001215 | 2/6/2021                | FT-FY21-012021-001215-A          | 1.3                     | FT-FY21-012021-001215-B          | <1 |
| WS-001216 | 7/7/2020              | 7/7/2021               | 1     | Cooler           | Annex A, in hallway                   | High Left           | WF-07072020-001216 | 2/6/2021                | FT-FY21-012021-001216-A          | <1                      | FT-FY21-012021-001216-B          | <1 |

|           |            |            |   |               |   |     |       |                    |          |                         |     |                         |    |
|-----------|------------|------------|---|---------------|---|-----|-------|--------------------|----------|-------------------------|-----|-------------------------|----|
| WS-001217 | 7/7/2020   | 7/7/2021   | 1 | Cooler        | Annex A, in hallway   | Low | Right | WF-07072020-001217 | 2/6/2021 | FT-FY21-012021-001217-A | <1  | FT-FY21-012021-001217-B | <1 |
| WS-002475 | 4/7/2020   | 4/7/2021   | 1 | Break Room    | In unmarked room on the right just as you enter the main office |     |       | WF-04072020-002475 | 2/6/2021 | FT-FY21-012021-002475-A | <1  | FT-FY21-012021-002475-B | <1 |
| WS-002477 | 10/12/2020 | 10/12/2021 | 1 | Bottle Filler | In hallway adjacent to girls' restroom                          |     |       | WF-10122020-002477 | 2/6/2021 | FT-FY21-012021-002477-A | 1.5 | FT-FY21-012021-002477-B | <1 |
| WS-002478 | 10/12/2020 | 10/12/2021 | 2 | Bottle Filler | In hallway adjacent to room 210                                 |     |       | WF-10122020-002478 | 2/6/2021 | FT-FY21-012021-002478-A | <1  | FT-FY21-012021-002478-B | <1 |
| WS-002479 | 10/12/2020 | 10/12/2021 | 2 | Bottle Filler | In hallway adjacent to art room 239                             |     |       | WF-10122020-002479 | 2/6/2021 | FT-FY21-012021-002479-A | <1  | FT-FY21-012021-002479-B | <1 |

### Food Prep Sink

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                |                       |                     |                    |                      |                                  |                      |                                  |    |
|---|-----------------------|------------------------|-------|----------------|-----------------------|---------------------|--------------------|----------------------|----------------------------------|----------------------|----------------------------------|----|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location       | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |    |
| WS-001185   | 1/5/2021              | 1/5/2022               | 1     | Food Prep Sink | In kitchen south wall | Mid                 | WF-01052021-001185 | 2/6/2021             | FT-FY21-012021-001185-A          | <1                   | FT-FY21-012021-001185-B          | <1 |

### FY21 Filter Test

| Greater than 5ppb - Devices requiring remediation |                       |                        |       |               |                                 |                     |                    |                      |                                  |                      |                                  |     |
|---|-----------------------|------------------------|-------|---------------|---------------------------------|---------------------|--------------------|----------------------|----------------------------------|----------------------|----------------------------------|-----|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type   | Device Location                 | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |     |
| WS-002476   | 10/12/2020            | 10/12/2021             | 1     | Bottle Filler | In hallway adjacent to room 121 |                     | WF-10122020-002476 | 2/6/2021             | FT-FY21-012021-002476-A          | <1                   | FT-FY21-012021-002476-B          | 5.1 |