



BARNARD LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001217	Cooler	1	Anex A, in hallway	Right Low	WT-042916-1234-A	< 1	WT-042916-1234-B	< 1			
2 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001216	Cooler	1	Annex A, in hallway	Left High	WT-042916-1233-A	< 1	WT-042916-1233-B	< 1			
3 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001215	Cooler	1	Annex B, in hallway	Right Low	WT-042916-1232-A	< 1	WT-042916-1232-B	< 1			
4 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001214	Cooler	1	Annex B, in hallway	Left High	WT-042916-1231-A	< 1	WT-042916-1231-B	< 1			
5 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001213	Cooler	2	In hallway adjacent to room 239 art room	Left	WT-042916-1230-A	< 1	WT-042916-1230-B	< 1			
6 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001212	Cooler	2	In hallway adjacent to room 239	Right	WT-042916-1229-A	< 1	WT-042916-1229-B	< 1			
7 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001211	Cooler	2	In hallway to adjacent room 218	High	WT-042916-1228-A	< 1	WT-042916-1228-B	< 1			
8 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001210	Cooler	2	In hallway adjacent to room 218	Low	WT-042916-1227-A	< 1	WT-042916-1227-B	< 1			
9 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001209	Cooler	2	In hallway adjacent room 216	Low	WT-042916-1226-A	< 1	WT-042916-1226-B	< 1			
10 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001208	Cooler	2	In hallway adjacent room 216	High	WT-042916-1225-A	< 1	WT-042916-1225-B	< 1			
11 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001207	Classroom	2	In room 204		WT-042916-1224-A	< 1	WT-042916-1224-B	< 1			
12 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001206	Classroom	2	In room 205		WT-042916-1223-A	< 1	WT-042916-1223-B	2.55			
13 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001205	Classroom	2	In room 206		WT-042916-1222-A	< 1	WT-042916-1222-B	< 1			
14 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001204	Classroom	2	In room 210		WT-042916-1221-A	< 1	WT-042916-1221-B	< 1			
15 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001203	Classroom	2	In room 211		WT-042916-1220-A	< 1	WT-042916-1220-B	< 1			
16 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001202	Classroom	2	In room 212		WT-042916-1219-A	< 1	WT-042916-1219-B	< 1			
17 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001201	Classroom	2	In room 213		WT-042916-1218-A	< 1	WT-042916-1218-B	< 1			
18 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001200	Classroom	2	In room 214		WT-042916-1217-A	< 1	WT-042916-1217-B	< 1			
19 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001199	Classroom	2	In room 215		WT-042916-1216-A	< 1	WT-042916-1216-B	< 1			
20 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001198	Classroom	2	In room 216		WT-042916-1215-A	< 1	WT-042916-1215-B	1.43			
21 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001197	Classroom	2	In room 217		WT-042916-1214-A	< 1	WT-042916-1214-B	1.23			
22 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001196	Classroom	2	In room 218		WT-042916-1213-A	< 1	WT-042916-1213-B	< 1			
23 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001195	Classroom	2	In room 219		WT-042916-1212-A	< 1	WT-042916-1212-B	< 1			
24 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001194	Classroom	2	In room 220		WT-042916-1211-A	< 1	WT-042916-1211-B	< 1			
25 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001193	Classroom	2	In room 221		WT-042916-1210-A	< 1	WT-042916-1210-B	< 1			
26 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001192	Classroom	2	In art room 239	Left	WT-042916-1209-A	< 1	WT-042916-1209-B	< 1			
27 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001191	Classroom	2	In art room 239 (left-mid)	Mid	WT-042916-1208-A	< 1	WT-042916-1208-B	< 1			
28 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001190	Classroom	2	In art room 239 (right-mid)	Mid	WT-042916-1207-A	< 1	WT-042916-1207-B	< 1			
29 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001189	Classroom	2	In art room 239	Right	WT-042916-1206-A	< 1	WT-042916-1206-B	< 1			
30 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001188	Health Suite	1	In health suite		WT-042916-1205-A	< 1	WT-042916-1205-B	< 1			
31 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001187	Utility	Basement	In boiler room (water source)		WT-042916-1204-A	351	WT-042916-1204-B	2.1	Non-drinking Water Source - Not accessible to children		
32 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001186	Kitchen	1	In kitchen south wall	Right	WT-042916-1203-A	< 1	WT-042916-1203-B	< 1			
33 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001185	Kitchen	1	In kitchen south wall	Mid	WT-042916-1202-A	< 1	WT-042916-1202-B	< 1			
34 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001184	Kitchen	1	In kitchen south wall	Left	WT-042916-1201-A	< 1	WT-042916-1201-B	< 1			
35 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001183	Kitchen	1	In kitchen north wall		WT-042916-1200-A	4.44	WT-042916-1200-B	< 1			
36 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001182	Break Room	1	In room 122		WT-042916-1199-A	< 1	WT-042916-1199-B	< 1			
37 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001181	Cooler	1	In hallway adjacent to bathrooms	Left High	WT-042916-1198-A	< 1	WT-042916-1198-B	< 1			
38 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001180	Cooler	1	In hallway adjacent to bathrooms	Right Low	WT-042916-1197-A	< 1	WT-042916-1197-B	< 1			
39 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001179	Cooler	1	In hallway adjacent to bathrooms	Right High	WT-042916-1196-A	< 1	WT-042916-1196-B	< 1			
40 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001178	Cooler	1	In hallway adjacent to bathrooms	Left Low	WT-042916-1195-A	< 1	WT-042916-1195-B	< 1			
41 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001177	Cooler	1	In hallway adjacent to room 121	Right High	WT-042916-1194-A	< 1	WT-042916-1194-B	< 1			
42 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001176	Cooler	1	In hallway adjacent to room 121	Left Low	WT-042916-1193-A	< 1	WT-042916-1193-B	< 1			
43 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001175	Fountain	1	In room 120		WT-042916-1192-A	1.16	WT-042916-1192-B	1.16			
44 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001174	Classroom	1	In room 120		WT-042916-1191-A	< 1	WT-042916-1191-B	< 1			
45 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001173	Fountain	1	In room 119		WT-042916-1190-A	9.48	WT-042916-1190-B	< 1			
46 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001172	Classroom	1	In room 119		WT-042916-1189-A	< 1	WT-042916-1189-B	< 1			
47 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001171	Fountain	1	In room 118		WT-042916-1188-A	< 1	WT-042916-1188-B	< 1			
48 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001170	Classroom	1	In room 118		WT-042916-1187-A	< 1	WT-042916-1187-B	< 1			
49 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001169	Classroom	1	In room 117		WT-042916-1186-A	< 1	WT-042916-1186-B	< 1			
50 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001168	Classroom	1	In room 116		WT-042916-1185-A	< 1	WT-042916-1185-B	3.01			
51 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001167	Classroom	1	In room 115		WT-042916-1184-A	1.64	WT-042916-1184-B	< 1			
52 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001166	Fountain	1	In room 114		WT-042916-1183-A	< 1	WT-042916-1183-B	< 1			
53 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001165	Classroom	1	In room 114		WT-042916-1182-A	< 1	WT-042916-1182-B	< 1			
54 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001164	Fountain	1	In room 113		WT-042916-1181-A	< 1	WT-042916-1181-B	< 1			
55 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001163	Classroom	1	In room 113		WT-042916-1180-A	< 1	WT-042916-1180-B	< 1			
56 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001162	Fountain	1	In room 112		WT-042916-1179-A	1.13	WT-042916-1179-B	< 1			
57 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001161	Classroom	1	In room 112		WT-042916-1178-A	< 1	WT-042916-1178-B	< 1			
58 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001160	Fountain	1	In room 111		WT-042916-1177-A	2.41	WT-042916-1177-B	< 1			
59 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001159	Classroom	1	In room 111		WT-042916-1176-A	< 1	WT-042916-1176-B	< 1			
60 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001158	Fountain	1	In room 110		WT-042916-1175-A	< 1	WT-042916-1175-B	< 1			
61 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001157	Classroom	1	In room 110		WT-042916-1174-A	< 1	WT-042916-1174-B	< 1			
62 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001156	Fountain	1	In room 109		WT-042916-1173-A	< 1	WT-042916-1173-B	< 1			
63 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001155	Classroom	1	In room 109		WT-042916-1172-A	< 1	WT-042916-1172-B	< 1			
64 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001154	Classroom	1	In room 105		WT-042916-1171-A	< 1	WT-042916-1171-B	< 1			
65 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001153	Fountain	1	In room 106		WT-042916-1170-A	1.5	WT-042916-1170-B	< 1			
66 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001152	Classroom	1	In room 106		WT-042916-1169-A	< 1	WT-042916-1169-B	< 1			
67 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS-001151	Classroom	1	In room 104		WT-042916-1168-A	< 1	WT-042916-1168-B	< 1			



BARNARD LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
68 BARNARD ELEMENTARY SCHOOL	5/3/2016	WS- 001149	Fountain	1	In room 105	WT-042916-1166- A	6.37	WT-042916-1166- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.